



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org




Web : http://www.erda.org



TEST REPORT

TC538919000018688F

SHEET NO. : 1 OF 15

NAME & ADDRESS OF CUSTOMER M/s. Rajasthan Powergen Transformer Pvt. Ltd. Khasra No. 911-914 Karola - Bhinmal Road, Karola, Sanchoe, Rajasthan-343041	TEST REPORT NO. : RP-1920-009858 DATE : 08/06/2019 CUSTOMER REF. NO. : NIL DATED : 04/06/2019 <table border="1"> <tr> <td>DATE OF SAMPLE RECEIPT</td> <td>DATE OF TESTING</td> </tr> <tr> <td>04/06/2019</td> <td>08/06/2019</td> </tr> </table>	DATE OF SAMPLE RECEIPT	DATE OF TESTING	04/06/2019	08/06/2019
DATE OF SAMPLE RECEIPT	DATE OF TESTING				
04/06/2019	08/06/2019				
SAMPLE DESCRIPTION DISTRIBUTION TRANSFORMER NON-SEALED TYPE RATING : 10 kVA RATED VOLTS : 11000/433 V RATED CURRENT : 0.525/13.33 A NO. OF PHASE : 03 TYPE OF COOLING : ONAN FREQUENCY : 50 Hz % IMPEDANCE : 4.5% VECTOR GROUP : Dyn 11 B.I.L. : H. V. : 28 kVrms / 95 kVp L.V. : 3 kVrms /----	SAMPLE IDENTIFICATION SR. NO. : RPTPL-001 YEAR OF MFG. : 2019 MFG. BY : M/s. Rajasthan Powergen Transformer Pvt. Ltd. ERDA SAMPLE CODE No.: ERDA-00319068				
TEST DETAIL : Lightning Impulse Test with Chopped on the Tail on all the three phases of HV Terminals at 95 kVp. ENCLOSURE : DRG. NO.: 1) RPTPL-10KVA-RP-01/02-2019 2) RPTPL-10KVA-RP-02/02-2019 3) RPTPL-GA-10KVA-02-2019 TEST WITNESSED BY : ---- REMARKS : From the observation of enclosed oscillographic records, it is concluded that the transformer conforms to the requirements of the above mentioned standard with respect to the test carried out.	TEST SPECIFICATION : As per IS:1180 (Part-I)-2014, Cl.No. 21.3.a Amendment No.1 & 2 & 3 and Test voltage was specified by the customer. (Test Procedure was followed as per IS : 2026-(Part-III)-2009, Cl. No. 14) 				
 PREPARED BY	 A. S. Khopkar APPROVED BY				
Note : 1. This report relates only to the particular sample received in good condition for testing at ERDA Vadodara. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from Director, ERDA. 4. Only the tests asked for by the customer have been carried out. 5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be constructed as where the cause has arisen Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.					

TC 2795377



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC538919000018688F

TEST REPORT NO. : RP-1920-009858

SHEET NO.: 2 of 15

DATE : 08/06/2019

Waveform	Comment	Ut / kVp	T1 / μ s	T2 / μ s	Tc / μ s
1U PHASE					
1	LI RW	-54.322	1.361	46.603	
2	100% LI FW	-94.515	1.382	46.718	
3	LI CRW	-55.426	1.350		3.057
4	110% LI CFW	-104.491	1.385		2.707
5	110% LI CFW	-103.810	1.369		3.724
6	100% LI FW	-96.136	1.383	46.723	
7	100% LI FW	-94.417	1.372	46.723	
1V PHASE					
8	LI RW	-54.717	1.361	46.638	
9	100% LI FW	-96.448	1.373	46.754	
10	LI CRW	-55.838	1.364		3.379
11	110% LI CFW	-104.828	1.399		2.573
12	110% LI CFW	-102.774	1.367		3.307
13	100% LI FW	-95.153	1.378	46.714	
14	100% LI FW	-95.967	1.383	46.738	
1W PHASE					
15	LI RW	-57.471	1.371	46.526	
16	100% LI FW	-96.050	1.378	46.650	
17	LI CRW	-56.496	1.352		3.307
18	110% LI CFW	-102.255	1.379		2.986
19	110% LI CFW	-103.772	1.377		4.262
20	100% LI FW	-94.732	1.374	46.657	
21	100% LI FW	-95.712	1.380	46.760	

TC 2795334

PREPARED BY *Neemishg*

CHECKED BY *P. Patel*





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC538919000018688F

TEST REPORT NO. : RP-1920-009858

DATE : 08/06/2019

SHEET NO.: 3 of 15




Fig.: 1

$U_p = -54.32 \text{ kV}$

$T_1 = 1.36 \text{ μs}$

$T_2 = 46.60 \text{ μs}$

$T_c = \text{μs}$

Comment: LI RW




Fig.: 2

$U_p = -94.51 \text{ kV}$

$T_1 = 1.38 \text{ μs}$

$T_2 = 46.72 \text{ μs}$

$T_c = \text{μs}$

Comment: 100% LI FW

Demishg

PREPARED BY

P. Patel

CHECKED BY

TC 2795335





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




TC538919000018688F


TEST REPORT NO. : RP-1920-009858

DATE : 08/06/2019

SHEET NO.: 4 of 15



Comment: LI CRW



Comment: 110% LI CFW

TC 2795336

PREPARED BY



CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC538919000018688F

TEST REPORT NO. : RP-1920-009858

DATE : 08/06/2019

SHEET NO.: 5 of 15




Fig.: 5

$U_p = -103.81 \text{ kV}$

$T_1 = 1.37 \mu\text{s}$

$T_2 = \mu\text{s}$

$T_c = 3.72 \mu\text{s}$

Comment: 110% LI CFW




Fig.: 6

$U_p = -96.14 \text{ kV}$

$T_1 = 1.38 \mu\text{s}$

$T_2 = 46.72 \mu\text{s}$

$T_c = \mu\text{s}$

Comment: 100% LI FW

TC 2795337

PREPARED BY



CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC538919000018688F

TEST REPORT NO. : RP-1920-009858

SHEET NO.: 6 of 15

DATE : 08/06/2019





Fig.: 7

$U_p = -94.42 \text{ kV}$

$T_1 = 1.37 \mu\text{s}$

$T_2 = 46.72 \mu\text{s}$

$T_c = \mu\text{s}$



Comment: 100% LI FW





Fig.: 8

$U_p = -54.72 \text{ kV}$

$T_1 = 1.36 \mu\text{s}$

$T_2 = 46.64 \mu\text{s}$

$T_c = \mu\text{s}$



Comment: LI RW

Nimishg

PREPARED BY

Rahul

CHECKED BY



TC 2795338



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC538919000018688F

TEST REPORT NO. : RP-1920-009858

DATE : 08/06/2019

SHEET NO.: 7 of 15





Fig.: 9

$U_p = -96.45 \text{ kV}$

$T_1 = 1.37 \text{ µs}$

$T_2 = 46.75 \text{ µs}$

$T_c = \text{µs}$



Comment: 100% LI FW





Fig.: 10

$U_p = -55.84 \text{ kV}$

$T_1 = 1.36 \text{ µs}$

$T_2 = \text{µs}$

$T_c = 3.38 \text{ µs}$



Comment: LI CRW

TC 2795339

PREPARED BY



CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC538919000018688F

TEST REPORT NO. : RP-1920-009858

DATE : 08/06/2019

SHEET NO.: 8 of 15




Fig.: 11

$U_p = -104.83 \text{ kV}$

$T_1 = 1.40 \mu\text{s}$

$T_2 = \mu\text{s}$

$T_c = 2.57 \mu\text{s}$

Comment: 110% LI CFW




Fig.: 12

$U_p = -102.77 \text{ kV}$

$T_1 = 1.37 \mu\text{s}$

$T_2 = \mu\text{s}$

$T_c = 3.31 \mu\text{s}$

Comment: 110% LI CFW

Damishg
PREPARED BY

P. Patel
CHECKED BY

TC 2795340





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC538919000018688F

TEST REPORT NO. : RP-1920-009858

DATE : 08/06/2019

SHEET NO.: 9 of 15




Fig.: 13

$U_p = -95.15 \text{ kV}$

$T_1 = 1.38 \text{ } \mu\text{s}$

$T_2 = 46.71 \text{ } \mu\text{s}$

$T_c = \text{ } \mu\text{s}$

Comment: 100% LI FW




Fig.: 14

$U_p = -95.97 \text{ kV}$

$T_1 = 1.38 \text{ } \mu\text{s}$

$T_2 = 46.74 \text{ } \mu\text{s}$

$T_c = \text{ } \mu\text{s}$

Comment: 100% LI FW

Arminishg
PREPARED BY

P. Patel
CHECKED BY

TC 2795341





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC538919000018688F

TEST REPORT NO. : RP-1920-009858

SHEET NO.: 10 of 15

DATE : 08/06/2019




Fig.: 15
 $U_p = -57.47 \text{ kV}$
 $T_1 = 1.37 \mu\text{s}$
 $T_2 = 46.53 \mu\text{s}$
 $T_c = \mu\text{s}$

Comment: LI RW




Fig.: 16
 $U_p = -96.05 \text{ kV}$
 $T_1 = 1.38 \mu\text{s}$
 $T_2 = 46.65 \mu\text{s}$
 $T_c = \mu\text{s}$

Comment: 100% LI FW

TC 2795342

PREPARED BY
 @nimishg

CHECKED BY
 P. Patel





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC538919000018688F

TEST REPORT NO. : RP-1920-009858

SHEET NO.: 11 of 15

DATE : 08/06/2019




Fig.: 17

$U_p = -56.50 \text{ kV}$

$T_1 = 1.35 \mu\text{s}$

$T_2 = \mu\text{s}$

$T_c = 3.31 \mu\text{s}$

Comment: LI CRW




Fig.: 18

$U_p = -102.26 \text{ kV}$

$T_1 = 1.38 \mu\text{s}$

$T_2 = \mu\text{s}$

$T_c = 2.99 \mu\text{s}$

Comment: 110% LI CFW

TC 2795343

PREPARED BY

Damishy



CHECKED BY

P. Patel



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC538919000018688F

TEST REPORT NO. : RP-1920-009858

DATE : 08/06/2019

SHEET NO.: 12 of 15




Fig.: 19

$U_p = -103.77 \text{ kV}$

$T_1 = 1.38 \mu\text{s}$

$T_2 = \mu\text{s}$

$T_c = 4.26 \mu\text{s}$

Comment: 110% LI CFW




Fig.: 20

$U_p = -94.73 \text{ kV}$

$T_1 = 1.37 \mu\text{s}$

$T_2 = 46.66 \mu\text{s}$

$T_c = \mu\text{s}$

Comment: 100% LI FW

TC 2795344

PREPARED BY



CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



TC538919000018688F

TEST REPORT NO. : RP-1920-009858

SHEET NO.: 13 of 15

DATE : 08/06/2019




Fig.: 21

$U_p = -95.71 \text{ kV}$

$T_1 = 1.38 \mu\text{s}$

$T_2 = 46.76 \mu\text{s}$

$T_c = \mu\text{s}$

Comment: 100% LI FW

TC 2795345

Amishg
PREPARED BY



P. Patel
CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



TC538919000018688F

TEST REPORT NO. : RP-1920-009858

SHEET NO.: 14 of 15

DATE : 08/06/2019

PHOTOGRAPH OF TEST SAMPLE



TC 2795346

Nimishg
PREPARED BY



P. Patel
CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC538919000018688F

TEST REPORT NO. : RP-1920-009858

SHEET NO.: 15 of 15

DATE : 08/06/2019

PHOTOGRAPH OF RATING AND TERMINAL MARKING PLATE

DISTRIBUTION TRANSFORMER

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.

Karoli-Bhinmal Road, Karoli, Santhore-343 041
Dist: Rajasthan INDIA

IS 1180 (2014)

PHASE TRANSFORMER

STANDARD	IS 1180 (2014)	ENERGY EFFICIENCY LEVEL	
KVA	10	MAX. TOTAL LOSSES	
VOLTS AT HV	11000	AT 50% RATED LOAD W	5.0
NO LOAD	LV	MAX. TOTAL LOSSES	
BIL	HV	AT 100% RATED LOAD W	0.8
	LV	TYPE OF COOLING	ANAL
AMPERES	HV	TEMP RISE OIL DEG. °C	55
	LV	TEMP RISE WDG DEG. °C	65
FREQUENCY	50	MASS OF OIL	KG5
VECTOR GROUP REF.	Yd11	TOTAL MASS	KG3
IMPEDANCE VOLT %	4.5	VOL. OF OIL	L
TAPPING		MONTH & YEAR OF MFG.	08/2019
FOR HV VARIATION		SERIAL NO.	1920009858
IN STEP FROM	TD		
CUSTOMER ORDER NO.			

MADE IN INDIA

2V 2U 2V 2W

1U 1V 1W

Dyn11

1U

2U 2V 2W

1W

TC 2795347

Nimishg
PREPARED BY



Puneel
CHECKED BY

DISTRIBUTION TRANSFORMER

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.

KAROLA-BHINMAL-ROD KAROLA SANCHORE-343041
RAJASTHAN.(INDIA)



PART-I
CM/L-8400030105

3 PHASE TRANSFORMER

STANDARD	IS: 1180 (2014)	ENERGY EFFICIENCY LEVEL	—
KVA	10	MAX. TOTAL LOSSES	
VOLTS AT NO LOAD	HV 11000 LV 433	AT 50% RATED LOAD W	84
BIL	HV 95kVp/28kVrms LV —/3kVrms	MAX. TOTAL LOSSES	
AMPERES	HV 0.525 LV 13.33	AT 100% RATED LOAD W	240
FREQUENCY	50 Hz	TYPE OF COOLING	ONAN
VECTOR GROUP REF.	Dyn-11	TEMP RISE OIL DEG C	35
IMPEDANCE VOLT %	4.5	TEMP RISE WDG DEG C	40
TAPPING	—	MASS OF OIL KGS	63
FOR HV VARIATION		TOTAL MASS KGS	262
IN — STEP FROM — TO — %		VOL. OF OIL L	75
CUSTOMER		MONTH & YEAR OF MFG.	MAY-2019
ORDER NO.		SERIAL NO.	RPTPL-001

MADE IN INDIA

95

105

Test Report No. RP-1920-009858
Date 08/06/2019
Product: 10kVA ximer
Verified By: [Signature]
Verification of this drawing by ERDA is limited to relevant dimensional checks only.
Verified dimensions are marked with *

SIZE: 105x105 mm HOLE CENTER: 95x95 mm

NOTE:

* SERIAL NO.
YEAR OF MANUFACTURE &
MONTH OF MANUFACTURE
WILL BE PUNCHED AT THE TIME OF DISPATCH
MATERIAL : Anodized Aluminum
THICKNESS : 1.5mm

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.


KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041
RAJASTHAN

DRN BY		RATING & TERMINAL MARKING PLATE FOR 10 KVA, 11/0.433 KV DISTRIBUTION TRANSFORMER
CHD BY		
APPD BY		

REV. NO.	DATE SIGN	BRIEF DESCRIPTION
	30.05.2019	01 of 02



DRG. NO. RPTPL-10KVA-RP-01/02-2019



SIZE: 105x105 mm HOLE CENTER: 95x95 mm

NOTE:
 * SERIAL NO ,
 YEAR OF MANUFACTURE &
 MONTH OF MANUFACTURE
 WILL BE PUNCHED AT THE TIME OF DISPATCH
 MATERIAL : Anodized Aluminum
 THICKNESS : 1.5 mm




RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.


KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041
 RAJASTHAN

DRN BY		RATING & TERMINAL MARKING PLATE FOR 10 KVA, 11/0.433 KV DISTRIBUTION TRANSFORMER
CHD BY		
APPD BY		

REV. NO.	DATE SIGN	BRIEF DESCRIPTION
	30.05.2019	02 of 02




DRG. NO. RPTPL-10KVA-RP-02/02-2019



ELEVATION

SIDE VIEW



PLAN

SR.NO.	ACCESSORIES	QTY.	TECHNICAL DETAILS	
			AS PER SPEC.	PER OFFER
1	OIL FILLING CAP	1	M.S.	M.S.
2	OIL LEVEL GAUGE WITH 3 POSITION	1	---	---
3	SILICAGEL BREATHER (500 Grams.)	1	AL DIE CAST AL VIE CAST	---
4	H.V. TERMINAL 12mm. DIA. WITH NUT	3	BRASS	BRASS
5	H.V. BUSHING 12KV, 250A	3	PORCELAIN	PORCELAIN
6	L.V. TERMINAL 12 mm. DIA. WITH NUT	4	BRASS	BRASS
7	RATING & TERMINAL MARKING PLATE	1	ANODIZED ALUMINIZED AL	---
8	STIFFENER ANGLE SIZE (40x40x5 mm.)	4	M.S.	M.S.
9	EARTHING TERMINAL WITH LUGS SIZE (16 Amp.)	2	M.S.	M.S.
10	BASE CHANNELS 75x40x460mm. LONG.	2	M.S.	M.S.
11	L.V. BUSHING TURRET	4	TENDER DRG.	TENDER DRG.
12	L.V. BUSHING 11KV/250A	4	PORCELAIN	PORCELAIN
13	THERMOMETER POCKET	1	M.S.	M.S.
14	LIFTING LUGS FOR COVER	2	M.S.	M.S.
15	LIFTING LUGS FOR TANK REINFORCED WITH PLAT	2	M.S.	M.S.
16	AIR RELEASE PLUG	1	M.S.	M.S.
17	PULLING LUG	4	M.S.	M.S.
18	METALLIC TIN PLATE	1	S.S.	S.S.
19	MCCB BOX	1	---	---

COOLING DETAILS

1	TOTAL SURFACE AREA :-	N. A.
2	NUMBER OF RADIATORS	N. A.
3	HEIGHT x WIDTH OF FINS	N. A.
4	TOTAL NUMBER OF COOLING FINS	N. A.

1	WEIGHTS IN KGS.	3	DIMENSIONS IN m.m.
1	CORE (+/- 5% TOL.)	54	TRANSFORMER OVERALL (+/- 10% TOL.)
	WINDINGS (+/- 5% TOL.)	36	L = 935
	TANK & FITTINGS (+/- 5% TOL.)	109	W = 480
	OIL (+/- 5% TOL.)	63	H = 1120
	TOTAL WEIGHT (+/- 10% TOL.)	262	TRANSFORMER TANK (+/- 5% TOL.)
2	THICKNESS IN m.m.		L1 = 695
	TANK SIDE PLATES (MIN.)	3.15	W1 = 270
	TOP & BOTTOM PLATES (MIN.)	5	H1/H2 = 575/585
			4 BUSHING CLEARANCES WITH ANGLE
			L3 (H.V.) 255 PHASE TO PHASE
			L4 (L.V.) 75 PHASE TO PHASE
			L5 (H.V.) 205 PHASE TO EARTH
			L6 (L.V.) 55 PHASE TO EARTH

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041

GENERAL ARRANGEMENT DRAWING
10 KVA 11/0.433 KV DIST. TRANSFORMER

DRG.NO.: RPTPL-GA-10KVA-02-2019
DATE: 30.05.2019

- NOTE
- 1 SHAPE OF TANK: RECTANGULAR SHAPE
 - 2 ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE STATED.
 - 3 METALLIC TIN PLATE: OPPOSITE SIDE OF COMBINED NAME PLATE
 - 4 * NOT PROVIDED DURING TESTING

Test Report No. RP-1910-009859
Date: 08.10.2019
Product: 10 KVA Dist. Transformer
Verified By: [Signature]
Verification of this drawing by [Signature] is limited to relevant dimensional checks only.
Verified dimensions are marked with *

