



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
 (Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
 ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
 EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
 Fax : +91 (0265) 2638382
 E-mail : erda@erda.org
 Web : http://www.erda.org



TEST REPORT

ULR-TC538919000019971F

SHEET 1 OF 21

<p>NAME & ADDRESS OF CUSTOMER</p> <p>RAJASTHAN POWERGEN TRANSFORMER PVT. LTD. Khasara No. 911-914 Karola-Bhinmal Road, Karola, Sanchore, Rajasthan - 343 041 (INDIA)</p>	<p>TEST REPORT NO.: RP-1920-011584 DATE: 22/06/2019</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">CUSTOMER REF. No.: Nil</td> <td style="width: 50%;">DATED: 15/06/2019</td> </tr> <tr> <td>DATE OF SAMPLE RECEIPT: 04/06/2019</td> <td>DATE OF TESTING: 17/06/2019 to 22/06/2019</td> </tr> </table>	CUSTOMER REF. No.: Nil	DATED: 15/06/2019	DATE OF SAMPLE RECEIPT: 04/06/2019	DATE OF TESTING: 17/06/2019 to 22/06/2019
CUSTOMER REF. No.: Nil	DATED: 15/06/2019				
DATE OF SAMPLE RECEIPT: 04/06/2019	DATE OF TESTING: 17/06/2019 to 22/06/2019				
<p>SAMPLE DESCRIPTION</p> <p>10 kVA Distribution Transformer</p> <p>11000/433 Volts, 0.525/13.33 Amp., Oil filled, Vector Group: Dyn-11, Further details as per sheet No. 3 OF 21</p>	<p>SAMPLE IDENTIFICATION</p> <p>ERDA SAMPLE CODE NO.: ERDA-00319068</p> <p>SERIAL NO.: RPTPL-001</p> <p>YEAR OF MFG.: 2019</p>				
<p>TEST DETAILS</p> <p>Short-circuit withstand test [Cl. No. 17 & 21.3 c)]</p> <p>ENCLOSURES:</p> <p>Number of oscillograms : Eleven Number of photograph : One Number of test circuit diagram : One Number of drawings : Five</p> <p>REMARKS: The sample conforms to the requirements for short-circuit withstand test as specified by customer.</p>	<p>TEST SPECIFICATIONS</p> <p>As per customer's requirement & test procedure followed as per IS 1180 (Part 1): 2014 [Amendment No. 1, 2 & 3]</p>				
<p style="text-align: center;"><i>W.P.</i></p> <p>PREPARED BY</p>	<p style="text-align: center;"><i>B.M.</i></p> <p>CHECKED BY</p>	<p style="text-align: center;"><i>Soni</i></p> <p>S. P. SONI APPROVED BY</p>			

- NOTE:**
1. This report relates only to the particular sample received for testing in good condition at ERDA.
 2. This report cannot be reproduced in part under any circumstances.
 3. Publication of this report requires prior permission in writing from Director, ERDA.
 4. Only test asked for by customer have been carried out.
 5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arisen.

Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.



TC 2806573



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

DATE: 22/06/2019

SHEET 2 OF 21

Contents	
1. Technical specifications of test object assigned by customer	Sheet No. 3 OF 21
2. Routine tests before short circuit	Sheet No. 4 OF 21 to 5 OF 21
3. Short-circuit withstand test	Sheet No. 6 OF 21 to 7 OF 21
4. Routine tests after short circuit	Sheet No. 8 OF 21 to 9 OF 21
5. Oscillogram	Sheet No. 10 OF 21 to 20 OF 21
6. Photograph	Sheet No. 21 OF 21
7. Oscillogram No.	0327/01 to 0327/11
8. Photograph No.	1920-003977/0308
9. Test circuit diagram No.	OLSC/DTC/01
10. Drawing No.	RPTPL-10KVA-RP-01/02-2019 RPTPL-10KVA-RP-02/02-2019 RPTPL-GA-10KVA-02-2019 RPTPL-TD-10KVA-03-2019 RPTPL-IA-10KVA-04-2019


PREPARED BY


CHECKED BY

TC 2806542





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

DATE: 22/06/2019

SHEET 3 OF 21

TECHNICAL SPECIFICATIONS OF TEST OBJECT ASSIGNED BY CUSTOMER

1. Name of manufacturer	: RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
2. Equipment	: 10 kVA Distribution Transformer
3. Standard No.	: As per customer's requirement & test procedure followed as per [Cl. No. (17 & 21.3 c)] of IS 1180 (Part 1): 2014 [Amendment No. 1, 2 & 3]
4. Serial No.	: RPTPL-001
5. Type	: Outdoor, Oil Cooled, AI wound, CRGO core, Non Sealed type, Concentric circular coil
6. kVA rating	: 10
7. Rated voltage H.V. (Volts)	: 11000
L.V. (Volts)	: 433
8. Rated current H.V. (Amp.)	: 0.525
L.V. (Amp.)	: 13.33
9. Number of phases	: 3
10. Connection H.V./L.V.	: Delta/Star
11. Frequency (Hz.)	: 50
12. Type of cooling	: ONAN
13. Temperature rise of oil/winding	: 35°C/40°C
14. Percentage Impedance	: 4.5 %
15. Primary winding conductor	: SE Aluminium wire, bare dia. 0.76mm
16. Secondary winding conductor	: DPC Aluminium strip (3mm x 7mm)
17. Quantity of oil (Litre)	: 75
18. Weight of oil (kg.)	: 63
19. Total weight (kg.)	: 262
20. Vector group	: Dyn-11
21. Year of manufacture	: 2019
22. Insulation level H.V.	: 28 kVrms
23. Insulation level L.V.	: 3 kVrms
24. Total losses at 75°C (Watts)	: 84 Max. (at 50 % load)
25. Total losses at 75°C (Watts)	: 240 Max. (at 100 % load)

TC 2806541

WP
PREPARED BY

BP
CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
 (Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
 ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
 EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
 Fax : +91 (0265) 2638382
 E-mail : erda@erda.org
 Web : http://www.erda.org



ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

SHEET 4 OF 21

DATE: 22/06/2019**ROUTINE TEST RESULTS BEFORE SHORT CIRCUIT**a) MEASUREMENT OF WINDING RESISTANCE

Measurement at oil temperature: 37.4°C					
LV Winding resistance (mΩ)			HV Winding Resistance (Ω)		
u - v	v - w	w - u	U - V	V - W	W - U
201.64	201.86	201.66	217.50	217.48	217.20

b) MEASUREMENT OF VOLTAGE RATIO AND CHECK OF PHASE DISPLACEMENT

Vector group: Dyn-11 was verified.

Rated turns Ratio	Measured turns ratio between Terminals					
	U-V/u-n	Difference %	V-W/v-n	Difference %	W-U/w-n	Difference %
44.001	44.000	-0.002	44.025	0.055	44.034	0.075

c) MEASUREMENT OF SHORT-CIRCUIT IMPEDANCE AND LOAD LOSS (at 100 % load)

Oil temp.: 36.1°C

Test current (Amp.) Iavg.	Impedance voltage (V) Vavg.	Frequency (Hz.)	Load loss measured (Watts)	Impedance Voltage (%Z) At 50 Hz.	Load loss computed at 75°C (Watts)	%Z at 75°C
0.525	478.115	50.124	146.101	4.336	167	4.410

d) MEASUREMENT OF LOAD LOSS (at 50 % load)

Oil temp.: 36.1°C

Test current (Amp.) Iavg.	Impedance voltage (V) Vavg.	Frequency (Hz.)	Load loss measured (Watts)	Load loss computed at 75°C (Watts)
0.262	238.283	50.069	36.397	42

TC 2806572

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

SHEET 5 OF 21

DATE: 22/06/2019e) MEASUREMENT OF NO-LOAD LOSS AND CURRENT

Oil temp.: 36.1°C

Applied Voltage (V) Vavg.	Current (Amp.) Iavg.	Freq. (Hz.)	Losses Measured (Watts)
433.090	0.188	50.013	33

- Total losses at 75°C: 75 Watts (at 50 % load)

- Total losses at 75°C: 200 Watts (at 100% load)

f) MEASUREMENT OF INSULATION RESISTANCE

Oil temp.: 37.4°C

Measured between	DC Test Voltage (V)	IR value (MΩ)
HV to LV winding	2500	> 2000
HV winding to LV + EARTH	2500	> 2000
LV winding to HV + EARTH	500	> 2000

g) INDUCED OVER-VOLTAGE WITHSTAND TEST

Sr. No.	Test	Applied voltage (V)	Applied Freq. (Hz.)	Duration (sec.)	Remarks
1.	Between LV windings with tank connected to earth.	866	100	60	Withstood

h) SEPARATE-SOURCE VOLTAGE WITHSTAND TEST

Sr. no.	Test	Applied voltage (kV)	Duration (sec.)	Remarks
1.	Between HV winding and LV winding connected to the tank and earth	28	60	Withstood
2.	Between LV winding and HV winding connected to the tank and earth	03	60	Withstood

TC 2806571

PREPARED BY *Wp*CHECKED BY *B.M.*



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

SHEET 6 OF 21

DATE: 22/06/2019**SHORT-CIRCUIT WITHSTAND TEST:**

The verification of the short-circuit withstand test was performed on the high voltage winding connected to three phase-balanced source and low voltage winding short circuited through current measuring instruments. Test conducted with pre set short circuit as per schematic circuit diagram No.: OLSC/DTC/01.

Condition of the equipment under test: As after routine tests.

Supply Frequency: 50 Hz.

Test No.	Oscillogram No.	Applied voltage (kVrms)	Short circuit current on LV (A)			Duration (sec.)	Remarks
			Peak	RMS	Avg.		
1.	0327/01	-	- 464 -	240 237 233	237	0.1	Calibration shot
2.	0327/02	11	- 580 -	307 303 300	303	0.5	No Abnormality
3.	0327/03	11	- 570 -	307 302 299	303	0.5	No Abnormality
4.	0327/04	11	- 575 -	306 302 298	302	0.5	No Abnormality
5.	0327/05	11	- - 578	307 302 299	303	0.5	No Abnormality
6.	0327/06	11	- - 576	307 301 299	302	0.5	No Abnormality
7.	0327/07	11	- - 570	307 301 298	302	0.5	No Abnormality
8.	0327/08	11	577 - -	307 301 298	302	0.5	No Abnormality
9.	0327/09	11	572 - -	307 301 298	302	0.5	No Abnormality
10.	0327/10	11	574 - -	305 299 297	300	0.5	No Abnormality
11.	0327/11	11	- 576 -	305 300 297	301	2.0	Thermal shot* No Abnormality

*As per customer's requirement

PREPARED BY

CHECKED BY



TC 2806538



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

SHEET 7 OF 21

DATE: 22/06/2019**Measurement of the % reactance during the short circuit test**

LV winding was short circuited. Three phase AC supply was connected to HV winding to pass test current. Before the short circuit test and after each shot, the percentage reactance was measured.

Sr. No.	Measurement performed		Measured value of % reactance at 50 Hz.			%Change in % reactance		
			U	V	W	U	V	W
1.	Before test		4.13	4.14	4.16	-	-	-
2.	After the test no.	2.	4.14	4.15	4.16	0.24	0.24	0.00
3.	After the test no.	3.	4.14	4.15	4.16	0.24	0.24	0.00
4.	After the test no.	4.	4.14	4.14	4.16	0.24	0.00	0.00
5.	After the test no.	5.	4.13	4.15	4.16	0.00	0.24	0.00
6.	After the test no.	6.	4.14	4.15	4.16	0.24	0.24	0.00
7.	After the test no.	7.	4.14	4.15	4.16	0.24	0.24	0.00
8.	After the test no.	8.	4.14	4.15	4.16	0.24	0.24	0.00
9.	After the test no.	9.	4.14	4.15	4.16	0.24	0.24	0.00
10.	After the test no.	10.	4.13	4.15	4.16	0.00	0.24	0.00
11.	After the test no.	11.	4.14	4.14	4.16	0.24	0.00	0.00


PREPARED BY

CHECKED BY

TC 2806537





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

SHEET 8 OF 21

DATE: 22/06/2019**ROUTINE TEST RESULTS AFTER SHORT CIRCUIT**a) MEASUREMENT OF WINDING RESISTANCE

Measurement at oil temperature: 33.9°C					
LV Winding resistance (mΩ)			HV Winding Resistance (Ω)		
u - v	v - w	w - u	U - V	V - W	W - U
198.86	199.13	198.94	214.64	214.60	214.34

b) MEASUREMENT OF VOLTAGE RATIO AND CHECK OF PHASE DISPLACEMENT

Vector group: Dyn-11 was verified.

Rated turns Ratio	Measured turns ratio between Terminals					
	U-V/u-n	Difference %	V-W/v-n	Difference %	W-U/w-n	Difference %
44.001	43.998	-0.007	44.030	0.066	44.024	0.052

c) MEASUREMENT OF SHORT-CIRCUIT IMPEDANCE AND LOAD LOSS (at 100 % load)

Oil temp.: 33.1°C

Test current (Amp.) Iavg.	Impedance voltage (V) Vavg.	Frequency (Hz.)	Load loss measured (Watts)	Impedance Voltage (%Z) At 50 Hz.	Load loss computed at 75°C (Watts)	%Z at 75°C
0.524	475.086	49.914	143.892	4.334	167	4.414

d) MEASUREMENT OF LOAD LOSS (at 50 % load)

Oil temp.: 33.1°C

Test current (Amp.) Iavg.	Impedance voltage (V) Vavg.	Frequency (Hz.)	Load loss measured (Watts)	Load loss computed at 75°C (Watts)
0.262	237.147	49.872	35.962	42

TC 2806536

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

SHEET 9 OF 21

DATE: 22/06/2019e) MEASUREMENT OF NO-LOAD LOSS AND CURRENT

Oil temp.: 33.1°C

Applied Voltage (V) Vavg.	Current (Amp.) Iavg.	Freq. (Hz.)	Losses Measured (Watts)
433.014	0.186	50.028	33

- Total losses at 75°C: 75 Watts (at 50 % load)
- Total losses at 75°C: 200 Watts (at 100% load)

f) MEASUREMENT OF INSULATION RESISTANCE

Oil temp.: 33.9°C

Measured Between	DC Test Voltage (V)	obtained value (MΩ)
HV to LV winding	2500	> 2000
HV winding to LV + EARTH	2500	> 2000
LV winding to HV + EARTH	500	> 2000

g) INDUCED OVER-VOLTAGE WITHSTAND TEST

Sr. No.	Test	Applied voltage (V)	Applied Freq. (Hz.)	Duration (sec.)	Remarks
1.	Between LV windings with tank connected to earth	866	100	60	Withstood

h) SEPARATE-SOURCE VOLTAGE WITHSTAND TEST

Sr. No.	Test	Applied voltage (kV)	Duration (sec.)	Remarks
1.	Between HV winding and LV winding connected to the tank and earth	28	60	Withstood
2.	Between LV winding and HV winding connected to the tank and earth	03	60	Withstood

Observation after test: The transformer was untanked and inspected.

- 1) Condition of conductor, core and clamping:
 - No visible damage, deformation or displacement.
- 2) Condition of spacers : Intact
- 3) Condition of oil : Clear

Results: 1) % Change in % reactance is within tolerance limits as per standard.

- 2) The results of routine tests carried out before and after the short-circuit withstand test found within limits as per standard.

TC 2806535

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

SHEET 10 OF 21

DATE: 22/06/2019



TC 2797027

OSCILLOGRAM NO. : 0327/01





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

SHEET 11 OF 21

DATE: 22/06/2019



TC 2797028

OSCILLOGRAM NO. : 0327/02





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

DATE: 22/06/2019

SHEET 12 OF 21



TC 2797029

OSCILLOGRAM NO. : 0327/03





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

SHEET 13 OF 21

DATE: 22/06/2019



TC 2797030

OSCILLOGRAM NO. : 0327/04





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

DATE: 22/06/2019

SHEET 14 OF 21



TC 2797031

OSCILLOGRAM NO. : 0327/05





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

SHEET 15 OF 21

DATE: 22/06/2019



TC 2797032

OSCILLOGRAM NO. : 0327/06





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

DATE: 22/06/2019

SHEET 16 OF 21



TC 2797033

OSCILLOGRAM NO. : 0327/07





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584


DATE: 22/06/2019

SHEET 17 OF 21



TC 2797034

OSCILLOGRAM NO. : 0327/08





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

DATE: 22/06/2019

SHEET 18 OF 21



TC 2797035

OSCILLOGRAM NO. : 0327/09





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

DATE: 22/06/2019

SHEET 19 OF 21



TC 2797036

OSCILLOGRAM NO. : 0327/10





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

DATE: 22/06/2019

SHEET 20 OF 21



OSCILLOGRAM NO.:0327/11

TC 2797037



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



ULR-TC538919000019971F

TEST REPORT NO.: RP-1920-011584

DATE: 22/06/2019


SHEET 21 OF 21



DISTRIBUTION TRANSFORMER			
RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.		IS: 1180	
Karola-Bhimnal Road, Karola, Sanchole-343 041		PART: CML-840/03101	
Dist : Rajasthan INDIA			
PHASE TRANSFORMER			
STANDARD	IS: 1180 (2014)	ENERGY EFFICIENCY LEVEL	
KVA	100	MAX TOTAL LOSSES	
VOLTS AT NO LOAD	HV 11000 LV 415	AT 50% RATED LOAD W	4.8
BIL	HV 100 LV 10	MAX TOTAL LOSSES AT 100% RATED LOAD W	6.5
AMPERES	HV 1000 LV 250	TYPE OF COOLING	AN-1
FREQUENCY	50	TEMP RISE OIL DEG °C	20
VECTOR GROUP REF.	Dyn11	TEMP RISE WDG DEG °C	15
IMPEDANCE VOLT %	4.5	MASS OF OIL KGS	22
TAPPING		TOTAL MASS KGS	27
FOR HV VARIATION		VOL OF OIL L	15
IN _____ STEP FROM _____ TO _____ %		MONTH & YEAR OF MFG.	06/2019
CUSTOMER		SERIAL NO.	8200103
ORDER NO.			
MADE IN INDIA			



TC 2806570



- CB - 66 KV CIRCUIT BREAKER
- TR - 66/11 KV TRANSFORMER
- ISO - ISOLATOR
- BCB - BACKUP CIRCUIT BREAKER
- HMS - H.T. MAKE SWITCH
- X - SOURCE SIDE REACTANCE
- R - SOURCE SIDE RESISTANCE
- PT - POTENTIAL TRANSFORMER
- TT - TEST TRANSFORMER
- S - CURRENT MEASURING DEVICE



REPORT NO.: RP-1920-011584
 DATE: 22/06/2019

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION		SCHEMATIC CIRCUIT DIAGRAM	
DRN. BY	CKD.	DATE	DRG. NO.
S. B. S.	M. B. M	27-1-98	OLSC/DTC/01

DISTRIBUTION TRANSFORMER
RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.

IS: 1180
 KAROLA-BHINMAL-ROD KAROLA SANCHORE-343041
 RAJASTHAN.(INDIA)




PART-I
 CM/L-8400030105

<input type="text" value="3"/>	PHASE TRANSFORMER	IS:1180 (2014)	ENERGY EFFICIENCY LEVEL	<input type="text" value="-"/>
STANDARD		<input type="text" value="10"/>	MAX. TOTAL LOSSES	
KVA	HV	<input type="text" value="11000"/>	AT 50% RATED LOAD W	<input type="text" value="84"/>
VOLTS AT NO LOAD	LV	<input type="text" value="433"/>	MAX. TOTAL LOSSES	
BIL	HV	<input type="text" value="95kVp/28kVrms"/>	AT 100% RATED LOAD W	<input type="text" value="240"/>
	LV	<input type="text" value="-/3kVrms"/>	TYPE OF COOLING	<input type="text" value="ONAN"/>
AMPERES	HV	<input type="text" value="0.525"/>	TEMP RISE OIL DEG C	<input type="text" value="35"/>
	LV	<input type="text" value="13.33"/>	TEMP RISE WDG DEG C	<input type="text" value="40"/>
FREQUENCY		<input type="text" value="50 Hz"/>	MASS OF OIL KGS	<input type="text" value="63"/>
VECTOR GROUP REF.		<input type="text" value="Dyn-11"/>	TOTAL MASS KGS	<input type="text" value="262"/>
IMPEDANCE VOLT %		<input type="text" value="4.5"/>	VOL. OF OIL L	<input type="text" value="75"/>
TAPPING		<input type="text" value="-"/>	MONTH & YEAR OF MFG.	<input type="text" value="MAY-2019"/>
FOR HV VARIATION			SERIAL NO.	<input type="text" value="RPTPL-001"/>

IN STEP FROM TO %

CUSTOMER
 ORDER NO.

MADE IN INDIA



RP-1920-011984
 22/05/2019
 10 KVA DS

95
 105


SIZE: 105x105 mm HOLE CENTER: 95x95 mm

NOTE:
 * SERIAL NO,
 YEAR OF MANUFACTURE &
 MONTH OF MANUFACTURE
 WILL BE PUNCHED AT THE TIME OF DISPATCH
 MATERIAL : Anodized Aluminum
 THICKNESS : 1.5mm


RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
 KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041
 RAJASTHAN

DRN BY		RATING & TERMINAL MARKING PLATE FOR 10 KVA, 11/0.433 KV DISTRIBUTION TRANSFORMER
CHD BY		
APPD BY		

REV. NO.	DATE SIGN	BRIEF DESCRIPTION
	30.05.2019	01 of 02



DRG. NO. RPTPL-10KVA-RP-01/02-2019



Test Report No. RP-1920-01484
 Date: 22/05/2019
 Project: 101kVA Dr
 Checked by: [Signature]


SIZE: 105x105 mm HOLE CENTER: 95x95 mm

NOTE:
 * SERIAL NO,
 YEAR OF MANUFACTURE &
 MONTH OF MANUFACTURE
 WILL BE PUNCHED AT THE TIME OF DISPATCH
 MATERIAL : Anodized Aluminum
 THICKNESS : 1.5 mm

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
 KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041
 RAJASTHAN


DRN BY		RATING & TERMINAL MARKING PLATE FOR 10 KVA, 11/0.433 KV DISTRIBUTION TRANSFORMER
CHD BY		
APPD BY		

REV. NO.	DATE SIGN	BRIEF DESCRIPTION		DRG. NO. RPTPL-10KVA-RP-02/02-2019
	30.05.2019	02 of 02		



ELEVATION

SIDE VIEW



PLAN

SR.NO.	ACCESSORIES	QTY.	TECHNICAL DETAILS AS PER SPEC/AS PER OFFER
1	OIL FILLING CAP	1	M.S.
2	OIL LEVEL GAUGE WITH 3 POSITION	1	M.S.
3	SILICAGEL BREATHER (500 Grms.)	1	AL DIE CAST AL DIE CAST
4	H.V. TERMINAL 12mm. DIA. WITH NUT	3	BRASS
5	H.V. BUSHING 12KV, 250A	3	PORCELAIN
6	L.V. TERMINAL 12 mm. DIA. WITH NUT	4	BRASS
7	RATING & TERMINAL MARKING PLATE	1	ANODIZED ALU
8	STIFFENER ANGLE SIZE (40x40x5 mm.)	4	M.S.
9	EARTHING TERMINAL WITH LUGS SIZE (16 Amp.)	2	M.S.
10	BASE CHANNELS 75x40x460mm. LDNG.	2	M.S.
11	L.V. BUSHING 1.1KV, 250A	4	TENDER DRG. PORCELAIN
12	L.V. BUSHING 1.1KV, 250A	4	PORCELAIN
13	THERMOMETER POCKET	1	M.S.
14	LIFTING LUGS FOR COVER WITH FLAT	2	M.S.
15	LIFTING LUGS FOR TANK REINFORCED WITH FLAT	2	M.S.
16	AIR RELEASE PLUG	1	M.S.
17	PULLING LUG	4	M.S.
18	METALLIC TIN PLATE	1	S.S.
19	MCCB BOX	1	S.S.

COOLING DETAILS

1	TOTAL SURFACE AREA :-	N. A.
2	NUMBER OF RADIATORS	N. A.
3	HEIGHT x WIDTH OF FINS	N. A.
4	TOTAL NUMBER OF COOLING FINS	N. A.

1	WEIGHTS IN KGS.	3	DIMENSIONS IN m.m.
	CORE (+/- 5% TOL.)	54	TRANSFORMER OVERALL (+/- 10% TOL.)
	WINDINGS (+/- 5% TOL.)	36	L = 935
	TANK & FITTINGS (+/- 5% TOL.)	109	W = 460
	OIL (+/- 5% TOL.)	63	H = 1120
	TOTAL WEIGHT (+/- 10% TOL.)	262	TRANSFORMER TANK (+/- 5% TOL.)
2	THICKNESS IN m.m.		L1 = 695
	TANK SIDE PLATES (MIN.)	3.15	W1 = 270
	TOP & BOTTOM PLATES (MIN.)	5	H1/H2 = 575/585
			4. BUSHING CLEARANCES WITH ANGLE
			L3 (H.V.) 255 PHASE TO PHASE
			L4 (L.V.) 75 PHASE TO PHASE
			L5 (H.V.) 205 PHASE TO EARTH
			L6 (L.V.) 55 PHASE TO EARTH

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
 KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041

GENERAL ARRANGEMENT DRAWING
 10 KVA 11/0.433 KV DIST. TRANSFORMER



DRG.NO.: RPTPL-GA-10KVA-02-2019
 DATE: 30.05.2019


- NOTE**
- SHAPE OF TANK: RECTANGULAR SHAPE
 - ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE STATED.
 - METALLIC TIN PLATE: OPPOSITE SIDE OF COMBINED NAME PLATE
 - * NOT PROVIDED DURING TESTING




RF-1920-011584
 22/05/2019
 10 KVA DT
 Short Circuit Laboratory
 Vadodara

S.N.	TECHNICAL DETAILS		AS PER SPECIFIED	AS OFFERED
	AS PER SPECIFIED	AS PER OFFERED		
1	PRIMARY VOLTAGE (KV)	11		LV
2	SECONDARY VOLTAGE (KV)	0.433		ALU
3	RATING (KVA)	10		2.83
4	VECTOR GROUP	DYN-11		3.5 /
5	CONFORMING TO I.S.S	1180 PART-1, 2014		0.453
6	PERMISSIBLE VOLTAGE FLUCTUATION %	12.5		20.45
7	TEMP OF TOP OIL (MAX) °C	35		S.E
8	TEMP OF WINDING (MAX) °C	40		0.65
CORE DETAIL				
	a) CORE MATERIAL	CRGO		2376
	b) PRINCIPAL SOURCE OF CORE MATERIAL	OPEN MARKET		216
	c) GRADE OF LAMINATION	M4 OR BETTER		112
	d) FLUX DENSITY, w/m ²	1.69 MAX		205
	e) NO STEPS OF CORE (NOS)	5		144
10	% IMPEDENCE	4.5		61.75 each
11	CORE DIMENSIONS			4
	STEP NO	1 2 3 4 5 6 7 8 9		1
	L MM	70 60 50 40 30		AS PER OFFERED
	W MM	24 2 X 9.6 2 X 5.6 2 X 3.8 2 X 2.7		
	GROSS SECTION cm ²	16.80 11.52 5.60 3.04 1.62		
	TOTAL GROSS SECTION AREA cm ² = 38.58 cm ²			
	EFFECTIVE CORE AREA = 387.58 x 0.97 = 37.42 cm ²			

S.N.	DESCRIPTION	AS PER SPECIFIED		AS OFFERED	
		HV	LV	HV	LV
12	WINDING				
	a) MATERIAL	ALU	ALU	ALU	ALU
	b) ELECTRIC CONDUCTIVITY M/Ω MM ² AT 20°C			2.83	2.83
	c) CONDUCTOR SIZE IN mm ²			3.5 /	3.5 /
	d) CONDUCTOR GROSS SECTION mm ²			0.453	0.453
	e) INSULATION MATERIAL			S.E	D.P.C.
	f) CURRENT DENSITY A/mm ²			0.65	0.65
	g) NO OF TURNS PER COIL			2376	216
	h) OUTER DIA. mm			112	112
	i) INSIDE DIA. mm			205	205
	j) AXIAL LENGTH mm			144	144
	k) NO OF COILS PER PHASE			4	4
13	BUSHING				
	MINIMUM CREEP DISTANCE				
14	LOSSES				
	MAXIMUM TOTAL LOSSES @ 50%	84 W			84 W
	MAXIMUM TOTAL LOSSES @ 100%	240 W			240 W
15	TANK				
	SIDE WALL THICKNESS mm				
	TOP & BOTTOM PLATE THICKNESS mm				
	OIL USED				
	GRADE				
16	NAME OF MANUFACTURER	APPROVED MAKE		ANY MAKE APPR BY CO.	
	VOLUME (Kgs.)	EHV		EHV	
	IN TANK (IN LTRS.)			63	
	IN CONSERVATOR (IN LTRS.)			75	
	TOTAL (IN LTRS.)			75	
17	BREATHER				
	CAPACITY	500 gms			ANY MAKE APPR BY CO.
18	RADIATOR				
	MAKE				
	DETAIL HEAT DISSIPATION CALCULATIONS.	TO BE ENCLOSED		ANY MAKE APPR BY CO.	TO BE ENCLOSED




Test Report No. RP1920-011584
 Date: 22/05/2019
 Product: 10KVAD
 Verified by: [Signature]



RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
 KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041
 TECHNICAL DETAIL DRAWING
 10 KVA 11/0.433 KV DIST. TRANSFORMER
 DRG.NO.: RPTPL-TD-10KVA-03-2019
 DATE: 30.05.2019

HALDI WOOD / PCB FLAT






CORE	DESCRIPTION	AS PER OFFER
A	LEG CENTER mm	215
B	WINDOW HEIGHT mm	315
C	CORE CIRCLE mm	73
	NO OF STEPS	5
	EFFECTIVE CORE AREA cm ²	37.42
L.V. COIL		
	NO OF COIL PER PHASE	1
	OUTER DIA mm	122
	INSIDE DIA mm	80
	AXIAL LENGTH mm	270
	CONDUCTOR CROSS SECTION mm ²	20.45
	CONDUCTOR INSULATION	DPC
H.V. COIL		
	NO OF COIL PER PHASE	4
	OUTER DIA mm	205
	INSIDE DIA mm	144
	AXIAL LENGTH mm	81.75 EACH
	CONDUCTOR CROSS SECTION mm ²	0.45

Ref: Report No. RP-1920-011584
 Date: 22/06/2019
 Product: 10 KVA DT
 Verification of this drawing by Engineer
 In accordance with dimensional standards
 All dimensions are in mm



INSULATION BETWEEN	AS PER SPEC	AS PER OFFER
CORE & L.V.	3.5	3.5
L.V. & H.V.	MIN 11	MIN 11
END INSULATION	25	25
H.V. WINDING AND TANK	30	30
H.V. PHASE TO PHASE	10	10

SR.NO.	DESCRIPTION	MATERIAL & SIZE	QTY.
9	CORE STUDS	M S ROD - 12 mm φ	4
8	TIE RODS	M S ROD - 12 mm φ	4
7	CORE CONSTRUCTION	C.R.G.O.	-
6	FOOT PLATE INSULATION	PRESS BOARD - 2 mm	2
5	FOOT PLATE	M S FLAT - 50x10	2
4	PHASE BARRIER	PRESS BOARD 1 mm x2	2
3	YOKE INSULATION	PRESS BOARD - 2 mm	2
2	CORE CLAMP INSULATION	PRESS BOARD - 2 mm	2
1	CORE CLAMPS	M S CHANNEL - 75x40	4



VERTICAL SPACERS
6 NOS.

INTER COIL SPACERS

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
 KAROLA-BHINMAL ROAD KAROLA SANCHORE-34-3041
 INTERNAL ARRANGEMENT DRAWING
 10 KVA 11/0.433 KV DIST. TRANSFORMER

NOTE: ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE STATED

DRG.NO.: RPTPL-IA-10KVA-04-2019
 DATE: 30.05.2019