



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT

ULR-TC538919000020300F

Sheet : 1 of 5

NAME AND ADDRESS OF CUSTOMER RAJASTHAN POWERGEN TRANSFORMER PVT. LTD. KHASRA NO.911-914,KAROLA-BHINMAL ROAD,KAROLA,SANCHORE, RAJASTHAN - 343041.	REPORT NO.: RP-1920-012032 DATE : 26/06/2019	
	CUSTOMER REF. NO. LETTER	DATE 08.06.2019
	DATE OF SAMPLE RECEIPT 04.06.2019	DATE OF TESTING 11.06.2019
	SAMPLE DESCRIPTION DISTRIBUTION TRANSFORMER (NON SEALED TYPE) Manufactured by : RAJASTHAN POWERGEN TRANSFORMER PVT LTD. Rating : 10 kVA Volts : 11000/433 V (at no-load) Current : 0.525/13.33 Amps Phases : 3/3 Vector group : Dyn11 Further details as per sheet no. 2.	
SAMPLE IDENTIFICATION ERDA sample code number : ERDA-00319068 Manufacturer serial no.: RPTPL-001 Year of manufacture : 2019 Enclosed drawing numbers : 1) RPTPL-10KVA-RP-01/02-2019 01 OF 02 2) RPTPL-10KVA-RP-02/02-2019 02 OF 02 3) RPTPL-GA-10KVA-02-2019		
TEST DETAILS As per sheet 3 of 5.	TEST SPECIFICATION As per sheet 3 of 5.	
TEST RESULTS : As per sheets from 4 of 5.		
ENCLOSURE: Photographs of test sample - As per sheet 5 of 5.		
REMARKS : 1) The transformer conforms to the guaranteed requirement as per above mentioned test specification for above mentioned test no. 1.		
 PREPARED BY	 CHECKED BY	 APPROVED BY (Kapil J Sharma)
Note : 1. This report relates only to the particular sample received for testing in good condition at E.R.D.A.,Makarpura. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from Director , E.R.D.A. 4. Only the tests asked for by the customer have been carried out. 5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arised.		
Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.		

TC 2808305





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



ULR-TC538919000020300F

REPORT NO.: RP-1920-012032

Sheet : 2 of 5

DATE : 26/06/2019

TECHNICAL SPECIFICATIONS OF TEST OBJECT ASSIGNED BY CUSTOMER

1.	Name of Manufacturer	RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
2.	Sr.No.	RPTPL-001
3.	kVA rating	10
4.	Rated Voltage H.V.(Volts)	11000
5.	Rated Voltage L.V.(Volts)	433
6.	Rated Current H.V.(Amp.)	0.525
7.	Rated Current L.V.(Amp.)	13.33
8.	Number of phases	3
9.	Vector Group	Dyn 11
10.	Winding Material	Aluminium
11.	Type of Cooling	ONAN
12.	Frequency (Hz)	50
13.	Guaranteed Percentage impedance %	4.50
14.	Total losses at 50 % load (Watts)	84
15.	Total losses at 100 % load (Watts)	240
16.	Guaranteed temperature rise of oil/Winding	35/40°C
17.	Year of Manufacture	2019
18.	Standard no.	IS 1180 (PART-1) 2014 with amendment no. 1, 2 & 3. customer's requirement

PREPARED BY

CHECKED BY

TC 2808304





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org





ULR-TC538919000020300F

REPORT NO.: RP-1920-012032

Sheet : 3 OF 5

DATE : 26/06/2019

Sr. No.	TEST DETAILS	TEST SPECIFICATION
1.	Temperature-rise test	As per customer's requirement, testing procedure followed as per cl.no.21.3.b of IS 1180(Part 1):2014
 PREPARED BY		 CHECKED BY

TC 2808303





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.



EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**ULR-TC538919000020300F****REPORT NO.:** RP-1920-012032**Sheet :** 4 OF 5**DATE :** 26/06/2019

Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained value	Remarks
1.	<p>Temperature-rise test : (As per customer's requirement, testing procedure followed as per cl.no.21.3.b of IS 1180(Part 1) : 2014)</p> <p>Before starting test, the dimensions of tank was measured & recorded.</p> <p>Size of tank : L-695 mm, W-270 mm, H1-575 mm, H2-585 mm</p> <p>Losses fed for temperature-rise test were 240 Watts.</p> <p>Specified losses were fed to the transformer (i.e. Supply was connected to HV winding and LV winding kept short-circuited) till steady state temperature-rise was attained. Top oil temperature was recorded hourly. After steady state condition, the losses were brought down in reference to the rated current one hour prior to shut down.</p> <p>At the shutdown, the hot windings resistance were measured and temperature-rise calculated.</p>			Conforms
	A) Top oil temperature-Rise :	Max. 35°C	11.8°C	
	B) Winding Temperature Rise (Resistance method)			
	1) HV Winding :	Max. 40°C	17.3°C	
	2) LV Winding :	Max. 40°C	17.4°C	
	C) Ambient temperature at shutdown :		36.4°C	
	D) Time of Shutdown (Hrs) :		21:00	
<p>PREPARED BY </p>		<p>CHECKED BY </p>		

TC 2808302





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org





ULR-TC538919000020300F

REPORT NO.: RP-1920-012032

Sheet : 5 OF 5

DATE : 26/06/2019

PHOTOGRAPHS OF TEST SAMPLE



TC 2808301

by

PREPARED BY

by

CHECKED BY




Test Report No. RD-1426-012032
 Date: 26/2/2019
 Product: 10 KVA
 Verified by: [Signature]
 Verification of this drawing by EIT A is limited to relevant dimensional checks only.
 Verified dimensions are marked with *

DISTRIBUTION TRANSFORMER

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.

KAROLA-BHINMAL-ROD KAROLA SANCHORE-343041
 RAJASTHAN.(INDIA)

IS: 1180

 PART-I
 CM/L-8400030105

<input type="text" value="3"/>	PHASE TRANSFORMER	ENERGY EFFICIENCY LEVEL <input type="text" value="-"/>
STANDARD	<input type="text" value="IS:1180 (2014)"/>	MAX. TOTAL LOSSES AT 50% RATED LOAD W <input type="text" value="84"/>
KVA	<input type="text" value="10"/>	MAX. TOTAL LOSSES AT 100% RATED LOAD W <input type="text" value="240"/>
VOLTS AT NO LOAD	HV <input type="text" value="11000"/> LV <input type="text" value="433"/>	TYPE OF COOLING <input type="text" value="ONAN"/>
BIL	HV <input type="text" value="95kVp/28kVrms"/> LV <input type="text" value="-/3kVrms"/>	TEMP RISE OIL DEG C <input type="text" value="35"/>
AMPERES	HV <input type="text" value="0.525"/> LV <input type="text" value="13.33"/>	TEMP RISE WDG DEG C <input type="text" value="40"/>
FREQUENCY	<input type="text" value="50 Hz"/>	MASS OF OIL KGS <input type="text" value="63"/>
VECTOR GROUP REF.	<input type="text" value="Dyn-11"/>	TOTAL MASS KGS <input type="text" value="262"/>
IMPEDANCE VOLT %	<input type="text" value="4.5"/>	VOL. OF OIL L <input type="text" value="75"/>
TAPPING	<input type="text" value="-"/>	MONTH & YEAR OF MFG. <input type="text" value="MAY-2019"/>
FOR HV VARIATION		SERIAL NO. <input type="text" value="RPTPL-001"/>
IN <input type="text" value="-"/> STEP FROM <input type="text" value="-"/> TO <input type="text" value="-"/> %		
CUSTOMER	<input type="text"/>	
ORDER NO.	<input type="text"/>	

MADE IN INDIA

95
105

95
105


SIZE: 105x105 mm HOLE CENTER: 95x95 mm

NOTE:
 * SERIAL NO,
 YEAR OF MANUFACTURE &
 MONTH OF MANUFACTURE
 WILL BE PUNCHED AT THE TIME OF DISPATCH
 MATERIAL : Anodized Aluminum
 THICKNESS : 1.5mm

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
 KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041
 RAJASTHAN

DRN BY		RATING & TERMINAL MARKING PLATE FOR
CHD BY		10 KVA, 11/0.433 KV DISTRIBUTION TRANSFORMER
APPD BY		


REV. NO.	DATE SIGN	BRIEF DESCRIPTION
	30.05.2019	01 of 02



DRG. NO. RPTPL-10KVA-RP-01/02-2019



Test Report No. RP-1420-012032
 Date: 26/6/2019
 Product: 10 KVA
 Verified by: ABJ
 Verification of this drawing by ERDA is limited to relevant dimensional checks only.
 Verified dimensions are marked with **




SIZE: 105x105 mm HOLE CENTER: 95x95 mm

NOTE:
 * SERIAL NO.,
 YEAR OF MANUFACTURE &
 MONTH OF MANUFACTURE
 WILL BE PUNCHED AT THE TIME OF DISPATCH
 MATERIAL : Anodized Aluminum
 THICKNESS : 1.5 mm

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
 KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041
 RAJASTHAN

DRN BY		RATING & TERMINAL MARKING PLATE FOR 10 KVA, 11/0.433 KV DISTRIBUTION TRANSFORMER
CHD BY		
APPD BY		

REV. NO.	DATE SIGN	BRIEF DESCRIPTION
	30.05.2019	02 of 02



DRG. NO. RPTPL-10KVA-RP-02/02-2019





SR.NO	ACCESSORIES	QTY.	TECHNICAL DETAILS AS PER SPEC. AS PER OFFER
1	OIL FILLING CAP	1	M.S.
2	OIL LEVEL GAUGE WITH 3 POSITION	1	M.S.
3	SILICAGE BREATHER (500 @ ϕ mm.)	1	AL DIE CAST AL. DIE CAST
4	H.V. TERMINAL 12mm. DIA. WITH NUT	3	BRASS
5	H.V. BUSHING 12KV, 250A	3	PORCELAIN
6	L.V. TERMINAL 12 m.m. DIA. WITH NUT	4	BRASS
7	RATING & TERMINAL MARKING PLATE	1	ANODIZED ALUMINIZED ALL
8	STIFFENER ANGLE SIZE (40x40x5 mm.)	4	M.S.
9	EARTHING TERMINAL WITH LUGS SIZE (16 Amp.)	2	M.S.
10	BASE CHANNELS 75x40x460mm. LONG.	2	M.S.
11	L.V. BUSHING TURRET	4	TENDER DRG. PORCELAIN
12	L.V. BUSHING 1.1KV, 250A	4	PORCELAIN
13	THERMOMETER POCKET	1	M.S.
14	LIFTING LUGS FOR COVER	2	M.S.
15	LIFTING LUGS FOR TANK REINFORCED WITH FLAT	2	M.S.
16	AIR RELEASE PLUG	1	M.S.
17	PULLING LUG	4	M.S.
18	METALLIC TIN PLATE	1	S.S.
19	MCSB BOX	1	S.S.

COOLING DETAILS	
1	TOTAL SURFACE AREA :-
2	NUMBER OF RADIATORS
3	HEIGHT x WIDTH OF FINS
4	TOTAL NUMBER OF COOLING FINS

DIMENSIONS IN m.m.	
1	TRANSFORMER OVERALL (+/- 10% TOL.)
2	L = 935
3	W = 460
4	H = 1120
5	TRANSFORMER TANK (+/- 5% TOL.)
6	L1 = 695
7	W1 = 270
8	H1/H2 = 575/585
9	BUSHING CLEARANCES WITH ANGLE
10	L3 (H.V.) 255 PHASE TO PHASE
11	L4 (L.V.) 75 PHASE TO PHASE
12	L5 (H.V.) 205 PHASE TO EARTH
13	L6 (L.V.) 55 PHASE TO EARTH

WEIGHTS IN KGS.	
1	CORE (+/- 5% TOL.)
2	WINDINGS (+/- 5% TOL.)
3	TANK & FITTINGS (+/- 5% TOL.)
4	OIL (+/- 5% TOL.)
5	TOTAL WEIGHT (+/- 10% TOL.)
6	THICKNESS IN m.m.
7	TANK SIDE PLATES (MIN.)
8	TOP & BOTTOM PLATES (MIN.)



Test Report No. RP-1420-012032
 Date: 26/6/2014
 Product: 10.15.14
 Verified by: [Signature]
 Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with *

NOTE

- 1 SHAPE OF TANK: RECTANGULAR SHAPE
- 2 ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE STATED.
- 3 METALLIC TIN PLATE: OPPOSITE SIDE OF COMBINED NAME PLATE
- 4 * NOT PROVIDED DURING TESTING



RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
 KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041

GENERAL ARRANGEMENT DRAWING
 10 KVA 11/0.433 KV DIST. TRANSFORMER

	DRG.NO.: RPTPL-GA-10KVA-02-2019
	DATE: 30.05.2019