



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT

SHEET 1 OF 9

NAME & ADDRESS OF CUSTOMER RAJASTHAN POWERGEN TRANSFORMER PVT. LTD. Khasra No. 911-914, Karola – Bhinmal Road, Karola, Sanchore, Rajasthan-343041 (India)	REPORT NO.: RP-1718-055680 DATE: 07.02.2018	
	CUSTOMER REF. No.: RPTPL/ERDA/TT/37/ 2017-18	DATED: 01.01.2018
	DATE OF SAMPLE RECEIPT: 02.01.2018	DATE OF TESTING: 10.01.2018 to 02.02.2018
	SAMPLE DESCRIPTION 16 kVA Distribution Transformer 11000/433 Volts, 0.84/21.33 Amp., Oil filled, Vector Group: Dyn-11, ENERGY EFFICIENCY LEVEL: 2 Further details as per sheet No. 3 of 9.	
SAMPLE IDENTIFICATION ERDA SAMPLE CODE NO.: ERDA-00234414 SERIAL NO.: RPTPL-001 DRAWING NO.: RPTPL/RP16/01/02/18 01 of 02 REV.NO.01 RPTPL/RP16/02/02/18 02 of 02 REV.NO.02 RPTPL-GA-16-02-18 REV. NO. 01 RPTPL-IA-16-003-14 REV. NO. 01 RPTPL-TD-16-004-14 REV. NO. 01 YEAR OF MFG.: 2018		
TEST DETAILS Short-circuit withstand test [Cl. No. (17 & 21.3 c)] ENCLOSURES: Number of oscillograms : Eleven Number of photograph : One Number of test circuit diagram : One Number of drawings : Five	TEST SPECIFICATIONS IS 1180 (Part 1): 2014 [Amendment No. 1 & 2]	
REMARKS: The sample conforms to the requirements of standard for short-circuit withstand test.		
 PREPARED BY	 CHECKED BY	 K. B. PATEL APPROVED BY

- NOTE:**
1. This report relates only to the particular sample received for testing in good condition at ERDA.
 2. This report cannot be reproduced in part under any circumstances.
 3. Publication of this report requires prior permission in writing from Director, ERDA.
 4. Only test asked for by customer have been carried out.
 5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arisen.

Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.

TC 2450704



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1718-055680
DATE: 07.02.2018

SHEET 2 OF 9

Contents	
1. Technical specifications of test object assigned by customer	Sheet No. 3 of 9
2. Routine test results before short circuit	Sheet No. 4 of 9 to 5 of 9
3. Short-circuit withstand test	Sheet No. 6 of 9 to 7 of 9
4. Routine test results after short circuit	Sheet No. 8 of 9 to 9 of 9
5. Oscillogram No.	1537/01 to 1537/11
6. Photograph No.	1718-016517/1463
7. Test circuit diagram No.	OLSC/DTC/01
8. Drawing No.	RPTPL/RP16/01/02/18 01 of 02 REV.NO.01 RPTPL/RP16/02/02/18 02 of 02 REV.NO.02 RPTPL-GA-16-02-18 REV. NO. 01 RPTPL-IA-16-003-14 REV. NO. 01 RPTPL-TD-16-004-14 REV. NO. 01

PREPARED BY

CHECKED BY

TC 2450652





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



REPORT NO.: RP-1718-055680

SHEET 3 OF 9

DATE: 07.02.2018

TECHNICAL SPECIFICATIONS OF TEST OBJECT ASSIGNED BY CUSTOMER

1. Name of manufacturer	: RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
2. Equipment	: 16 kVA Distribution Transformer
3. Standard No.	: [Cl. No. (17 & 21.3 c)] of IS 1180 (Part 1): 2014 [Amendment No. 1 & 2]
4. Serial No.	: RPTPL-001
5. Energy efficiency level	: 2
6. Type	: Outdoor, Oil Cooled
7. kVA rating	: 16
8. Rated voltage H.V. (Volts)	: 11000
L.V. (Volts)	: 433
9. Rated current H.V. (Amp.)	: 0.84
L.V. (Amp.)	: 21.33
10. Number of phases	: 3
11. Connection H.V./L.V.	: Delta/Star
12. Frequency (Hz.)	: 50
13. Type of cooling	: ONAN
14. Temperature rise of oil/winding	: 35°C/40°C
15. Percentage Impedance	: 4.5%
16. Primary winding conductor	: SE Aluminium wire, bare dia. 0.92mm
17. Secondary winding conductor	: DPC Aluminium strip, bare size (3.4mm x 5.75mm)
18. Quantity of oil (Litre)	: 82
19. Weight of oil (kg.)	: 70
20. Weight of core and winding (kg.)	: 105
21. Total weight (kg.)	: 303
22. Vector group	: Dyn-11
23. Year of manufacture	: 2018
24. Insulation level H.V.	: 28 kVrms
25. Insulation level L.V.	: 03 kVrms
26. Total losses at 75°C (Watts)	: 135 Max. (at 50 % load)
27. Total losses at 75°C (Watts)	: 440 Max. (at 100 % load)

PREPARED BY

CHECKED BY

TC 2450705



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1718-055680

SHEET 4 OF 9

DATE: 07.02.2018

ROUTINE TEST RESULTS BEFORE SHORT CIRCUIT

a) MEASUREMENT OF WINDING RESISTANCE

Measurement at average oil temperature: 27.6°C					
LV Winding resistance (mΩ)			HV Winding Resistance (Ω)		
u - v	v - w	w - u	U - V	V - W	W - U
165.93	166.16	166.16	124.57	124.03	124.69

b) MEASUREMENT OF VOLTAGE RATIO AND CHECK OF PHASE DISPLACEMENT

Vector group: Dyn-11 was verified.

Rated turns Ratio	Measured turns ratio between Terminals					
	U-V/u-n	Difference %	V-W/v-n	Difference %	W-U/w-n	Difference %
44.001	44.020	0.043	44.027	0.059	44.039	0.086

c) MEASUREMENT OF SHORT-CIRCUIT IMPEDANCE AND LOAD LOSS (at 100 % load)

Average oil temp.: 26.8°C

Test current (Amp.) I _{avg}	Impedance voltage (V) V _{avg}	Frequency (Hz.)	Load loss measured (Watts)	Impedance Voltage (%Z) at 50 Hz.	Load loss computed at 75°C (Watts)	%Z at 75°C
0.837	505.796	49.994	250.027	4.616	297	4.720

d) MEASUREMENT OF LOAD LOSS (at 50 % load)

Average oil temp.: 26.8°C

Test current (Amp.) I _{avg}	Impedance voltage (V) V _{avg}	Frequency (Hz.)	Load loss measured (Watts)	Load loss computed at 75°C (Watts)
0.419	253.240	50.003	62.782	74

PREPARED BY

CHECKED BY

TC 2450654





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1718-055680

SHEET 5 OF 9

DATE: 07.02.2018

e) MEASUREMENT OF NO-LOAD LOSS AND CURRENT

Average oil temp.: 26.8°C

Applied Voltage (V) Vavg.	Current (Amp.) Iavg.	Frequency (Hz.)	Losses Measured (Watts)
433.112	0.334	50.006	57

- Total losses at 75°C: 131 Watts (at 50 % load)
- Total losses at 75°C: 354 Watts (at 100% load)

f) MEASUREMENT OF INSULATION RESISTANCE

Average oil temp.: 27.6°C, Measured at Voltage: 1000 V DC

	IR value (MΩ)
HV to LV winding	> 2000
HV winding to LV + EARTH	> 2000
LV winding to HV + EARTH	> 2000

g) INDUCED OVER-VOLTAGE WITHSTAND TEST

Sr. No.	Test	Applied voltage (V)	Applied Freq. (Hz.)	Duration (sec.)	Remarks
1.	Between LV windings with tank connected to earth.	866	100	60	Withstood

h) SEPARATE-SOURCE VOLTAGE WITHSTAND TEST

Sr. no.	Test	Applied voltage (kV)	Duration (sec.)	Remarks
1.	Between HV winding and LV winding connected to the tank and earth	28	60	Withstood
2.	Between LV winding and HV winding connected to the tank and earth	03	60	Withstood

TC 2450655

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1718-055680

SHEET 6 OF 9

DATE: 07.02.2018

SHORT-CIRCUIT WITHSTAND TEST:

The verification of the short-circuit withstand test was performed on the high voltage winding connected to three phase-balanced source and low voltage winding short circuited through current measuring instruments. Test conducted with pre set short circuit as per schematic circuit diagram No.: OLSC/DTC/01.

Condition of the equipment under test: As after routine tests.

Supply Frequency: 50 Hz.

Test No.	Oscillogram No.	Applied voltage (kVrms)	Short circuit current on LV (A)			Duration (sec.)	Remarks
			Peak	RMS	Avg.		
1.	1537/01	-	- 651 -	355 363 347	355	0.1	Calibration shot
2.	1537/02	11	- 857 -	452 461 441	451	0.5	No Abnormality
3.	1537/03	11	- 843 -	453 461 440	451	0.5	No Abnormality
4.	1537/04	11	- 853 -	452 462 441	452	0.5	No Abnormality
5.	1537/05	11	859 - -	452 460 439	450	0.5	No Abnormality
6.	1537/06	11	790 - -	449 460 439	449	0.5	No Abnormality
7.	1537/07	11	809 - -	448 459 438	448	0.5	No Abnormality
8.	1537/08	11	- - 847	450 457 436	448	0.5	No Abnormality
9.	1537/09	11	- - 846	450 458 437	448	0.5	No Abnormality
10.	1537/10	11	- - 851	450 458 437	448	0.5	No Abnormality
11.	1537/11	11	- 836 -	447 458 437	447	2.0	Thermal Shot No Abnormality

TC 2450656

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1718-055680

SHEET 7 OF 9

DATE: 07.02.2018

Measurement of the % reactance during the short circuit test

LV winding was short circuited. Three phase AC supply was connected to HV winding to pass test current. Before the short circuit test and after each shot, the percentage reactance was measured.

Sr. No.	Measurement performed		Measured value of % reactance at 50 Hz.			%Change in % reactance		
			U	V	W	U	V	W
1.	Before test		4.38	4.39	4.37	-	-	-
2.	After the test no.	2.	4.37	4.39	4.37	-0.23	0.00	0.00
3.	After the test no.	3.	4.38	4.39	4.37	0.00	0.00	0.00
4.	After the test no.	4.	4.38	4.39	4.37	0.00	0.00	0.00
5.	After the test no.	5.	4.38	4.39	4.37	0.00	0.00	0.00
6.	After the test no.	6.	4.38	4.39	4.37	0.00	0.00	0.00
7.	After the test no.	7.	4.38	4.39	4.37	0.00	0.00	0.00
8.	After the test no.	8.	4.38	4.39	4.37	0.00	0.00	0.00
9.	After the test no.	9.	4.38	4.39	4.37	0.00	0.00	0.00
10.	After the test no.	10.	4.37	4.39	4.37	-0.23	0.00	0.00
11.	After the test no.	11.	4.38	4.39	4.37	0.00	0.00	0.00

PREPARED BY

CHECKED BY

TC 2450657





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1718-055680

SHEET 8 OF 9

DATE: 07.02.2018

ROUTINE TEST RESULTS AFTER SHORT CIRCUIT

a) MEASUREMENT OF WINDING RESISTANCE

Measurement at average oil temperature: 29.3°C					
LV Winding resistance (mΩ)			HV Winding Resistance (Ω)		
u - v	v - w	w - u	U - V	V - W	W - U
171.15	171.29	171.33	127.98	127.41	128.07

b) MEASUREMENT OF VOLTAGE RATIO AND CHECK OF PHASE DISPLACEMENT

Vector group: Dyn-11 was verified.

Rated turns Ratio	Measured turns ratio between Terminals					
	U-V/u-n	Difference %	V-W/v-n	Difference %	W-U/w-n	Difference %
44.001	44.022	0.048	44.028	0.061	44.040	0.089

c) MEASUREMENT OF SHORT-CIRCUIT IMPEDANCE AND LOAD LOSS (at 100 % load)

Average oil temp.: 29.5°C

Test current (Amp.) I _{avg}	Impedance voltage (V) V _{avg}	Frequency (Hz.)	Load loss measured (Watts)	Impedance Voltage (%Z) at 50 Hz.	Load loss computed at 75°C (Watts)	%Z at 75°C
0.837	507.945	50.085	256.563	4.626	303	4.729

d) MEASUREMENT OF LOAD LOSS (at 50 % load)

Average oil temp.: 29.5°C

Test current (Amp.) I _{avg}	Impedance voltage (V) V _{avg}	Frequency (Hz.)	Load loss measured (Watts)	Load loss computed at 75°C (Watts)
0.419	254.174	50.091	64.308	76

PREPARED BY

CHECKED BY

TC 2450658



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1718-055680

SHEET 9 OF 9

DATE: 07.02.2018

e) MEASUREMENT OF NO-LOAD LOSS AND CURRENT

Average oil temp.: 29.5°C

Applied Voltage (V) Vavg.	Current (Amp.) Iavg.	Frequency (Hz.)	Losses Measured (Watts)
433.216	0.330	50.07	56

- Total losses at 75°C: 132 Watts (at 50 % load)
- Total losses at 75°C: 359 Watts (at 100% load)

f) MEASUREMENT OF INSULATION RESISTANCE

Average oil temp.: 29.3°C, Measured at Voltage: 1000 V DC

	IR value (MΩ)
HV to LV winding	> 2000
HV winding to LV + EARTH	> 2000
LV winding to HV + EARTH	> 2000

g) INDUCED OVER-VOLTAGE WITHSTAND TEST

Sr. No.	Test	Applied voltage (V)	Applied Freq. (Hz.)	Duration (sec.)	Remarks
1.	Between LV windings with tank connected to earth	866	100	60	Withstood

h) SEPARATE-SOURCE VOLTAGE WITHSTAND TEST

Sr. No.	Test	Applied voltage (kV)	Duration (sec.)	Remarks
1.	Between HV winding and LV winding connected to the tank and earth	28	60	Withstood
2.	Between LV winding and HV winding connected to the tank and earth	03	60	Withstood

Observation after test: The transformer was untanked and inspected.

- 1) Condition of conductor, core and clamping:
 - No visible damage, deformation or displacement.
- 2) Condition of spacers : Intact
- 3) Condition of oil : Clear

Results: 1) % Change in % reactance is within tolerance limits as per standard.
2) The results of routine tests carried out before and after the short-circuit withstand test found within limits as per standard.

TC 2450659

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : <http://www.erda.org>



REPORT NO.: RP-1718-055680

DATE: 07.02.2018



OSCILLOGRAM NO. : 1537/01



TC 2425980



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1718-055680

DATE: 07.02.2018



TC 2425981

OSCILLOGRAM NO. : 1537/02





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1718-055680

DATE: 07.02.2018



OSCILLOGRAM NO. : 1537/03



TC 2425982



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : <http://www.erda.org>



REPORT NO.: RP-1718-055680

DATE: 07.02.2018



TC 2425983

OSCILLOGRAM NO. : 1537/04





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : <http://www.erda.org>



REPORT NO.: RP-1718-055680

DATE: 07.02.2018



OSCILLOGRAM NO. : 1537/05



TC 2425985



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : <http://www.erda.org>



REPORT NO.: RP-1718-055680

DATE: 07.02.2018



TC 2425976

OSCILLOGRAM NO. : 1537/06





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : <http://www.erda.org>



REPORT NO.: RP-1718-055680

DATE: 07.02.2018



TC 2425977

OSCILLOGRAM NO. : 1537/07





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : <http://www.erda.org>



REPORT NO.: RP-1718-055680

DATE: 07.02.2018



OSCILLOGRAM NO. : 1537/08



TC 2425986



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : <http://www.erda.org>



REPORT NO.: RP-1718-055680

DATE: 07.02.2018



TC 2425978

OSCILLOGRAM NO. : 1537/09





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1718-055680

DATE: 07.02.2018



TC 2425979

OSCILLOGRAM NO. : 1537/10





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : <http://www.erda.org>



REPORT NO.: RP-1718-055680

DATE: 07.02.2018



OSCILLOGRAM NO.: 1537/11

TC 2425984



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : http://www.erda.org




REPORT NO.: RP-1718-055680

DATE: 07.02.2018



TC 2450660



- CB - 66 KV CIRCUIT BREAKER
- TR - 66/11 KV TRANSFORMER
- ISO - ISOLATOR
- BCB - BACKUP CIRCUIT BREAKER
- HMS - H.T. MAKE SWITCH
- X - SOURCE SIDE REACTANCE
- R - SOURCE SIDE RESISTANCE
- PT - POTENTIAL TRANSFORMER
- TT - TEST TRANSFORMER
- S - CURRENT MEASURING DEVICE



REPORT NO.: RP-1718-055680
 DATE: 7/2/18

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION	
SCHEMATIC CIRCUIT DIAGRAM	
DRN. BY	DATE
S. B. S.	27-1-98
CKD.	DRG. NO.
M. B. M	OLSC/DTC/01

Test Report No. RP-1718-05568D
 Date 07.02.2018
 Product 16 KVA DT
 Verified by RPJ
 Verification of this drawing by ERDA is limited to relevant dimensional checks only.
 Verified dimensions are marked with ****V**



DISTRIBUTION TRANSFORMER

RAJASTHAN POWERGEN TRANSFORMER PVT.LTD

BHNIMAL-KAROLA ROAD KAROLA SANCHORE
RAJASTHAN. (INDIA)

IS: 1180

PART-I
CM/L-8400030105

<input type="checkbox"/> 3 PHASE TRANSFORMER		ENERGY EFFICIENCY LEVEL	<input type="checkbox"/> 2
STANDARD	<input type="checkbox"/> IS: 1180 (2014)	MAX. TOTAL LOSSES AT 50% RATED LOAD W	<input type="checkbox"/> 135
KVA	<input type="checkbox"/> 16	MAX. TOTAL LOSSES AT 100% RATED LOAD W	<input type="checkbox"/> 440
VOLTS AT NO LOAD	HV <input type="checkbox"/> 11000 LV <input type="checkbox"/> 433	TYPE OF COOLING	<input type="checkbox"/> ONAN
BIL	HV <input type="checkbox"/> 75 KVP / 25 KV rms LV <input type="checkbox"/> - / 3 KV rms	TEMP RISE OIL DEG C	<input type="checkbox"/> 35
AMPERES	HV <input type="checkbox"/> 0.84 LV <input type="checkbox"/> 21.33	TEMP RISE WDG DEG C	<input type="checkbox"/> 40
FREQUENCY	<input type="checkbox"/> 50 Hz	MASS OF OIL KGS	<input type="checkbox"/> 70
VECTOR GROUP REF.	<input type="checkbox"/> Dyn-11	TOTAL MASS KGS	<input type="checkbox"/> 303
IMPEDANCE VOLT %	<input type="checkbox"/> 4.5	VOL. OF OIL L	<input type="checkbox"/> 82
TAPPING	<input type="checkbox"/> -	MONTH & YEAR OF MFG.	<input type="checkbox"/> 2018
FOR HV VARIATION	SERIAL NO. <input type="checkbox"/> RPTPL-001		
IN <input type="checkbox"/> STEP FROM <input type="checkbox"/> TO <input type="checkbox"/> %			
CUSTOMER	<input type="text"/>		
ORDER NO.	<input type="text"/>		

MADE IN INDIA

95
105

SIZE: 105x105 mm HOLE CENTER: 95x95 mm

NOTE:
 * SERIAL NO., ACTUAL IMPEDANCE(%) VOLTAGE, YEAR OF MANUFACTURE & MONTH OF MANUFACTURE WILL BE PUNCHED AT THE TIME OF DESPATCH
 MATERIAL : ANODISED ALUMINIUM SHEET THICKNESS : 0.9 mm


RAJASTHAN POWERGEN TRANSFORMER PVT.LTD
 BHNIMAL-KAROLA ROAD KAROLA SANCHORE
 RAJASTHAN. (INDIA)

DRN BY		RATING & TERMINAL MARKING PLATE FOR 16 KVA ,11/0.433 KV DISTRIBUTION TRANSFORMER 3 PHASE, ENERGY EFFICIENCY LEVEL-2
CHD BY	S.G.M.	
APPD BY	J.P.C.	

DATE	03.02.2018	BRIEF DESCRIPTION		DRG. NO. RPTPL/RP16/01/02/18	REV. NO. 01
------	------------	-------------------	--	------------------------------	-------------

01 of 02

Test Report No. RP-1718-055690
 Date 07.02.2018
 Product 16 kVA DT
 Verified by [Signature]
 Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with **



SIZE: 105x105 mm HOLE CENTER: 95x95 mm


NOTE:
 * SERIAL NO, ACTUAL IMPEDANCE(%) VOLTAGE, YEAR OF MANUFACTURE & MONTH OF MANUFACTURE WILL BE PUNCHED AT THE TIME OF DESPATCH
 MATERIAL : ANODISED ALUMINIUM SHEET THICKNESS : 0.9 mm

RAJASTHAN POWERGEN TRANSFORMER PVT.LTD
 BHINMAL-KAROLA ROAD KAROLA SANCHORE
 RAJASTHAN. (INDIA)

DRN BY		RATING & TERMINAL MARKING PLATE FOR 16 KVA ,11/0.433 KV DISTRIBUTION TRANSFORMER 3 PHASE, ENERGY EFFICIENCY LEVEL-2
CHD BY	S.G.M.	
APPD BY	J.P.C.	

DATE	03.02.2018	BRIEF DESCRIPTION		DRG. NO. RPTPL/RP16/02/02/18	REV. NO. 02
------	------------	-------------------	--	------------------------------	-------------

1 2 3 4 5



SR.NO.	ACCESSORIES	QTY.	TECHNICAL DETAILS AS PER SPECS PER OFFER
1	CONSERVATOR (#130) WITH OIL FILLING HOLE (52mm) WITH CAP & DRAIN PLUG (12 mm)	1	M.S. M.S.
2	Oil level gauge with 3 position (-5, -50 & 100%)	1	AL
3	SILICAGEL BREATHER (300 Gr. wt. >)	1	AL DYE CAST AL DYE CAST
4	H.V. TERMINAL 12mm DIA. WITH NUT	3	BRASS
5	H.V. BUSHING	3	PORCELAIN
6	L.V. TERMINAL 12 mm DIA.	4	BRASS TINED BRASS TINED
7	COOLING RADIATOR n.n. THICK	0	MA.
8	RATING & TERMINAL MARKING PLATE	1	ANODISED ANODISED
9	REIN-FORCING ANGLE SIZE (40x40x6 mm.)	4	M.S. M.S.
10	EARTHING TERMINAL WITH LUGS SIZE (16 Amp.)	2	M.S. M.S.
11	BASE CHANNELS 75x40x460mm. LONG	2	M.S. M.S.
12	L.T. BUSHING 1.1KV/250A	4	PORCELAIN
13	THERMOMETER POCKET	1	M.S. M.S.
14	AIR RELEASE PLUG	1	M.S. M.S.
15	LIFTING LUGS FOR COVER (8 mm.m.)	2	N.A.
16	LIFTING LUGS FOR TANK WITH FLAT (8 mm.m.)	2	M.S. M.S.
17	DRAIN VALVE	1	M.S. M.S.
18	PULLING LUG (8 mm.m.)	4	M.S. M.S.
19	CONSERVATOR PIPE (#30mm MM)	2	M.S. M.S.

COOLING DETAILS	
1	TOTAL SURFACE AREA : 1.239 mm ² .
2	TOTAL NUMBER OF COOLING TUBES
3	L X B X H OF TUBE

WEIGHTS IN KGS.	
CORE	70
WINDINGS	35
TANK&FITTINGS with all access	128
OIL	70
TOTAL WEIGHT	303
THICKNESS IN mm.	3.15
TANK SIDE PLATES (MIN.)	5
TOP & BOTTOM PLATES (MIN.)	5
T/F OIL QUANTITY	as per spec
MAIN TANK DIMENSIONS	L3 (H.V.) 295
OVERALL DIMENSIONS	+/- 5 % L4 (L.V.) 75
DIMENSIONS OF CONSERVATOR	+/- 5 % L5 (H.V.) 140
i) INSIDE DIAMETER IN mm.	130
j) LENGTH IN mm.	600
e) CAPACITY IN LTRS.	7

ALL DIMENSIONS ARE IN MM. UNLESS OTHERWISE STATED.

RAJASTHAN POWERGEN TRANSFORMER PVT.LTD. BHINMAL-KAROLA ROAD, SANCHORE-343041. RAJASTHAN.	
DRN BY	GENERAL ARRANGEMENT OF TRANSFORMER OF
CHD BY	16 KVA 11/ 0.433 KV DISTRIBUTION TRANSFORMER
APPD BY	Energy Efficiency Level - 2
DATE	03.02.2018
SCALE	DRG. NO. RP TPL-GA-16-02-18
	REV. NO. 01

SIDE VIEW

ELEVATION

PLAN


Test Report No. RP-1A18-000680
 Date 07.02.2018
 Product 16 KVA 11
 Verified by [Signature]
 Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with #.




NOTE
 1 SHAPE OF TANK: RECTANGULAR SHAPE
 2 PAINT: AS PER IS
 3 ALL DIMENSIONS ARE IN MM UNLESS OTHERWISE STATED.
 # NOT PROVIDED DURING TESTING

SIGNATURE OF AUTHORISED PERSON & STAMP OF THE FIRM		REV. DATE & NO. SIGN		BRIEF DESCRIPTION	


WINDING & CONSTRUCTION DETAILS.



ELEVATION



PLAN



Test Report No. RP-1718-055690
 Date 09.02.2018
 Product 16 KV 27
 Verified by [Signature]
 Verification of this drawing by ERDA is limited to relevant dimensional checks only.
 Verified dimensions are marked with a star.

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.

DRN BY	A.V.P.	SCALE
CHD BY	S.G.M.	INTERNAL ARRANGEMENT OF
APPD BY	J.P.C.	16KVA, 11/0.433KV, E.E.L-2
DATE	03.02.2018	DIST TRANSFORMER

DRG. NO.	REV. NO.
RPITPL-IA-16-003-14	01

CORE	DESCRIPTION	AS PER TECH. SPECIFICATION	AS PER OFFER
A	LEG CENTRES	m.m.	211
B	WINDOW HEIGHT	m.m.	298
C	CORE CIRCLE	m.m.	76
D	NO. OF STEPS	NOS.	7
E	EFFECTIVE CORE AREA	Cm ²	41.50
F	OUTER DIAMETER	m.m.	113
G	INSIDE DIAMETER	m.m.	83
H	AXIAL LENGTH	m.m.	286
I	CONDUCTOR CROSS SECTION	m.m. ²	19
J	CONDUCTOR INSULATION	m.m.	DPC
K	NO. OF H.V. COILS PER PHASE	4/6/8/10	2
L	OUTER DIAMETER	m.m.	201
M	INSIDE DIAMETER	m.m.	135
N	AXIAL LENGTH (EACH)	m.m.	127
O	CONDUCTOR CROSS SECTION	m.m. ²	0.6647
P	CONDUCTOR INSULATION	m.m.	SE
Q	INSULATION BETWEEN (TAP COILS)	m.m.	N.A.
R	BASE FLAT INSULATION	m.m.	2
S	WRAP (GAP) ON CORE	m.m.	3.5
T	WEDGES BETWEEN H.V. & L.V. COILS	NOS.	6
U	GAP BETWEEN H.V. & L.V.	m.m.	11
V	FRAME CHANNEL INSULATION	m.m.	2
W	PHASE BARRIER	m.m.	2x1
X	END INSULATION BLOCK	m.m.	25
Y	CLEARANCE TO TANK WALL FROM H.V. WINDING	m.m.	30
Z	BOTTOM FRAME SIZE ISMC	mm x mm.	75x40
AA	BASE CHANNEL SIZE	mm. x mm.	75x40
AB	NOS. OF SPACERS BETWEEN H.V. AXIAL COIL (PERIPHERAL)	m.m.	MIN. 10mm.
AC	INTER PHASE CLEARANCE	m.m.	7mm.
AD	THICKNESS OF SPACERS	m.m.	4 Nos. of 12m.m.
AE	TIE RODS SIZE & NOS.	m.m./Nos.	4 Nos. of 12m.m.
AF	CORE STUD SIZE & NOS.	m.m./Nos.	4 Nos. of 12m.m.
AG	#		
AH	##		

SR. NO.		7		5		4		3		2		1	
TECHNICAL DETAILS		AS PER SPEC. AS PER OFFER		11		11		ALUMINIUM		ALUMINIUM		ALUMINIUM	
1. PRIMARY VOLTAGE (KV)		11		11		11		---		---		---	
2. SECONDARY VOLTAGE (KV)		0.433		0.433		0.433		---		---		---	
3. RATING (KVA)		16		16		16		---		---		---	
4. VECTOR GROUP		Dyn 11		Dyn 11		Dyn 11		SE		DPC		SE	
5. CONFORMING TO I.S.S.		IS: 2026, 1180		IS: 2026, 1180		IS: 2026, 1180		1.6		1.6		0.7294	
6. PERMISSIBLE VOLTAGE FLUCTUATION %		12.5		12.5		12.5		---		---		---	
7. TEMPERATURE OF TOP OIL (MAX.) °C		35		35		35		---		---		---	
8. TEMPERATURE OF WINDING (MAX.) °C		40		40		40		---		---		---	
9. CORE DETAILS		CRGO Annealed steel		CRGO Annealed steel		CRGO Annealed steel		---		---		---	
a) CORE MATERIAL		---		---		---		---		---		---	
b) PRINCIPAL SOURCE OF CORE MATERIAL		U.S.A.		U.S.A.		U.S.A.		---		---		---	
c) GRADE OF LAMINATION		M4 OR BETTER		M4 OR BETTER		M4 OR BETTER		---		---		---	
e) FLUX DENSITY W/m ²		1.6 Max.		1.51		1.51		---		---		---	
d) NO. OF STEPS OF CORE (NOS.)		7		7		7		---		---		---	
10. % IMPEDANCE		4.5		4.5		4.5		---		---		---	
11. CORE DIMENSIONS								25 mm/kv		As Specified		As Offered	
Step No.		H		1		2		3		4		5	
L mm.		75		70		65		60		55		50	
W mm.		15.1		2x7.9		2x4.75		2x3.55		2x2.85		2x2.35	
Cross Sect. Cm ²		11.325		11.06		6.175		4.26		3.135		2.35	
Total Cross Sect. Area Cm ²		42.785		42.785		42.785		42.785		42.785		42.785	
EFFECTIVE CORE AREA		=		42.785 X 0.97		42.785 X 0.97		42.785 X 0.97		42.785 X 0.97		42.785 X 0.97	
=		41.50		41.50		41.50		41.50		41.50		41.50	
Cm ²													
12. WINDING													
a) MATERIAL		ALUMINIUM		ALUMINIUM		ALUMINIUM		ALUMINIUM		ALUMINIUM		ALUMINIUM	
b) SPECIFIC CONDUCTIVITY		---		---		---		---		---		---	
c) CONDUCTOR SIZE mm.xmm.(Bare)		---		---		---		---		---		---	
d) CONDUCTOR CROSS SECTION mm. ²		---		---		---		---		---		---	
e) INSULATION MATERIAL		SE		SE		SE		DPC		DPC		DPC	
f) CURRENT DENSITY A/mm. ²		1.6		1.6		1.6		1.6		1.6		1.6	
g) NO. OF TURNS		7920		7920		7920		7920		7920		7920	
h) OUTER DIAMETER mm.		---		---		---		---		---		---	
i) INSIDE DIAMETER mm.		---		---		---		---		---		---	
j) AXIAL LENGTH mm.		---		---		---		---		---		---	
k) NO. OF COILS PER PHASE NO.		2		2		2		1		1		1	
13. BUSHING													
MINIMUM CREEPAGE DISTANCE		25 mm/kv		25 mm/kv		25 mm/kv		25 mm/kv		25 mm/kv		25 mm/kv	
14. LOSSES													
TOTAL LOSSES Watts AT 50°C		135		135		135		135		135		135	
TOTAL LOSSES Watts AT 75°C		440		440		440		440		440		440	
15. TANK													
SIDE WALL THICKNESS mm.		---		---		---		---		---		---	
TOP & BOTTOM PLATE THICKNESS mm.		---		---		---		---		---		---	
16. OIL USED													
NAME OF MANUFACTURER		APAR		APAR		APAR		APAR		APAR		APAR	
GRADE		IS-335		IS-335		IS-335		IS-335		IS-335		IS-335	
VOLUME (LITRES)		---		---		---		---		---		---	
IN TANK		---		---		---		---		---		---	
IN CONSERVATOR		---		---		---		---		---		---	
TOTAL		---		---		---		---		---		---	
17. BREATHER													
MAKE		---		---		---		---		---		---	
CAPACITY		---		---		---		---		---		---	
RADIATOR		---		---		---		---		---		---	
MAKE		---		---		---		---		---		---	
DETAILED HEAT DISSIPATION CALCULATION		TO BE ENCLOSED		TO BE ENCLOSED		TO BE ENCLOSED		TO BE ENCLOSED		TO BE ENCLOSED		TO BE ENCLOSED	


RAJASTHAN POWERGEN TRANSFORMER PVT.LTD.
 BHINMAL-KAROLA ROAD, KAROLA, SANCHORE-343041

DRN BY A.V.P. SCALE
 CHD BY S.G.M.
 APPD BY J.P.C.
 DATE 03.02.2018

TECHNICAL DETAILS FOR
 16KVA, 11/0.433KV, E.E.L-2
 DIST. TRANSFORMER

DRG. NO. REV. NO.
 RPTPL-TD-16-004-14 01

Test Report No. RP-1718-055680
 Date 07.02.2018
 Product 16 kVA E.L-2
 Verified by [Signature]
 Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with **.



Step No.	H	1	2	3	4	5	6	7	8
L mm.	75	70	65	60	55	50	40	30	0
W mm.	15.1	2x7.9	2x4.75	2x3.55	2x2.85	2x2.35	2x3.65	2x2.6	0
Cross Sect. Cm ²	11.325	11.06	6.175	4.26	3.135	2.35	2.92	1.56	0

Total Cross Sect. Area Cm² 42.785

EFFECTIVE CORE AREA = 42.785 X 0.97 = 41.50 Cm²