



Certificate No. : TC-5389

**ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



**TEST REPORT**

ULR NO.: TC538919000014147F

SHEET 1 OF 9

<b>NAME &amp; ADDRESS OF CUSTOMER</b>  <b>RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.</b> Khasra No. 911-914, Karola-Bhinmal Road, Karola, Sanchore, Rajasthan-343041 (India)	<b>REPORT NO.:</b> RP-1920-004071 <b>DATE:</b> 30.04.2019	
	<b>CUSTOMER REF. No.:</b> Nil	<b>DATED:</b> 03.04.2019
	<b>DATE OF SAMPLE RECEIPT:</b>  20.03.2019	<b>DATE OF TESTING:</b>  11.04.2019 to 25.04.2019
	<b>SAMPLE DESCRIPTION</b>  <b>25 kVA Distribution Transformer</b>  11000/433 Volts,  1.31/33.33 Amp.,  Oil filled,  Vector Group: Dyn-11,  <b>ENERGY EFFICIENCY LEVEL: 2</b>  Further details as per sheet No. 3 of 9.	
<b>SAMPLE IDENTIFICATION</b>  <b>ERDA SAMPLE CODE NO.:</b> ERDA-00307717  <b>SERIAL NO.:</b> RPTPL-001  <b>DRAWING NO.:</b> RPTPL-25KVA-RP-01/02-2019 RPTPL-25KVA-RP-02/02-2019 RPTPL-GA-25KVA-02-2019 RPTPL-TD-25KVA-03-2019 RPTPL-IA-25KVA-04-2019  <b>YEAR OF MFG.:</b> 2019		
<b>TEST DETAILS</b> Short-circuit withstand test [Cl. No. (17 & 21.3 c)]  <b>ENCLOSURES:</b> Number of oscillograms : Eleven Number of photograph : One Number of test circuit diagram : One Number of drawings : Five	<b>TEST SPECIFICATIONS</b> As per customer's requirement, Test procedure followed as per IS 1180 (Part 1): 2014 [Amendment No. 1 & 2]	
<b>REMARKS:</b> The sample <b>conforms</b> to the requirements of standard for short-circuit withstand test as specified by customer.		
 <b>PREPARED BY</b>	 <b>CHECKED BY</b>	 <b>K. B. PATEL APPROVED BY</b>

- NOTE:**
1. This report relates only to the particular sample received for testing in good condition at ERDA.
  2. This report cannot be reproduced in part under any circumstances.
  3. Publication of this report requires prior permission in writing from Director, ERDA.
  4. Only test asked for by customer have been carried out.
  5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arised.

**Caution:** ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.



TC 2767810



Certificate No. : TC-5389

## ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



**ULR NO.:** TC538919000014147F

**REPORT NO.:** RP-1920-004071

**DATE:** 30.04.2019

SHEET 2 OF 9

<b>Contents</b>	
1. Technical specifications of test object assigned by customer	Sheet No. 3 of 9
2. Routine test results before short circuit	Sheet No. 4 of 9 to 5 of 9
3. Short-circuit withstand test	Sheet No. 6 of 9 to 7 of 9
4. Routine test results after short circuit	Sheet No. 8 of 9 to 9 of 9
5. Oscillogram No.	0050/01 to 0050/11
6. Photograph No.	1920-000295/0070
7. Test circuit diagram No.	OLSC/DTC/01
8. Drawing No.	RPTPL-25KVA-RP-01/02-2019 RPTPL-25KVA-RP-02/02-2019 RPTPL-GA-25KVA-02-2019 RPTPL-TD-25KVA-03-2019 RPTPL-IA-25KVA-04-2019

  
**PREPARED BY**

  
**CHECKED BY**

TC 2767809





Certificate No. : TC-5389

## ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



**ULR NO.:** TC538919000014147F

**REPORT NO.:** RP-1920-004071

**DATE:** 30.04.2019

SHEET 3 OF 9

### TECHNICAL SPECIFICATIONS OF TEST OBJECT ASSIGNED BY CUSTOMER

1. Name of manufacturer : **RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.**
2. Equipment : **25 kVA Distribution Transformer**
3. Standard No. : As per customer's requirement, Test procedure followed as per [Cl. No. (17 & 21.3 c)] of IS 1180 (Part 1): 2014 [Amendment No. 1 & 2]
4. Serial No. : RPTPL-001
5. Energy efficiency level : 2
6. Type : Outdoor, Oil Cooled, Aluminium wound, Non sealed type
7. kVA rating : 25
8. Rated voltage H.V. (Volts) : 11000  
L.V. (Volts) : 433
9. Rated current H.V. (Amp.) : 1.31  
L.V. (Amp.) : 33.33
10. Number of phases : 3
11. Connection H.V./L.V. : Delta/Star
12. Frequency (Hz.) : 50
13. Type of cooling : ONAN
14. Temperature rise of oil/winding : 35°C/40°C
15. Percentage Impedance : 4.5%
16. Primary winding conductor : SE Aluminium wire, bare dia. 0.935mm
17. Secondary winding conductor : DPC Aluminium strip, bare size (3.7mm x 8.5mm)
18. Quantity of oil (Litre) : 80
19. Weight of oil (kg.) : 67
20. Total weight (kg.) : 300
21. Vector group : Dyn-11
22. Year of manufacture : 2019
23. Insulation level H.V. : 28 kVrms
24. Insulation level L.V. : 03 kVrms
25. Total losses at 75°C (Watts) : 190 Max. (at 50 % load)
26. Total losses at 75°C (Watts) : 635 Max. (at 100 % load)

TC 2767808

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

**ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**ULR NO.:** TC538919000014147F**REPORT NO.:** RP-1920-004071**DATE:** 30.04.2019

SHEET 4 OF 9

**ROUTINE TEST RESULTS BEFORE SHORT CIRCUIT**a) MEASUREMENT OF WINDING RESISTANCE

Measurement at oil temperature: 36.9°C					
LV Winding resistance (mΩ)			HV Winding Resistance (Ω)		
u - v	v - w	w - u	U - V	V - W	W - U
99.19	98.91	99.19	99.59	99.15	99.21

b) MEASUREMENT OF VOLTAGE RATIO AND CHECK OF PHASE DISPLACEMENT

Vector group: Dyn-11 was verified.

Rated turns Ratio	Measured turns ratio between Terminals					
	U-V/u-n	Difference %	V-W/v-n	Difference %	W-U/w-n	Difference %
44.001	44.036	0.080	44.048	0.107	44.036	0.080

c) MEASUREMENT OF SHORT-CIRCUIT IMPEDANCE AND LOAD LOSS (at 100 % load)

Oil temp.: 37.2°C

Test current (Amp.) I <sub>avg</sub>	Impedance voltage (V) V <sub>avg</sub>	Frequency (Hz.)	Load loss measured (Watts)	Impedance Voltage (%Z) at 50 Hz.	Load loss computed at 75°C (Watts)	%Z at 75°C
1.310	448.292	50.027	428.478	4.073	488	4.179

d) MEASUREMENT OF LOAD LOSS (at 50 % load)

Oil temp.: 37.2°C

Test current (Amp.) I <sub>avg</sub>	Impedance voltage (V) V <sub>avg</sub>	Frequency (Hz.)	Load loss measured (Watts)	Load loss computed at 75°C (Watts)
0.655	224.018	49.978	107.263	122

TC 2767943

PREPARED BY  
*WMP*CHECKED BY  
*gpe*



Certificate No. : TC-5389

**ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**ULR NO.:** TC538919000014147F**REPORT NO.:** RP-1920-004071**DATE:** 30.04.2019

SHEET 5 OF 9

e) MEASUREMENT OF NO-LOAD LOSS AND CURRENT

Oil temp.: 37.2°C

Applied Voltage (V) Vavg.	Current (Amp.) Iavg.	Frequency (Hz.)	Losses Measured (Watts)
433.001	0.191	50.005	58

- Total losses at 75°C: 180 Watts (at 50 % load)
- Total losses at 75°C: 546 Watts (at 100% load)

f) MEASUREMENT OF INSULATION RESISTANCE

Oil temp.: 36.9°C

Measured Between	DC Test Voltage (V)	IR value (MΩ)
HV to LV winding	2500	> 2000
HV winding to LV + EARTH	2500	> 2000
LV winding to HV + EARTH	500	> 2000

g) INDUCED OVER-VOLTAGE WITHSTAND TEST

Sr. No.	Test	Applied voltage (V)	Applied Freq. (Hz.)	Duration (sec.)	Remarks
1.	Between LV windings with tank connected to earth.	866	100	60	Withstood

h) SEPARATE-SOURCE VOLTAGE WITHSTAND TEST

Sr. no.	Test	Applied voltage (kV)	Duration (sec.)	Remarks
1.	Between HV winding and LV winding connected to the tank and earth	28	60	Withstood
2.	Between LV winding and HV winding connected to the tank and earth	03	60	Withstood

TC 2767942

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

**ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**ULR NO.:** TC538919000014147F**REPORT NO.:** RP-1920-004071

SHEET 6 OF 9

**DATE:** 30.04.2019**SHORT-CIRCUIT WITHSTAND TEST:**

The verification of the short-circuit withstand test was performed on the high voltage winding connected to three phase-balanced source and low voltage winding short circuited through current measuring instruments. Test conducted with pre set short circuit as per schematic circuit diagram No.: OLSC/DTC/01.

Condition of the equipment under test: As after routine tests.

Supply Frequency: 50 Hz.

Test No.	Oscillogram No.	Applied voltage (kVrms)	Short circuit current on LV (A)			Duration (sec.)	Remarks
			Peak	RMS	Avg.		
1.	0050/01	-	- 1130 -	622 627 620	623	0.1	Calibration shot
2.	0050/02	11	- 1401 -	782 783 773	779	0.5	No Abnormality
3.	0050/03	11	- 1404 -	781 782 773	779	0.5	No Abnormality
4.	0050/04	11	- 1399 -	782 782 772	779	0.5	No Abnormality
5.	0050/05	11	- - 1374	780 782 773	778	0.5	No Abnormality
6.	0050/06	11	- - 1380	780 783 773	779	0.5	No Abnormality
7.	0050/07	11	- - 1371	781 782 772	778	0.5	No Abnormality
8.	0050/08	11	1371 - -	778 785 774	779	0.5	No Abnormality
9.	0050/09	11	1318 - -	780 788 778	782	0.5	No Abnormality
10.	0050/10	11	1366 - -	783 786 776	782	0.5	No Abnormality
11.	0050/11	11	- 1403 -	778 780 771	776	2.0	Thermal Shot* No Abnormality

\*As per customer's requirement

TC 2767811

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

**ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**ULR NO.:** TC538919000014147F**REPORT NO.:** RP-1920-004071**DATE:** 30.04.2019

SHEET 7 OF 9

**Measurement of the % reactance during the short circuit test**

LV winding was short circuited. Three phase AC supply was connected to HV winding to pass test current. Before the short circuit test and after each shot, the percentage reactance was measured.

Sr. No.	Measurement performed		Measured value of % reactance at 50 Hz.			%Change in % reactance		
			U	V	W	U	V	W
1.	Before test		3.73	3.71	3.72	-	-	-
2.	After the test no.	2.	3.73	3.71	3.72	0.00	0.00	0.00
3.	After the test no.	3.	3.73	3.71	3.72	0.00	0.00	0.00
4.	After the test no.	4.	3.73	3.71	3.72	0.00	0.00	0.00
5.	After the test no.	5.	3.73	3.71	3.72	0.00	0.00	0.00
6.	After the test no.	6.	3.73	3.71	3.72	0.00	0.00	0.00
7.	After the test no.	7.	3.73	3.71	3.72	0.00	0.00	0.00
8.	After the test no.	8.	3.73	3.71	3.72	0.00	0.00	0.00
9.	After the test no.	9.	3.73	3.71	3.72	0.00	0.00	0.00
10.	After the test no.	10.	3.73	3.71	3.72	0.00	0.00	0.00
11.	After the test no.	11.	3.73	3.71	3.72	0.00	0.00	0.00


  
**PREPARED BY**

  
**CHECKED BY**

TC 2767940





Certificate No. : TC-5389

**ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**ULR NO.:** TC538919000014147F**REPORT NO.:** RP-1920-004071**DATE:** 30.04.2019

SHEET 8 OF 9

**ROUTINE TEST RESULTS AFTER SHORT CIRCUIT**a) MEASUREMENT OF WINDING RESISTANCE

Measurement at oil temperature: 34.5°C					
LV Winding resistance (mΩ)			HV Winding Resistance (Ω)		
u - v	v - w	w - u	U - V	V - W	W - U
99.36	99.06	99.33	99.43	99.01	99.06

b) MEASUREMENT OF VOLTAGE RATIO AND CHECK OF PHASE DISPLACEMENT

Vector group: Dyn-11 was verified.

Rated turns Ratio	Measured turns ratio between Terminals					
	U-V/u-n	Difference %	V-W/v-n	Difference %	W-U/w-n	Difference %
44.001	44.036	0.080	44.035	0.077	44.036	0.080

c) MEASUREMENT OF SHORT-CIRCUIT IMPEDANCE AND LOAD LOSS (at 100 % load)

Oil temp.: 34.3°C

Test current (Amp.) I <sub>avg</sub>	Impedance voltage (V) V <sub>avg</sub> .	Frequency (Hz.)	Load loss measured (Watts)	Impedance Voltage (%Z) at 50 Hz.	Load loss computed at 75°C (Watts)	%Z at 75°C
1.310	447.860	50.009	426.634	4.070	492	4.186

d) MEASUREMENT OF LOAD LOSS (at 50 % load)

Oil temp.: 34.3°C

Test current (Amp.) I <sub>avg</sub> .	Impedance voltage (V) V <sub>avg</sub> .	Frequency (Hz.)	Load loss measured (Watts)	Load loss computed at 75°C (Watts)
0.654	223.547	50.033	106.284	123

TC 2767939

PREPARED BY

CHECKED BY







Certificate No.: TC-5389

**ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**ULR NO.:** TC538919000014147F**REPORT NO.:** RP-1920-004071

SHEET 9 OF 9

**DATE:** 30.04.2019**e) MEASUREMENT OF NO-LOAD LOSS AND CURRENT**

Oil temp.: 34.3°C

Applied Voltage (V) Vavg.	Current (Amp.) Iavg.	Frequency (Hz.)	Losses Measured (Watts)
433.312	0.192	50.007	58

- Total losses at 75°C: 181 Watts (at 50 % load)
- Total losses at 75°C: 550 Watts (at 100% load)

**f) MEASUREMENT OF INSULATION RESISTANCE**

Oil temp.: 34.5°C

Measured Between	DC Test Voltage (V)	IR value (MΩ)
HV to LV winding	2500	> 2000
HV winding to LV + EARTH	2500	> 2000
LV winding to HV + EARTH	500	> 2000

**g) INDUCED OVER-VOLTAGE WITHSTAND TEST**

Sr. No.	Test	Applied voltage (V)	Applied Freq. (Hz.)	Duration (sec.)	Remarks
1.	Between LV windings with tank connected to earth	866	100	60	Withstood

**h) SEPARATE-SOURCE VOLTAGE WITHSTAND TEST**

Sr. No.	Test	Applied voltage (kV)	Duration (sec.)	Remarks
1.	Between HV winding and LV winding connected to the tank and earth	28	60	Withstood
2.	Between LV winding and HV winding connected to the tank and earth	03	60	Withstood

**Observation after test:** The transformer was untanked and inspected.

- 1) Condition of conductor, core and clamping:
  - No visible damage, deformation or displacement.
- 2) Condition of oil : Clear
- 3) Condition of spacers : Intact

**Results:** 1) % Change in % reactance is within tolerance limits as per standard.

- 2) The results of routine tests carried out before and after the short-circuit withstand test found within limits as per standard.

TC 2767938

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org


Web : http://www.erda.org



**ULR NO.:** TC538919000014147F

**REPORT NO.:** RP-1920-004071

**DATE:** 30.04.2019



TC 2716280

OSCILLOGRAM NO. : 0050/01





Certificate No. : TC-5389

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org


Web : http://www.erda.org



**ULR NO.:** TC538919000014147F

**REPORT NO.:** RP-1920-004071

**DATE:** 30.04.2019



TC 2716281

OSCILLOGRAM NO. : 0050/02





Certificate No. : TC-5389

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org


Web : http://www.erda.org



**ULR NO.:** TC538919000014147F

**REPORT NO.:** RP-1920-004071

**DATE:** 30.04.2019



TC 2716282

OSCILLOGRAM NO. : 0050/03





Certificate No. : TC-5389

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org


Web : http://www.erda.org



**ULR NO.:** TC538919000014147F

**REPORT NO.:** RP-1920-004071

**DATE:** 30.04.2019



TC 2716284

OSCILLOGRAM NO. : 0050/04





Certificate No. : TC-5389

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org


Web : http://www.erda.org



**ULR NO.:** TC538919000014147F

**REPORT NO.:** RP-1920-004071

**DATE:** 30.04.2019



TC 2716285

OSCILLOGRAM NO. : 0050/05





Certificate No. : TC-5389

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : http://www.erda.org



**ULR NO.:** TC538919000014147F  
**REPORT NO.:** RP-1920-004071

**DATE:** 30.04.2019



TC 2716286

OSCILLOGRAM NO. : 0050/06





Certificate No. : TC-5389

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org


Web : http://www.erda.org



**ULR NO.:** TC538919000014147F

**REPORT NO.:** RP-1920-004071

**DATE:** 30.04.2019



TC 2716287

OSCILLOGRAM NO. : 0050/07







Certificate No. : TC-5389

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : http://www.erda.org



**ULR NO.:** TC538919000014147F  
**REPORT NO.:** RP-1920-004071

**DATE:** 30.04.2019



TC 2716288

OSCILLOGRAM NO. : 0050/08





# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




Certificate No. : TC-5389

**ULR NO.:** TC538919000014147F

**REPORT NO.:** RP-1920-004071

**DATE:** 30.04.2019



TC 2716289

OSCILLOGRAM NO. : 0050/09





# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




Certificate No. : TC-5389

**ULR NO.:** TC538919000014147F

**REPORT NO.:** RP-1920-004071

**DATE:** 30.04.2019



TC 2716290

OSCILLOGRAM NO. : 0050/10





Certificate No. : TC-5389

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : http://www.erda.org



**ULR NO.:** TC538919000014147F  
**REPORT NO.:** RP-1920-004071

**DATE:** 30.04.2019



OSCILLOGRAM NO.: 0050/11

TC 2716291



Certificate No. : TC-5389

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



**ULR NO.:** TC538919000014147F  
**REPORT NO.:** RP-1920-004071

**DATE:** 30.04.2019




**DISTRIBUTION TRANSFORMER**  
**RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.** IS 1180  
 Koroia-Bhinmal Road, Sanchole Dist - Jalora, Rajasthan. PART I CML-840036165

PHASE TRANSFORMER	ENERGY EFFICIENCY LEVEL
STANDARD	MAX. TOTAL LOSSES
KVA	AT 50% RATED LOAD W
VOLTS AT NO LOAD	MAX. TOTAL LOSSES
H.V.	AT 100% RATED LOAD W
L.V.	TYPE OF COOLING
BIL	TEMP RISE OIL DEG C
H.V.	TEMP RISE WDG DEG C
L.V.	MASS OF OIL KGS
AMPERES	TOTAL MASS KGS
H.V.	VOL. OF OIL L
L.V.	MONTH & YEAR OF MFG.
FREQUENCY Hz	TAPPING
VECTOR GROUP REF.	FOR HV VARIATION
IMPEDANCE VOLT %	IN STEP FROM TO %
TAPPING	CUSTOMER
ORDER NO.	

**MADE IN INDIA**



TC 2767937



- CB - 66 KV CIRCUIT BREAKER
- TR - 66/11KV TRANSFORMER
- ISO - ISOLATOR
- BCB - BACKUP CIRCUIT BREAKER
- HMS - H.T. MAKE SWITCH
- X - SOURCE SIDE REACTANCE
- R - SOURCE SIDE RESISTANCE
- PT - POTENTIAL TRANSFORMER
- TT - TEST TRANSFORMER
- S - CURRENT MEASURING DEVICE



REPORT NO.: RP-1920-004071  
 DATE: 30.04.2019

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION		SCHEMATIC CIRCUIT DIAGRAM	
DRN. BY	CKD.	DATE	DRG. NO.
S. B. S.	M. B. M	27-1-98	OLSC/DTC/01



Test Report No. RP-1920-00421  
 Date 30.04.2019  
 Product 25 kVA D.T.  
 Verified by W  
 Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with \*\*

**DISTRIBUTION TRANSFORMER**

**RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.**

KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041  
 RAJASTHAN.(INDIA)




PART-I  
 CM/L-8400030105

<b>3</b> PHASE TRANSFORMER	IS:1180 (2014)	ENERGY EFFICIENCY LEVEL	<b>2</b>
STANDARD KVA	<b>25</b>	MAX. TOTAL LOSSES AT 50% RATED LOAD W	<b>190</b>
VOLTS AT NO LOAD	HV <b>11000</b> LV <b>433</b>	MAX. TOTAL LOSSES AT 100% RATED LOAD W	<b>635</b>
BIL	HV <b>95kVp/28kVrms</b> LV <b>-/3kVrms</b>	TYPE OF COOLING	<b>ONAN</b>
AMPERES	HV <b>1.31</b> LV <b>33.33</b>	TEMP RISE OIL DEG C	<b>35</b>
FREQUENCY	<b>50 Hz</b>	TEMP RISE WDG DEG C	<b>40</b>
VECTOR GROUP REF.	<b>Dyn-11</b>	MASS OF OIL KGS	<b>67</b>
IMPEDANCE VOLT %	<b>4.5</b>	TOTAL MASS KGS	<b>300</b>
TAPPING	<b>-</b>	VOL. OF OIL L	<b>80</b>
FOR HV VARIATION		MONTH & YEAR OF MFG.	<b>MAR-2019</b>
IN <input type="text"/> STEP FROM <input type="text"/> TO <input type="text"/> %		SERIAL NO.	<b>RPTPL-001</b>

CUSTOMER   
 ORDER NO.

**MADE IN INDIA**



**SIZE: 105x105 mm HOLE CENTER: 95x95 mm**

NOTE:  
 \* SERIAL NO, YEAR OF MANUFACTURE & MONTH OF MANUFACTURE WILL BE PUNCHED AT THE TIME OF DISPATCH  
 MATERIAL : Anodized Aluminum  
 THICKNESS : 1.5mm

**RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.**  
 KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041  
 RAJASTHAN.


DRN BY		RATING & TERMINAL MARKING PLATE FOR 25 KVA, 11/0.433 KV DISTRIBUTION TRANSFORMER 3 PHASE, ENERGY EFFICIENCY LEVEL-2
CHD BY		
APPD BY		

REV. NO.	DATE SIGN	BRIEF DESCRIPTION	
	16.03.2019	01 of 02	

DRG. NO. RPTPL-25KVA-RP-01/02-2019



Test Report No. RP-1920-004071  
 Date 30.04.2019  
 Product 25 KVA DG  
 Verified by MP  
 Verification of this drawing by ERDA is limited to relevant dimensional checks only.  
 Verified dimensions are marked with \*\*



SIZE: 105x105 mm HOLE CENTER: 95x95 mm

NOTE:  
 \* SERIAL NO.,  
 YEAR OF MANUFACTURE &  
 MONTH OF MANUFACTURE  
 WILL BE PUNCHED AT THE TIME OF DISPATCH  
 MATERIAL : Anodized Aluminum  
 THICKNESS : 1.5 mm


RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.

KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041  
 RAJASTHAN.

DRN BY  
 CHD BY  
 APPD BY

RATING & TERMINAL MARKING PLATE FOR  
 25 KVA, 11/0.433 KV DISTRIBUTION TRANSFORMER  
 3 PHASE , ENERGY EFFICIENCY LEVEL-2

REV. NO.	DATE SIGN	BRIEF DESCRIPTION
	16.03.2019	02 of 02



DRG. NO. RPTPL-25KVA-RP-02/02-2019




SR.NO.	ACCESSORIES	QTY.	TECHNICAL DETAILS AS PER SPECS PER OFFER
1	CONSERVATOR WITH OIL FILLING HOLE WITH CAP & DRAIN PLUG	1	M.S.
2	OIL LEVEL GAUGE WITH 3 POSITION	1	M.S.
3	SILICAGEL BREATHER (500 Grams.)	1	AL DIE CAST AL. DIE CAST
4	H.V. TERMINAL 12mm. DIA. WITH NUT	3	BRASS
5	H.V. BUSHING 12KV, 250A	3	PORCELAIN
6	L.V. TERMINAL 12 mm. DIA. WITH NUT	4	BRASS
7	RATING & TERMINAL MARKING PLATE	1	ANODISED
8	STIFFENER ANGLE SIZE (40x40x5 mm.)	4	M.S.
9	EARTHING TERMINAL WITH LUGS SIZE (16 Amp.)	2	M.S.
10	BASE CHANNELS 75x40x46Dmm. LENG.	2	M.S.
11	L.V. BUSHING 1.1KV, 250A	4	TENDER DRG. PORCELAIN
12	L.V. BUSHING 1.1KV, 250A	4	PORCELAIN
13	THERMOMETER POCKET	1	M.S.
14	LIFTING LUGS FOR COVER	2	M.S.
15	LIFTING LUGS FOR TANK REINFORCED WITH FLAT	2	M.S.
16	AIR RELEASE PLUG	1	M.S.
17	PULLING LUG	4	M.S.
18	CONSERVATOR PIPE	2	M.S.
19	METALLIC TIN PLATE	1	S.S.
20	MCCB BOX	1	-

**COOLING DETAILS**


1	TOTAL SURFACE AREA :- TANK: 1.1664 sq. m.	N. A.
2	NUMBER OF RADIATORS	N. A.
3	HEIGHT x WIDTH OF FINS	N. A.
4	TOTAL NUMBER OF COOLING FINS	N. A.

1 WEIGHTS IN KGS. (+/- 10% TOL.)		5 DIMENSIONS IN mm.	
CORE	80	TRANSFORMER OVERALL (+/- 10% TOLERANCE)	L = 908
WINDINGS	33	L	W = 495
TANK & FITTINGS	86	H	H = 1150
OIL	67	TRANSFORMER TANK (+/- 10% TOLERANCE)	L1 = 665
TOTAL WEIGHT	300	W1	W1 = 250
THICKNESS IN mm.	3, 15	H1/H2 =	635 / 645
TANK SIDE PLATES (MIN.)	5	6 BUSHING CLEARANCES WITH ANGLE	
TOP & BOTTOM PLATES (MIN.)	5	L3 (H.V.)	255 PHASE TO PHASE
OVERALL DIMENSIONS	+/- 10 %	L4 (L.V.)	75 PHASE TO PHASE
DIMENSIONS OF CONSERVATOR		L5 (H.V.)	205 PHASE TO EARTH
a) INSIDE DIAMETER IN mm.	140	L6 (L.V.)	55 PHASE TO EARTH
b) LENGTH IN mm.	600		
c) CAPACITY IN LITRS.	9		



**SIDE VIEW**

**ELEVATION**



**PLAN**

Test Report No. RP-1920-004071  
 Date 30.04.2019  
 Product 25 kVA Φ.7  
 Verified by WVP  
 Verification of this drawing by ERDA is limited to relevant dimensional checks only.  
 Verified dimensions are marked with \*



- NOTE**
- 1 SHAPE OF TANK: RECTANGULAR SHAPE
  - 2 ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE STATED.
  - 3 METALLIC TIN PLATE: OPPOSITE SIDE OF COMBINED NAME PLATE
  - 4 \* NOT PROVIDED DURING TESTING

**RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.**  
 KAROLA-BHINMAL ROAD KAROLA, SANCHORE-343041

GENERAL ARRANGEMENT DRAWING  
 25 KVA 11/0.433 KV DIST. TRANSFORMER  
 ENERGY EFFICIENCY LEVEL-2




DRG.NO.: RPTPL-GA-25KVA-02-2019  
 DATE: 16.03.2019

S.N.		TECHNICAL DETAILS										
		AS PER SPECIFIED					AS PER OFFERED					
1	PRIMARY VOLTAGE (KV)	11				11						
2	SECONDARY VOLTAGE (KV)	0.433				0.433						
3	RATING (KVA)	25				25						
4	VECTOR GROUP	DYN-11				DYN-11						
5	CONFORMING TO I.S.	1180 PART-1, 2014				1180 PART-1, 2014						
6	PERMISSIBLE VOLTAGE FLUCTUATION %	12.5				12.5						
7	TEMP OF TOP OIL (MAX) °C	35				35						
8	TEMP OF WINDING (MAX) °C	40				40						
<b>CORE DETAIL</b>												
a	CORE MATERIAL	CRGO				CRGO						
b	PRINCIPAL SOURCE OF CORE MATERIAL	CRGO				CRGO						
c	GRADE OF LAMINATION	M4 OR BETTER				M4 OR BETTER						
d	FLUX DENSITY w/m <sup>2</sup>	1.69 MAX.				1.69 MAX.						
e	NO STEPS OF CORE (NOS)	11				11						
10	% IMPEDENCE	4.5				4.5						
11	CORE DIMENSIONS											
	STEP NO.	1	2	3	4	5	6	7	8	9	10	11
	L MM	80	75	70	65	60	55	50	45	40	30	20
	W MM	25	12	16	12	14	32	33	32	27	22	22
	GROSS SECTION CM <sup>2</sup>	20.08	9.15	16.02	14.29	3.24	2.33	2.00	1.53	1.12	1.32	0.6
	TOTAL GROSS SECTION AREA CM <sup>2</sup>	= 51.88 CM <sup>2</sup>										
	EFFECTIVE CORE AREA - 51.88 x 0.97 = 50.32 CM <sup>2</sup>											

S.N.		AS PER SPECIFIED		AS OFFERED	
		HV	LV	HV	LV
12	WINDING	ALU	ALU	ALU	ALU
	a) MATERIAL	ALU	ALU	ALU	ALU
	b) ELECTRIC CONDUCTIVITY N/G MM <sup>2</sup> AT 20°C	2.83	2.83	2.83	2.83
	c) CONDUCTOR SIZE IN mm <sup>2</sup>	0.935 DIA	0.935 DIA	0.935 DIA	0.935 DIA
	d) CONDUCTOR GROSS SECTION mm <sup>2</sup>	3.7 x 8.5	3.7 x 8.5	3.7 x 8.5	3.7 x 8.5
	e) INSULATION MATERIAL	0.6866	0.6866	0.6866	0.6866
	f) INSULATION MATERIAL	SE	SE	SE	D.P.C
	g) CURRENT DENSITY A/MM <sup>2</sup>	1.1034	1.1034	1.1034	1.0897
	h) NO OF TURNS PER PHASE	194	194	194	152
	i) OUTER DIA. mm	146	146	146	124
	j) INSIDE DIA. mm	79 each	79 each	79 each	91
	k) NO OF COILS PER PHASE	4	4	4	4
13	BUSHING	AS SPECIFIED	AS SPECIFIED	AS SPECIFIED	AS SPECIFIED
14	MINIMUM CREEPSPACE DISTANCE				
15	MAXIMUM TOTAL LOSSES @ 50%	190 W	190 W	190 W	190 W
	MAXIMUM TOTAL LOSSES @ 100%	635 W	635 W	635 W	635 W
	TANK				
	SIDE WALL THICKNESS mm				3.15
	TOP & BOTTOM PLATE THICKNESS mm				5
	OIL USED				
16	NAME OF MANUFACTURER	APPROVED MAKE	APPROVED MAKE	ANY MAKE APPR BY CO	ANY MAKE APPR BY CO
	GRADE	EHV	EHV	EHV	EHV
	VOLUME (K.us.)				67
	IN TANK (IN LTRs.)				77
	IN CONSERVATOR (IN LTRs.)				3
	TOTAL (IN LTRs.)				80
17	BREATHER				
	CAPACITY	500 gms.	500 gms.	ANY MAKE APPR BY CO	500 gms.
18	RADIATOR				
	MAKE				
	DETAILED HEAT DISSIPATION CALCULATIONS.	TO BE ENCLOSED	TO BE ENCLOSED	ANY MAKE APPR BY CO	TO BE ENCLOSED




**RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.**  
 KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041

TECHNICAL DETAIL DRAWING  
 25 KVA 11/0.433 KV DIST. TRANSFORMER  
 ENERGY EFFICIENCY LEVEL-2

DRG.NO.: RPTPL-ID-25KVA-03-2019  
 DATE: 16.03.2019

Test Report No. RP-1920-004071  
 Date 30.04.2019  
 Product 25 KVA DT  
 Verified by MP  
 Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with \*.

**WINDING & CONSTRUCTION DETAILS.**



CORE	DESCRIPTION	AS PER TECH SPECIFIED	AS FOR OFFER
A	LEG. CENTRES mm.		205
B	WINDOW HEIGHT (CHANNEL TO CHANNEL)		384
C	CORE CIRCLE mm.		84
D	NO OF STEPS.		11
	EFFECTIVE CORE AREA CMF		50.32
L.V. COIL			
E	OUTER DIA IN mm.		124
F	INSIDE DIA IN mm.		91
G	AXIAL LENGTH mm.		343
	CONDUCTOR CROSS SECT. mm <sup>2</sup>		30.59
	CONDUCTOR INSULATION		DIC
H.V. COIL			
H	NO OF HV COIL PER Ph.		4
I	OUTER DIA mm.		194
J	INSIDE DIA mm.		146
	AXIAL LENGTH mm.		79
	CONDUCTOR CROSS SECT. mm <sup>2</sup>		0.6866
	CONDUCTOR INSULATION		S.E.
INSULATION			
K	INSULATION BETWEEN (TAP COILS) mm.		
L	BASE FLAT INSULATION mm.		2
N	GAP BETWEEN CORE & L.V. mm.	3.5	3.5
O	WEDGES BETWEEN HV & L.V. COILS NO.		6
P	GAP BETN HV & L.V. mm.	MIN 11	MIN 11
Q	FRAME CHANNEL INSULATION		2
R	PHASE BARRIER mm.	2 x 1	2 x 1
S	END INSULATION mm.	25	25
T	CLEARANCE TO TANK WALL mm.	50	50
U	FROM H.V. WDG.		
V	BOTTOM FRAME SIZE ISMC mm.		75 x 40
W	BASE M.S. FLAT SIZE mm.		40 x 10
X	NO. OF SPACERS BETN TWO HV COILS	6	6
Y	INTER PHASE CLEARANCE mm.	MIN 10	MIN 10
	TIE ROD SIZE & NO.		12 mm x 4
	CORE STUD SIZE & NO.		12 mm x 4

NOTE: THICKNESS OF SPACER = 3MM



Test Report No. RP-1920-004071  
 Date 30.04.2019  
 Product 2.5 kVA D-2  
 Verified by MP  
 Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with \*\*

**RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.**  
 KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041

INTERNAL ARRANGEMENT DRAWING  
 25 KVA 11/0.433 KV DIST. TRANSFORMER  
 ENERGY EFFICIENCY LEVEL-2

DRG.NO.: RPTPL-IA-25KVA-04-2019  
 DATE: 16.03.2019