



#### **ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382 E-mail : erda@erda.org

Web: http://www.erda.org



#### **TEST REPORT**

ULR-TC538919000014527F	Sheet	: 1	of	15

NAME AND ADDRESS OF CUSTOMER	<b>REPORT NO.:</b> RP-1920-00	4663	
	<b>DATE</b> : 02.05.2019		
RAJASTHAN POWERGEN TRANSFORMER	CUSTOMER REF. NO.	DATE	
PVT. LTD.	LETTER	03.04.2019	
KHASRA NO. 911-914, KAROLA-BHINMAL	DATE OF SAMPLE	DATE OF TESTING	
ROAD, KAROLA, SANCHORE,	RECEIPT	DATE OF TESTING	
RAJASTHAN-343041	20 02 2010	08.04.2019 TO	
	20.03.2019	25.04.2019	
SAMPLE DESCRIPTION	SAMPLE IDENTIFICATION		
DISTRIBUTION TRANSFORMER	ERDA sample code number : ERDA-00307717		
(NON-SEALED TYPE)	Manufacturer serial number: RPTPL-001		
Manufactured by: RAJASTHAN POWERGEN	Year of manufacture: 2019		
TRANSFORMER PVT. LTD.	Enclosed drawing numbers :		
Rating : 25 kVA	1) RPTPL-25KVA-RP-01/02-2019 SHEET 01 OF 02		
Volts : 11000/433 V (at no-load)	2) RPTPL-25KVA-RP-02/02-2019 SHEET 02 OF 02		
Current : 1.31/33.33 Amps	3) RPTPL-GA-25KVA-02-20		
Phases: 3/3	4) RPTPL-CD-25KVA-05-2	019	
Vector group: Dyn11		ž.	
Energy efficiency level: 2			
Further details as per sheet no.2			
TEST DETAILS	TEST SPECIFICATION		
As per sheet 3 of 15.	As per sheet 3 of 15.		

TEST RESULTS: As per sheets from 4 of 15 to 14 of 15.

**ENCLOSURE**: Photographs of test sample – As per sheet 15 of 15.

**REMARKS**: 1) The transformer **conforms** to the guaranteed requirement as per above

mentioned test specification for above mentioned test nos. 3,4,5,6,9,10,11,

12,14.

2) Criteria limit has not been specified for test nos. 1,2,7,8 & 13.

PREPARED BY

CHECKED BY

APPROVED BY (Kapil J. Sharma)

Note: 1. This report relates only to the particular sample received for testing in good condition at E.R.D.A., Makarpura.

2. This report cannot be reproduced in part under any circumstances.

3. Publication of this report requires prior permission in writing from Director, E.R.D.A.

4. Only the tests asked for by the customer have been carried out.

5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arised.

Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports.

ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.







(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India. EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org Web : http://www.erda.org



#### ULR-TC538919000014527F

TECHNICAL	<b>SPECIFICATIONS</b>	OF TEST OBJECT	<b>ASSIGNED BY</b>	CUSTOMER
	- OF LCTI TOWITOINS		WOOTGILED DI	COSIONER

1.	Name of Manufacturer	RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
2.	Sr.No.	RPTPL-001
3.	kVA rating	25
4.	Rated Voltage H.V.(Volts)	11000
5.	Rated Voltage L.V.(Volts)	433
6.	Rated Current H.V.(Amp.)	1.31
7.	Rated Current L.V.(Amp.)	33.33
8.	Number of phases	3
9.	Energy Efficiency level	2
10.	Vector Group	Dyn11
11.	Winding Material	Aluminium
12.	Type of Cooling	ONAN
13.	Frequency (Hz)	50
14.	Guaranteed Percentage impedance (%)	4.5
15.	Total losses at 50 % load (Watts)	190
16.	Total losses at 100 % load (Watts)	635
17.	Guaranteed temperature rise of oil/Winding	35/40°C
18.	Year of Manufacture	2019
19.	Standard no.	IS 1180 (PART-1) 2014 with amendment n 1,2 & 3,IS 2026, As per CBIP manual ,as p customer's requirement.

PREPARED BY





# **ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail: erda@erda.org

: http://www.erda.org





# ULR-TC538919000014527F

Web

REPO DATE	RT NO.: RP-1920-004663 : 02.05.2019	<b>Sheet:</b> 3 of 15
	TEST DETAILS	TEST SPECIFICATION
1.	Measurement of short-circuit impedance and load loss at 50 percent and 100 percent load	As per cl.no.21.2.c of IS 1180 (Part 1):2014
2.	Measurement of no-load loss and current	As per cl.no.21.2.d of IS 1180 (Part 1):2014
3.	Total losses at 50 % load	As per cl.no. 6.8 of IS 1180 (Part 1):2014
4.	Total losses at 100 % load	As per cl.no. 6.8 of IS 1180 (Part 1):2014
5.	Temperature rise test	As per customer's requirement, testing procedure followed as per Cl.no.21.3.b of IS 1180 (Part 1):2014
6.	Magnetic balance test	As per CBIP manual; Publication no.317 - 2013
7.	Measurement of unbalance current	As per customer's requirement
8.	Measurement of zero-sequence impedance(s) on three-phase transformers	As per customer's requirement, testing procedure followed as per cl.no.10.7 of IS 2026 (Part 1): 2011
9.	Oil leakage test	As per cl.no.21.2.j of IS 1180 (Part 1):2014
10.	Pressure test (routine test)	As per cl.no.21.2.h of IS 1180 (Part 1):2014
11.	Pressure test (type test)	As per cl.no.21.3.d of IS 1180 (Part 1):2014
12.	Determinations of sound levels	As per customer's requirement, testing procedure followed as per cl. no. 21.4.a of IS 1180 (Part 1): 2014 & cl. No.13 of IS 2026(Part 10): 2009
13.	Measurement of the Harmonics of the No-load current	As per customer's requirement testing procedure followed as per cl.no.10.6. of IS: 2026 (PART 1)-2011
14.	Permissible flux density and over fluxing	As per cl.no.6.9 of IS 1180 (Part 1):2014
PREF	PARED BY CHECK	ED BY





(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33 Fax : +91 (0265) 2638382

E-mail: erda@erda.org

: http://www.erda.org



#### ULR-TC538919000014527F

Web

REPORT NO.: RP-1920-004663 **Sheet:** 4 of 15

DATE : 02.05.2019

DAIL				
		Requirement as		
Sr.		per	Obtained	
No.	Particulars of test and Cl. No.	specification	Value	Remarks
1.	Measurement of short-circuit			
	impedance and load loss at 50 percent			
	and 100 percent load:			
	(As per cl.no.21.2.c of IS 1180 (Part 1):			
	2014)			
	At 50% load :			
	Tested with 0.6552 Amps (on HV side)			
	Frequency: 49.995 Hz			
	Oil temperature: 28.6 °C			
	Test current (Amps)		0.6552	
	Impedance voltage (Volts)		222.75	
	Measured load loss (Watts)		104.09	
	Impedance voltage (%)		107.03	
	(Computed to 50% load)			
	At 28.6°C		2.03	
	At 75°C		2.05	
	Load loss (Watts)		2.05	
	(Computed to 50% load)		104.24	
	At 28.6°C At 75°C		104.34	
	At 75 C		122.98	
	At 100% load :			
	Tested with 1.3117 Amps (on HV side)			
	Frequency: 49.992 Hz			
	A CONTRACTOR OF THE CONTRACTOR			
	Oil temperature : 28.6°C		1 2117	
	Test current (Amps)	1	1.3117	
	Impedance voltage (Volts)		446.08	
	Measured load loss (Watts)	1	417.57	
	Impedance voltage (%)	1		
	(Computed to 100% load)		4.05	
	At 28.6°C		4.05	Conforms
	At 75°C	,	4.18	Conforms
	Load loss (Watts)	1	1	
	(Computed to 100% load)		446.40	
	At 28.6°C		416.49	
	At 75°C		490.95	

PREPARED BY





(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33 Fax : +91 (0265) 2638382

: erda@erda.org E-mail

Web : http://www.erda.org



#### ULR-TC538919000014527F

REPORT NO.: RP-1920-004663 **Sheet:** 5 of 15

DATE : 02.05.2019

Sr.	74	Requirement as	Obtained	
No.	Particulars of test and Cl. No.	per specification	Value	Remarks
2.	Measurement of no-load loss and			III III
	current:	e		"
	(As per cl.no.21.2.d of IS 1180 (Part 1):			
	2014)Tested with average 433.92 Volts			
	(on LV side)			
				U
	Frequency: 50.080 Hz			
	RMS voltage (Volts)		435.46	
	No-load current (mA)		192.67	_se
	Measured no-load loss (Watts)		58.45	
	Corrected no-load loss (Watts)		58.25	
3.	Total losses at 50 % load (Watts):	Max. 190	181.23	Conforms
	(As per cl.no.6.8 of IS 1180 (Part 1):2014)			
4.	Total losses at 100 % load (Watts):	Max. 635	549.20	Conforms
	(As per cl.no.6.8 of IS 1180 (Part 1):2014)			
			1	

PREPARED BY





(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

: +91 (0265) 2638382 E-mail: erda@erda.org

: http://www.erda.org Web



#### ULR-TC538919000014527F

**Sheet:** 6 of 15 **REPORT NO.:** RP-1920-004663

DATE • 02 05 2019

DATE					
Sr.		Requirement as	Obtained	Damanula	
No.	Particulars of test and Cl. No.	per specification	value	Remarks	
5.	Temperature-rise test: (As per customer's requirement, testing procedure followed as per Cl.no.21.3.b of IS 1180 (Part 1):2014) Before starting test, the dimensions of tank were measured & recorded. Size of tank: L1-665 mm, W1-250 mm, H1-635 mm, H2-645 mm,			Conforms	
	Specified losses fed for temperature- rise test were 635 Watts.  Specified losses were fed to the				
i,	transformer (i.e. Supply was connected to HV winding and LV winding kept short-circuited) till steady state temperature-rise was attained. Top oil temperature was recorded hourly. After steady state condition, the losses were brought down in reference to the rated current one hour prior to shut down.  At the shutdown, the hot windings resistance were measured and temperature-rise calculated.  A) Top oil temperature-Rise  B) Winding Temperature Rise  (Resistance method)  1) HV Winding		28.1°C 32.4°C		
	2) LV Winding	: Max. 40 °C : Max. 40 °C	32.8°C	ii	
	C) Ambient temperature at shutdown D)Time of Shutdown(HRS)		38.9°C 15:30		

PREPARED BY

CHECKED







**REPORT NO.:** RP-1920-004663

# **ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382 E-mail : erda@erda.org

: http://www.erda.org





**Sheet:** 7 of 15

#### ULR-TC538919000014527F

Web

DAT		5.2019				
Sr. No.	Particulars of test and Cl. No.			Requirement as per specification	Obtained Value	Remarks
6.	Magnetic bal (As per CBIP r 2013)	ance test : nanual; Publica	ation no.317 -			Conforms
	Voltage Applied Between	Applied Voltage (Volts)	Measured Voltage Between		v	
	2u & 2n	100.03	2v & 2n 2w & 2n	50 to 90 V	71.35 29.39	
	2v & 2n	100.08	2u & 2n 2w & 2n	30 to 70 V 30 to 70 V	49.31 51.25	
	2w & 2n	100.32	2u & 2n 2v & 2n	50 to 90 V	27.41 73.91	
7.	Measurement of unbalance current:  (As per customer's requirement)  All the three terminals of the secondary (LV) winding shorted together, except neutral terminal. Ammeter was connected between short circuited secondary (LV) windings and neutral terminal for measurement of unbalance current. 3-phase voltage was applied to the primary (HV) winding for circulating rated current in both the windings and					

PREPARED BY

measured unbalance current.

b) Measured unbalance current:

c) Measured unbalance current(%):

a) Rated secondary (LV) winding current:

CHECKED BY



33.33 Amp

<0.1 Amp

< 0.3





# **ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382 E-mail : erda@erda.org

: http://www.erda.org





# ULR-TC538919000014527F

Web

REPORT	NO.: RP-1920-004663	<b>Sheet:</b> 8 of 15
DATE	<u>• 02 05 2019</u>	

DATI	ATE : 02.05.2019				
Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained Value	Remarks	
8.	Measurement of zero-sequence			Bank 1000 3000	
	impedance(s) on three-phase				
	transformers :	g.			
	(As per customer's requirement, testing	n x			
	procedure followed as per cl.no.10.7 of				
	IS 2026 (Part 1): 2011)				
	The 2u, 2v and 2w terminals of LV				
	winding shorted together. A test current				
	(i.e. $1/3^{rd}$ of rated current) was circulated				
	between shorted terminals and 2n and				
	measured a voltage across them. The				
	obtained values are tabulated as below:				
			11 000		
	Test current (Amps)	¥0	11.098		
	Measured Voltage (Volts)	22	1.130		
	Z ps = 3V (Ω/Phase)		0.305		
	I The Standard (O()				
	$Z ps = \underbrace{3V \times kVA}_{(\%)}$		4.07		
_	I x 10 (kV) <sup>2</sup>			Conforms	
9.	Oil leakage test: (As per cl.no.21.2.j of IS 1180 (Part1:			Conforms	
	2014)				
ì	The assembled transformer with all fittings	There should	No leakage		
	including bushings in position was tested	be no leakage	observed.		
	at a pressure at the top equivalent to the	at any point			
	head that was available at the base of the				
	tank for 8 hours.				
10.	Pressure test (routine test):				
	(As per cl.no.21.2.h of IS 1180 (Part 1:			Conforms	
	2014)	There should	No leakage		
	The transformer was tested at an air pressure of 35 kPa above atmosphere		observed.		
	pressure of 35 kPa above authosphere pressure maintained inside the tank for 10	at any point.	observed.		
	min.				
	1		L	L	

PREPARED BY







# **ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India. EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

: +91 (0265) 2638382 Fax : erda@erda.org E-mail





#### ULR-TC538919000014527F

Web

ULR-TC538919000014527F							
REPO	<b>DRT NO.:</b> RP-1920-004663		Sheet: 9	of 15			
DATI	: 02.05.2019						
Sr.		Requirement as	Obtained				
No.	Particulars of test and Cl. N	o. per specification		emarks			
11.	Pressure test (type test):		Co	nforms			
	(As per cl.no.21.3.d of IS 1180(Pa	rt 1):					
	2014)		_				
	> The transformer tank was subject	ted to					
	air pressure of 80 kPa for 30 mi						
	The permanent deflection of flat	· Control of the cont					
-1	were recorded, after pressure has released.	s been					
Ĭ	released.	0					
	Deflection Length of						
	Measured at Plate (mm)						
	HV side 665	Max. 5.0 mm	0.9 mm				
	LV side 665	Max. 5.0 mm	0.6 mm				
	Side A 250	Max. 5.0 mm	0.1 mm				
	Side B 250	Max. 5.0 mm	0.0 mm				
	> The transformer tank was subject vacuum of 250 mm of Mercury minutes. The permanent deflect flat plates were recorded, after value has been released.	for 30 tion of					
_	Deflection Length of						
-1	Measured at Plate (mm)						
	HV side 665	Max. 5.0 mm	0.8 mm				
	LV side 665	Max. 5.0 mm	0.7 mm				
	Side A 250	Max. 5.0 mm	0.2 mm				
	Side B 250	Max. 5.0 mm	0.1 mm				
	HV Side						
		There should be	No air				
		no air leakage at	leakage				
	Side A Side B	any point.	observed.				
	LV Side						
10	The state of the s						

PREPARED BY







# **ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382 E-mail : erda@erda.org Web : http://www.erda.org



# ULR-TC538919000014527F

**REPORT NO.:** RP-1920-004663 SHEET: 10 OF 15

**DATE** : 02.05.2019

Particulars of Tests & Cl. No.:
12) Determinations of sound levels [A- Weighted Sound Power Level Measurement]

[As per customer's request, testing procedure followed as per Cl. No. 21.4.a of IS 1180 (Part

1):2014 & Cl. No. 13 of IS 2026 (Part 10): 2009]

Condition of Transformer was energized at no load condition & excited at the rated

**transformer** voltage of sinusoidal waveform & rated frequency.

**Details of** Name: Sound level meter Make: Lutron

equipment used: Meter Type: Type 1 Serial No.: I.62852

Calibration Report No. & Date: V-181201-1-4 DTD. 01.12.2018

**TEST RESULTS:** 

	A-Weighted sound press	sure levels of the backgro	und noise
Sr. No.	Measurement Locations (Refer Sketch Below)	At the start of test dB(A)	At the end of test dB(A)
1	A	46.3	46.2
2	В	46.2	46.8
3	С	46.6	46.8
4	D	46.3	46.6
5	Е	46.7	46.0
6	F	46.9	46.7
7	G	46.8	46.5
8	Н	46.3	46.2
9	I	46.4	46.4
10	J	46.8	46.8
	Arithmetic Average $\overline{L_{ha4}}$	46.5	46.5

				The state of the s	
A-Weighted sound	pressure	levels at	energized	condition L	nΔi

Sr. No.	Measurement Locations (Refer Sketch Below) dB(A)	L <sub>pAi</sub> dB(A)
1	A	46.9
2	В	47.0
3	С	47.3
4	D	47.8
5	E	47.6
6	F	47.3
7	G	47.4
8	Н	47.7
9	I	47.2
10	J	47.3
	Arithmetic Average $\overline{L_{pA0}}$	47.4

PREPARED BY







(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

: +91 (0265) 2638382 Fax E-mail: erda@erda.org Web

: http://www.erda.org





**SHEET:** 11 OF 15

#### ULR-TC538919000014527F

**REPORT NO.:** RP-1920-004663

: 02.05.2019

**TEST PARAMETERS:** 

Measurement distance: 1 m,

Microphone Spacing: 1 m

Measurement made: Half of the height of the transformer tank

Method followed: Sound pressure measurement as per Cl. No. 11, 11.3 & Table 2 of

IS 2026 (Part 10): 2009.

Length of prescribed contour: 10.806 m

Transformer Tank Height: 0.645 m

Person present during sound level measurement: 3

A-Weighted sound pressure level ( $\overline{L_{pA0}}$ ):	47.4 dB(A)
Corrected average A-weighted sound pressure level $(\overline{L_{pA}})$ :	40.1 dB(A)
Calculated A- weighted sound power level (LwA):	49.5 dB(A)

REMARKS: 1] Guaranteed value of sound pressure level is considered as 48 dB(A) as mentioned in customer's letter.

2] Transformer conforms to the requirement of guaranteed value of Sound pressure level.

Н A H.V. Side Transformer Under Test B G L.V. Side C D Е

Sketch showing the locations of sound measurement

PREPARED BY







# **ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India. EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

: +91 (0265) 2638382 Fax E-mail : erda@erda.org Web : http://www.erda.org





# ULR-TC538919000014527F

SHEET No. 12 of 15

REPO	RT NO.: RP-1920-004663		Date: 02.05.2019	
Sr. No.	Particulars of test and clause no.	Requirement as per specification.	Obtained value	Remarks
13	Measurement of the Harmonics of the Noload current (As per customer's request testing procedure followed as per cl. no. 10.6 of IS 2026 (Part 1):2011)	The harmonics of the no-load current in the three phases shall be measured and magnitude of the harmonics shall be expressed as a percentage of the fundamental component.	harmonics components & individual voltage	
Prepa	ared by:		Checked by:	







# **ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382 E-mail : erda@erda.org

Web : http://www.erda.org





ULR-TC538919000014527F

SHEET No. 13 of 15

REPORT NO.: RP-1920-004663 Date: 02.05.2019

**TABLE-1**: Harmonics in voltage and current (as a percentage of fundamental)

	Harmonic order	Current I <sub>R</sub> in %	Current I <sub>R</sub> in Amps	Voltage V <sub>RY</sub> in %	Current I <sub>Y</sub> in %	Current I <sub>Y</sub> in Amps	Voltage V <sub>YB</sub> in %	Current I <sub>B</sub> in %	Current $I_B$ in Amps	Voltage V <sub>BR</sub> in %
	1	100.00	0.19	100.00	100.00	0.16	100.00	100.00	0.20	100.00
	2	0.52	0.00	0.03	0.67	0.00	0.01	1.05	0.00	0.04
4	3	10.58	0.02	0.25	13.41	0.02	0.27	3.77	0.01	0.43
ĺ	4	0.18	0.00	0.02	0.40	0.00	0.04	0.49	0.00	0.02
	5	24.44	0.05	2.02	24.82	0.04	1.85	22.22	0.04	2.08
	6	0.17	0.00	0.02	0.05	0.00	0.04	0.15	0.00	0.02
	7	5.70	0.01	0.48	5.57	0.01	0.48	5.06	0.01	0.57
	8	0.06	0.00	0.01	0.07	0.00	0.02	0.03	0.00	0.02
	9	0.15	0.00	0.09	0.51	0.00	0.14	0.54	0.00	0.24
	10	0.05	0.00	0.01	0.02	0.00	0.02	0.05	0.00	0.00
	11	0.65	0.00	0.12	1.02	0.00	0.10	0.82	0.00	0.09
	12	0.01	0.00	0.01	0.06	0.00	0.01	0.04	0.00	0.02
1	13	0.15	0.00	0.04	0.30	0.00	0.05	0.20	0.00	0.09
١	14	0.05	0.00	0.01	0.04	0.00	0.01	0.04	0.00	0.02
1	15	0.13	0.00	0.04	0.15	0.00	0.04	0.01	0.00	0.10
	16	0.03	0.00	0.02	0.10	0.00	0.02	0.03	0.00	0.01
	17	0.31	0.00	0.10	0.53	0.00	0.11	0.31	0.00	0.07
	18	0.05	0.00	0.01	0.07	0.00	0.02	0.02	0.00	0.01
	19	0.27	0.00	0.07	0.54	0.00	0.18	0.24	0.00	0.05
	20	0.03	0.00	0.01	0.10	0.00	0.02	0.04	0.00	0.02
	21	0.14	0.00	0.05	0.16	0.00	0.12	0.09	0.00	0.04
	22	0.03	0.00	0.01	0.04	0.00	0.01	0.09	0.00	0.02
	23	0.14	0.00	0.03	0.29	0.00	0.05	0.12	0.00	0.04
	24	0.04	0.00	0.02	0.06	0.00	0.03	0.03	0.00	0.01
	25	0.04	0.00	0.01	0.07	0.00	0.02	0.07	0.00	0.00
	THD %	27.26		2.11	28.80		1.96	23.15		2.22
	Parameter	0.20		432.20	0.17		436.60	0.21	-	437.40
	measured	Α		V	Α		V	Α		V

Prepared by

Checked by





(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33 Fax : +91 (0265) 2638382

E-mail: erda@erda.org

: http://www.erda.org Web





# ULR-TC538919000014527F

_	20011-12010-0020	102283130000	CONTROL MARKET CONTROL TO THE				
		ORT NO.: RP-192				Sheet: 1	.4 of 15
	Sr. No.	**************************************	lars of test and	I Cl. No.	Requirement as per specification	Obtained Value	Remarks
	14.	applied to the I winding termina exciting current 112.5 % of rate Rated full load Amps	of IS 1180 (Par of test: of voltage at rate L.V. winding ter ols were kept op of was recorded d voltage.		8 9		Conforms
		% of rated Voltage	Test voltage (Volts)	No load current	Mary 2.0.0/	0.570.0/	
	9	100 %	435.46	192.67 mA	Max. 3.0 %	0.578 %	
		112.5 %	487.16	402.05 mA	Max. 6.0 %	1.206 %	
	a a	Tra measurement o was dismantled and thickness	f total area of th and various dim were measured e core. Number	opened for the core nensions of width to calculate the of turns of L.V.			e _
		Stacking factor customer) Total no. of turn	: <b>0.97</b> (As specins of L.V winding of L.V winding : 2	: <b>5345.57</b> mm <sup>2</sup> fied by : <b>152</b> per phase <b>250 V</b> per phase			- 26 2 - 26
			calculated with - ge and frequency nd frequency.				-
	٦ ×	Flux density =	(4.44 x Freq.(	tage per phase  Hz) x Turns of Core)	Max. 1.90 Tesla	1.61 Tesla	

PREPARED BY







# **ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382 E-mail : erda@erda.org

Web : http://www.erda.org





#### ULR-TC538919000014527F

**REPORT NO.:** RP-1920-004663


**DATE** : 02.05.2019

**Sheet:** 15 of 15

# **PHOTOGRAPHS OF TEST SAMPLE**























Stacked core lyep onco	Steel	
CORE DIA	84	
WINDOW HEIGHT	384	
LEG CENTRE	205	
FLUX DENSITY	1.47	
OVER FLUX DENSITY	1.65	
L.V PHASE VOLTAGE	250 V	
LV TURNS PER PHASE	152	
RATED FREQUENCY.	50 HZ	<u> </u>
STACKING FACTOR	0.97	

Stack onthickness in 25.1 2x6.1 2x6.1 2x2.7 2x2.7 2x2.7 2x1.7 2x1.7 2x1.7 2x1.7 2x1.7		_			•								*
Width (amination)   80   75   75   70   65   60   55   50   45   40   20   20	Area in cm2	1	20.08	9.15	6.02	4.29	3.24	2.53	2.00	1.53	1.12	1.32	9.0
	Stack	こことこれのの	25.1	2x6.1	2x4.3	2x3.3	2x2.7	2×2.3	2x2	2×1.7	2x1.4	2x2.2	2×1.5
Step 1 2 2 1 10 1 10 1 11 1 1 1 1 1 1 1 1 1	Width	<u>Lamination</u>	80	75	70	65	. 09	55	50	45	40	30	20
	Step		-	2	3	4	5	9	7	∞;	6	10	11



51.88 cm^2 TOTAL GROSS CORE AREA = 250 × 10000

× 51.88

0.97

152

×

50

4.44 ×

11

flux density at 100% voltage

11

Tesla 1.47 281.2 × 10000 152 × 50 = 1.65 Tesla × 4.44 11 flux density at 112% voltage

84

51.88

×

0.97



KVA 11/0.433 KV DIST. TRANSFORMER ENERGY EFFICIENCY LEVEL-2 CORE DETAILS DRAWING 25





920-004663 erified dimensions are marked with 1\* /enification of this drawing by ERDA is erifled by Data:...