



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382




E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT

SHEET NO. : 1 of 15

NAME & ADDRESS OF CUSTOMER : M/s. Rajasthan Powergen Transformer Pvt. Ltd. Khasra No. 911-914, Karola-Bhinmal Road, Karola, Sanchore, Rajasthan-343041(India)	TEST REPORT NO. : RP-1819-026025 DATE : 01/10/2018	
	CUSTOMER REF. NO. : NIL DATED : 27/09/2018	
	DATE OF SAMPLE RECEIPT	DATE OF TESTING
	27/09/2018	01/10/2018
SAMPLE DESCRIPTION : DISTRIBUTION TRANSFORMER NON-SEALED TYPE ENERGY EFFICIENCY LEVEL : 3 RATING : 315 kVA RATED VOLTS : 11000/433 V RATED CURRENT : 16.53/420 A NO. OF PHASE : 03 TYPE OF COOLING : ONAN FREQUENCY : 50 Hz % IMPEDANCE : 4.5% VECTOR GROUP : Dyn 11 B.I.L. : H. V. : 28kVrms/75 kVp L. V. : 3 kVrms/----	SAMPLE IDENTIFICATION : SR. NO. : RPTPL-001 YEAR OF MFG. : 2018 MFG. BY : M/s. Rajasthan Powergen Transformer Pvt. Ltd. ERDA Sample Code No.: ERDA-00278711	
TEST DETAIL : Lightning Impulse Test with Chopped on the Tail on all the three phases of HV Terminals at 75 kVp. ENCLOSURE : DRG. NO.: 1) RPTPL-RP-315KVA-01/02-2018 2) RPTPL-RP-315KVA-02/02-2018 3) RPTPL-OL-315KVA-02-2018 TEST WITNESSED BY: ----	TEST SPECIFICATION : As per IS:1180 (Part-I)-2014, Cl.No. 21.3.a Amendment No.1 & 2 (Test Procedure was Followed as per IS : 2026-(Part-III)-2009, Cl. No. 14)	
REMARKS : From the observation of enclosed oscillographic records, it is concluded that the transformer conforms to the requirements of the above mentioned standard with respect to the test carried out.		
 PREPARED BY	 CHECKED BY	 A. S. KHOPKAR APPROVED BY
Note : 1. This report relates only to the particular sample received in good condition for testing at ERDA, VADODARA. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from Director, ERDA. 4. Only the tests asked for by the customer have been carried out. 5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be constructed as where the cause has arisen Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.		

TC 2629265



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO. : RP-1819-026025
DATE : 01/10/2018

SHEET NO.: 2 of 15

Waveform	Comment	Ut / kVp	T1 / μ s	T2 / μ s	Tc / μ s
1U PHASE(TAP NO.: 3)					
1	LI RW	-46.177	1.363	53.266	
2	100% LI FW	-74.590	1.359	52.530	
3	LI CRW	-52.052	1.422		3.176
4	110% LI CFW	-81.436	1.371		3.651
5	110% LI CFW	-81.298	1.369		3.213
6	100% LI FW	-75.697	1.361	52.897	
7	100% LI FW	-75.362	1.358	52.796	
1V PHASE(TAP NO.: 1)					
8	LI RW	-47.880	1.362	54.016	
9	100% LI FW	-75.541	1.357	53.670	
10	LI CRW	-51.551	1.417		2.805
11	110% LI CFW	-82.826	1.370		3.498
12	110% LI CFW	-82.611	1.366		2.884
13	100% LI FW	-76.095	1.360	53.640	
14	100% LI FW	-75.457	1.362	53.643	
1W PHASE(TAP NO.: 7)					
15	LI RW	-45.705	1.408	52.099	
16	100% LI FW	-74.643	1.404	51.740	
17	LI CRW	-50.281	1.455		3.239
18	110% LI CFW	-81.005	1.411		3.724
19	110% LI CFW	-81.081	1.413		3.527
20	100% LI FW	-74.926	1.404	51.789	
21	100% LI FW	-73.628	1.404	51.587	

TC 2629157

PREPARED BY



CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO. : RP-1819-026025
DATE : 01/10/2018

SHEET NO.: 3 of 15





Fig.: 1
 $U_p = -46.18 \text{ kV}$
 $T_1 = 1.36 \text{ } \mu\text{s}$
 $T_2 = 53.27 \text{ } \mu\text{s}$
 $T_c = \text{ } \mu\text{s}$



Comment: LI RW





Fig.: 2
 $U_p = -74.59 \text{ kV}$
 $T_1 = 1.36 \text{ } \mu\text{s}$
 $T_2 = 52.53 \text{ } \mu\text{s}$
 $T_c = \text{ } \mu\text{s}$



Comment: 100% LI FW

TC 2629158

PREPARED BY



CHECKED BY



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO. : RP-1819-026025
DATE : 01/10/2018

SHEET NO.: 4 of 15





Fig.: 3

$U_p = -52.05 \text{ kV}$

$T_1 = 1.42 \text{ } \mu\text{s}$

$T_2 = \text{ } \mu\text{s}$

$T_c = 3.18 \text{ } \mu\text{s}$



Comment: LI CRW





Fig.: 4

$U_p = -81.44 \text{ kV}$

$T_1 = 1.37 \text{ } \mu\text{s}$

$T_2 = \text{ } \mu\text{s}$

$T_c = 3.65 \text{ } \mu\text{s}$



Comment: 110% LI CFW

CHECKED BY

TC 2629159

PREPARED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO. : RP-1819-026025
DATE : 01/10/2018

SHEET NO.: 5 of 15





Fig.: 5
 $U_p = -81.30 \text{ kV}$
 $T_1 = 1.37 \text{ } \mu\text{s}$
 $T_2 = \text{ } \mu\text{s}$
 $T_c = 3.21 \text{ } \mu\text{s}$



Comment: 110% LI CFW





Fig.: 6
 $U_p = -75.70 \text{ kV}$
 $T_1 = 1.36 \text{ } \mu\text{s}$
 $T_2 = 52.90 \text{ } \mu\text{s}$
 $T_c = \text{ } \mu\text{s}$



Comment: 100% LI FW

TC 2629160

PREPARED BY



CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO. : RP-1819-026025
DATE : 01/10/2018

SHEET NO.: 6 of 15





Fig.: 7

$U_p = -75.36 \text{ kV}$
 $T_1 = 1.36 \mu\text{s}$
 $T_2 = 52.80 \mu\text{s}$
 $T_c = \mu\text{s}$



Comment: 100% LI FW





Fig.: 8

$U_p = -47.88 \text{ kV}$
 $T_1 = 1.36 \mu\text{s}$
 $T_2 = 54.02 \mu\text{s}$
 $T_c = \mu\text{s}$



Comment: LI RW

PREPARED BY



CHECKED BY

TC 2629161



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO. : RP-1819-026025
DATE : 01/10/2018

SHEET NO.: 7 of 15





Fig.: 9

$U_p = -75.54 \text{ kV}$
 $T_1 = 1.36 \text{ } \mu\text{s}$
 $T_2 = 53.67 \text{ } \mu\text{s}$
 $T_c = \text{ } \mu\text{s}$



Comment: 100% LI FW





Fig.: 10

$U_p = -51.55 \text{ kV}$
 $T_1 = 1.42 \text{ } \mu\text{s}$
 $T_2 = \text{ } \mu\text{s}$
 $T_c = 2.81 \text{ } \mu\text{s}$



Comment: LI CRW

TC 2629162

PREPARED BY



CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO. : RP-1819-026025
DATE : 01/10/2018

SHEET NO.: 8 of 15





Fig.: 11

$U_p = -82.83 \text{ kV}$

$T_1 = 1.37 \text{ } \mu\text{s}$

$T_2 = \text{ } \mu\text{s}$

$T_c = 3.50 \text{ } \mu\text{s}$



Comment: 110% LI CFW





Fig.: 12

$U_p = -82.61 \text{ kV}$

$T_1 = 1.37 \text{ } \mu\text{s}$

$T_2 = \text{ } \mu\text{s}$

$T_c = 2.88 \text{ } \mu\text{s}$



Comment: 110% LI CFW

CHECKED BY

PREPARED BY



TC 2629163



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



Certificate No. : TC-5389

TEST REPORT NO. : RP-1819-026025
DATE : 01/10/2018

SHEET NO.: 9 of 15





Fig.: 13

$U_p = -76.09 \text{ kV}$

$T_1 = 1.36 \text{ µs}$

$T_2 = 53.64 \text{ µs}$

$T_c = \text{µs}$



Comment: 100% LI FW





Fig.: 14

$U_p = -75.46 \text{ kV}$

$T_1 = 1.36 \text{ µs}$

$T_2 = 53.64 \text{ µs}$

$T_c = \text{µs}$



Comment: 100% LI FW

TC 2629164

PREPARED BY



CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO. : RP-1819-026025
DATE : 01/10/2018

SHEET NO.: 10 of 15





Fig.: 15
 $U_p = -45.70 \text{ kV}$
 $T_1 = 1.41 \mu\text{s}$
 $T_2 = 52.10 \mu\text{s}$
 $T_c = \mu\text{s}$



Comment: LI RW





Fig.: 16
 $U_p = -74.64 \text{ kV}$
 $T_1 = 1.40 \mu\text{s}$
 $T_2 = 51.74 \mu\text{s}$
 $T_c = \mu\text{s}$



Comment: 100% LI FW

TC 2629165

PREPARED BY



CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO. : RP-1819-026025
DATE : 01/10/2018

SHEET NO.: 11 of 15





Fig.: 17
 $U_p = -50.28 \text{ kV}$
 $T_1 = 1.45 \text{ } \mu\text{s}$
 $T_2 = \text{ } \mu\text{s}$
 $T_c = 3.24 \text{ } \mu\text{s}$



Comment: LI CRW





Fig.: 18
 $U_p = -81.01 \text{ kV}$
 $T_1 = 1.41 \text{ } \mu\text{s}$
 $T_2 = \text{ } \mu\text{s}$
 $T_c = 3.72 \text{ } \mu\text{s}$



Comment: 110% LI CFW

TC 2629166

PREPARED BY



CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO. : RP-1819-026025
DATE : 01/10/2018

SHEET NO.: 12 of 15





Fig.: 19

$U_p = -81.08 \text{ kV}$

$T_1 = 1.41 \text{ } \mu\text{s}$

$T_2 = \text{ } \mu\text{s}$

$T_c = 3.53 \text{ } \mu\text{s}$



Comment: 110% LI CFW





Fig.: 20

$U_p = -74.93 \text{ kV}$

$T_1 = 1.40 \text{ } \mu\text{s}$

$T_2 = 51.79 \text{ } \mu\text{s}$

$T_c = \text{ } \mu\text{s}$



Comment: 100% LI FW

TC 2629167

PREPARED BY



CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO. : RP-1819-026025
DATE : 01/10/2018

SHEET NO.: 13 of 15



Comment: 100% LI FW

TC 2629168

PREPARED BY



CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



TEST REPORT No.: RP-1819-026025

SHEET No.: 14 OF 15

DATE : 01/10/2018

PHOTOGRAPH OF TEST SAMPLE



PREPARED BY



CHECKED BY

TC 2629169



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT No.: RP-1819-026025

SHEET No.: 15 OF 15

DATE : 01/10/2018

PHOTOGRAPH OF TERMINAL MARKING AND RATING PLATE

DISTRIBUTION TRANSFORMER

**RAJASTHAN POWERGEN
TRANSFORMER PVT. LTD.**

Karola-Bhinmal Road, Karola, Sanchole-343 041,
Dist - Rajasthan INDIA

3 PHASE TRANSFORMER

STANDARD	IS:1180 (2014)		ENERGY EFFICIENCY LEVEL	<input type="checkbox"/> 3
KVA	<input type="checkbox"/> 315		MAX. TOTAL LOSSES	
VOLTS AT NO LOAD	HV	<input type="checkbox"/> 11000	AT 50% RATED LOAD W	<input type="checkbox"/> 955
	LV	<input type="checkbox"/> 433	MAX TOTAL LOSSES	
BIL	HV	<input type="checkbox"/> 7500/20	AT 100% RATED LOAD W	<input type="checkbox"/> 2750
	LV	<input type="checkbox"/> 7300	TYPE OF COOLING	<input type="checkbox"/> ONAN
AMPERES	HV	<input type="checkbox"/> 1653	TEMP RISE OIL DEG °C	<input type="checkbox"/> 40
	LV	<input type="checkbox"/> 420	TEMP RISE WDG DEG °C	<input type="checkbox"/> 25
FREQUENCY	<input type="checkbox"/> 50 Hz		MASS OF OIL	KGS <input type="checkbox"/> 410
VECTOR GROUP REF	<input type="checkbox"/> YNd11		TOTAL MASS	KGS <input type="checkbox"/> 230
IMPEDANCE VOLT %	<input type="checkbox"/> 4.5%		VOL. OF OIL	L <input type="checkbox"/> 500
TAPPING	<input type="checkbox"/> -		MONTH & YEAR OF MFG.	<input type="checkbox"/> SEP 2018
FOR HV VARIATION			SERIAL NO.	<input type="checkbox"/> KMP-01
IN <input type="checkbox"/> 25 STEP FROM <input type="checkbox"/> 0 TO <input type="checkbox"/> 10 %				
CUSTOMER ORDER NO.				

MADE IN INDIA

OFF CIRCUIT TAP CHANGER		NO LOAD VOLTAGE	
SWITCH POSITION	CONNECTION	HV	LV
1	1-7	11000	433
2	7-2	10500	433
3	2-8	10000	433
4	8-3	9500	433
5	3-9	9000	433
6	9-4	8500	433
7	4-10	8000	433

PREPARED BY



CHECKED BY

TC 2629170

DISTRIBUTION TRANSFORMER

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
RAJASTHAN.(INDIA)

PHASE TRANSFORMER

STANDARD	<input type="text" value="IS:1180 (2014)"/>	ENERGY EFFICIENCY LEVEL	<input type="text" value="3"/>
KVA	<input type="text" value="315"/>	MAX. TOTAL LOSSES	
VOLTS AT NO LOAD	HV <input type="text" value="11000"/> LV <input type="text" value="433"/>	AT 50% RATED LOAD, W	<input type="text" value="955"/>
BIL	HV <input type="text" value="75kvp/28kvrms"/> LV <input type="text" value="/3kvrms"/>	MAX. TOTAL LOSSES	<input type="text" value="2750"/>
AMPERES	HV <input type="text" value="16.53"/> LV <input type="text" value="420"/>	AT 100% RATED LOAD W	<input type="text" value="2750"/>
FREQUENCY	<input type="text" value="50 Hz"/>	TYPE OF COOLING	<input type="text" value="ONAN"/>
VECTOR GROUP REF.	<input type="text" value="Dyn-11"/>	TEMP RISE OIL DEG C	<input type="text" value="40"/>
IMPEDANCE VOLT %	<input type="text" value="4.5%"/>	TEMP RISE WDG DEG C	<input type="text" value="45"/>
TAPPING	<input type="text" value="-"/>	MASS OF OIL KGS	<input type="text" value="410"/>
FOR HV VARIATION		TOTAL MASS KGS	<input type="text" value="2230"/>
IN <input type="text" value="2.5"/> STEP FROM <input type="text" value="+5%"/> TO <input type="text" value="- 10"/> %		VOL. OF OIL L	<input type="text" value="500"/>
CUSTOMER	<input type="text" value="-"/>	MONTH & YEAR OF MFG.	<input type="text" value="SEP-2018"/>
ORDER NO.	<input type="text" value="-"/>	SERIAL NO.	<input type="text" value="RPTPL-001"/>

MADE IN INDIA



SIZE: 105x105 mm HOLE CENTER: 95x95 mm

Test Report No. RP-7839-026025
 Date: 07/10/2018
 Product: 315 KVA XIMER
 Verified By: [Signature]
 Verification of this marking by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with *.



NOTE:
 * YEAR OF MANUFACTURE & MONTH OF MANUFACTURE WILL BE PUNCHED AT THE TIME OF DESPATCH

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
 KAROLA BHIMAL ROAD, KAROLA, SANCHORE-343041

DRN BY		RATING & TERMINAL MARKING PLATE FOR 315 KVA ,11/0.433 KV DISTRIBUTION TRANSFORMER .3 PHASE, EFFICIENCY LEVEL-3
CHD BY		
APPD BY		

REV. NO.	DATE SIGN	BRIEF DESCRIPTION	DRG. NO.	RPTPL-RP-315KVA-01/02-2018	REV. NO.
		01 of 02			

OFF CIRCUIT TAP CHANGER		NO LOAD VOLTAGE	
SWITCH POSITION	CONNECTION	HV	LV
1	6-7	11550	433
2	7-5	11275	433
3	5-8	11000	433
4	8-4	10725	433
5	4-9	10450	433
6	9-3	10175	433
7	3-10	9900	433



Test Report No. RP-315KVA-02/02-2018
 Date: 02/20/2018
 Product: 315 KVA XIMOR
 Verified By: [Signature]
 Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with E.



SIZE: 105x105 mm HOLE CENTER: 95x95 mm

NOTE:
 * YEAR OF MANUFACTURE & MONTH OF MANUFACTURE WILL BE PUNCHED AT THE TIME OF DESPATCH

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
 KAROLA BHIMAL ROAD, KAROLA, SANCHORE-343041

DRN BY		RATING & TERMINAL MARKING PLATE FOR 315 KVA ,11/0.433 KV DISTRIBUTION TRANSFORMER 3 PHASE , EFFICIENCY LEVEL-3
CHD BY		
APPD BY		

REV. NO.	DATE SIGN	BRIEF DESCRIPTION	DRG. NO.	RPTPL-RP-315KVA-02/02-2018	REV. NO.
1		02 of 02			



ELECTRICAL CLEARANCE IN AIR IN mm MIN	
CLEARANCE BETWEEN HV	LV
PHASE TO PHASE	255
PHASE TO EARTH	140

DIMENSIONS IN mm		L1	B1	H1	H2	CONSERVATOR TANK(INSIDE)
L	B	H	D1	L2	OVERALL	
1120	470	1080	1060	3300	1700	1250
				1950		660L

NOTE:

1. TOLERANCE ON WEIGHTS & DIMENSIONS +/- 10% * Not Provided During Testing


SR.NO.	DESCRIPTION	QTY.
23	BIMETALLIC CONNECTORS FOR HV & LV	7
22	COVER LIFTING EYES	2
21	OFF CIRCUIT TAP SWITCH	1
20	TANK REINFORCING ANGLE	2
19	AIR RELEASE PLUG	1
18	FILTER VALVE WITH PLUG (32 mm)	1
* 17	UNI-DIRECTIONAL FLAT ROLLERS	4
16	EXPLOSION VENT	1
* 15	METALLIC COVER FOR DRAIN VALVE	1
14	PULLING LUGS-Bt	4
13	COOLING RADIATORS-800 c/c X 230 W X 3 FINS	4
12	LV BUSHINGS	4
11	HV BUSHING WITH ARCHING HORNS	3
10	OIL LEVEL GAUGE WITH MARKINGS	1
9	UNDER BASE CHANNELS	2
* 8	SILICAGEL BREATHER - 1kg	1
7	THERMOMETER POCKET	1
6	CONSERVATOR WITH DRAIN PLUG	1
5	DRAIN VALVE WITH PLUG	1
4	OIL FILLING HOLE WITH CAP	1
3	LIFTING LUGS	4
2	EARTHING TERMINALS WITH LUGS	2
1	RATING & TERMINAL MARKING PLATE	1

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
KAROLA BHIMAL ROAD, KAROLA, SANCHORE-343041

OUTLINE DRAWING

315 KVA, 11/0.433 KV CU WOUND DISTIN. T/F.S.

RPTPL-OL-315KVA-02-2018



SR.NO.	WEIGHT CHART	FIGURES
1	CORE COIL ASSEMBLY	1450 KG
2	TANK WITH FITTINGS	370 KG
3	MASS OF OIL	410 KG
4	TOTAL MASS	2230 KG
5	OIL VOLUME	500 LTR
TANK SHEET THICKNESS		
SIDES		4.0 mm
TOP & BOTTOM		6.0 mm

TENDER NO.:

CUSTOMER:

DRN BY

APPRD BY

DATE

SCALE

E. E. L-3

26.09.2018

Test Report No. RP-1825-026025
Date: 27-10-2018
Product: 315 kVA XIMEX
Verified By: [Signature]
Verified at: [Signature]
This drawing is for reference only.
Dimensions are in mm unless otherwise specified.