



Certificate No.: TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT

TC538918000000614F

Sheet : 1 of 15

NAME AND ADDRESS OF CUSTOMER Rajasthan Powergen Transformer Pvt. Ltd. Khasra No. 911-914, Karola-Bhinmal Road, Karola, Sanchoe, Rajasthan 343041	REPORT NO.: RP-1819-026833 DATE : 10.10.2018	
	CUSTOMER REF. NO. Letter	DATE 27.09.2018
	DATE OF SAMPLE RECEIPT 27.09.2018	DATE OF TESTING 29.09.2018 to 04.10.2018
	SAMPLE IDENTIFICATION ERDA sample code number : ERDA-00278711 Manufacturer serial no.: RPTPL-001 Year of manufacture : 2018 Enclosed drawing numbers : 1) RPTPL-RP-315KVA-01/02-2018 01 of 02 2) RPTPL-RP-315KVA-02/02-2018 02 of 02 3) RPTPL-OL-315KVA-02-2018	
SAMPLE DESCRIPTION DISTRIBUTION TRANSFORMER (NON-SEALED TYPE) Manufactured by : RAJASTHAN POWERGEN TRANSFORMER PVT. LTD. Rating : 315 kVA Volts : 11000/433 V (at no-load) Current : 16.53/420 Amps Phases : 3/3 Vector group : Dyn11 Energy efficiency level :3 Further details as per sheet no.2 of 15	TEST SPECIFICATION As per sheet 3 of 15.	
TEST DETAILS As per sheet 3 of 15.		
TEST RESULTS : As per sheets from 4 of 15 to 14 of 15.		
ENCLOSURE: Photographs of test sample - As per sheet 15 of 15		
REMARKS : 1) The transformer conforms to the guaranteed requirement as per above mentioned test specification for above mentioned test nos. 2,5,6,7,11 to 17. 2) Criteria limit has not been specified for test nos. 1,3,4,8,9 & 10.		
PREPARED BY 	CHECKED BY 	APPROVED BY (Kapil J. Sharma)
Note : 1. This report relates only to the particular sample received for testing in good condition at E.R.D.A., Makarpura. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from Director , E.R.D.A. 4. Only the tests asked for by the customer have been carried out. 5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arisen. Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.		

TC 2636846





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC538918000000614F

REPORT NO.: RP-1819-026833

Sheet: 2 of 15

DATE : 10.10.2018

TECHNICAL SPECIFICATIONS OF TEST OBJECT ASSIGNED BY CUSTOMER

1.	Name of Manufacturer	RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
2.	Sr.No.	RPTPL-001
3.	kVA rating	315
4.	Rated Voltage H.V.(Volts)	11000
5.	Rated Voltage L.V.(Volts)	433
6.	Rated Current H.V.(Amp.)	16.53
7.	Rated Current L.V.(Amp.)	420
8.	Number of phases	3
9.	Energy Efficiency level	3
10.	Vector Group	Dyn11
11.	Winding Material	Copper
12.	Type of Cooling	ONAN
13.	Frequency (Hz)	50
14.	Guaranteed Percentage impedance (%)	4.5
15.	Total losses at 50 % load (Watts)	955
16.	Total losses at 100 % load (Watts)	2750
17.	Guaranteed temperature rise of oil/Winding	40/45°C
18.	Year of Manufacture	2018
19.	Standard no.	IS 1180 (PART-1) 2014 with amendment no. 1 & 2. & CBIP manual

PREPARED BY

CHECKED BY

TC 2645058



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC538918000000614F

REPORT NO.: RP-1819-026833

Sheet : 3 of 15

DATE : 10.10.2018

SR. NO.	TEST DETAILS	TEST SPECIFICATION
1.	Measurement of winding resistance.	As per cl.no.21.2.a of IS 1180 (Part 1):2014
2.	Measurement of voltage ratio and check of phase displacement	As per cl.no.21.2.b of IS 1180 (Part 1):2014
3.	Measurement of short-circuit impedance and load loss at 50 percent and 100 percent load.(At tap no.3)	As per cl.no.21.2.c of IS 1180 (Part 1):2014
4.	Measurement of no-load loss and current.	As per cl.no.21.2.d of IS 1180 (Part 1):2014
5.	Total losses at 50 % load	As per cl.no.7.8 of IS 1180 (Part 1):2014
6.	Total losses at 100 % load	As per cl.no.7.8 of IS 1180 (Part 1):2014
7.	No load current at 112.5 percent voltage	As per cl.no.21.4.c of IS 1180 (Part 1):2014
8.	Measurement of short-circuit impedance and load loss at 50 percent and 100 percent load. (At tap no.1)	As per cl.no.21.2.c of IS 1180 (Part 1):2014
9.	Measurement of short-circuit impedance and load loss at 50 percent and 100 percent load.(At tap no.7)	As per cl.no.21.2.c of IS 1180 (Part 1):2014
10.	Measurement of insulation resistance.	As per cl.no.21.2.e of IS 1180 (Part 1):2014
11.	Induced overvoltage withstand test.	As per cl.no.21.2.f of IS 1180 (Part 1):2014
12.	Separate-source voltage withstand test	As per cl.no.21.2.g of IS 1180 (Part 1):2014
13.	Temperature rise test	As per cl.no.21.3.b of IS 1180 (Part 1):2014
14.	Magnetic balance test	As per CBIP manual; Publication no.317-2013
15.	Oil leakage test	As per cl.no.21.2.j of IS 1180 (Part 1):2014
16.	Pressure test (routine test)	As per cl.no.21.2.h of IS 1180 (Part 1):2014
17.	Pressure test (type test)	As per cl.no.21.3.d of IS 1180 (Part 1):2014
 PREPARED BY		 CHECKED BY



TC 2636844



(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



TC538918000000614F

REPORT NO.: RP-1819-026833

Sheet : 4 OF 15

DATE : 10.10.2018

Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained Value	Remarks
1.	Measurement of winding resistance : (As per cl.no.21.2.a of IS 1180 (Part 1) : 2014) Average oil temperature: 28.5°C <div style="text-align: right;">HV Winding</div> Tap number:1 1U – 1V: -- 2.1432 Ω 1V – 1W: -- 2.1450 Ω 1U – 1W: -- 2.1438 Ω Average: -- 2.1440 Ω Tap number:2 1U – 1V: -- 2.0946 Ω 1V – 1W: -- 2.0850 Ω 1U – 1W: -- 2.0896 Ω Average: -- 2.0897 Ω Tap number:3 1U – 1V: -- 2.0486 Ω 1V – 1W: -- 2.0392 Ω 1U – 1W: -- 2.0468 Ω Average: -- 2.0449 Ω Tap number:4 1U – 1V: -- 1.9998 Ω 1V – 1W: -- 1.9941 Ω 1U – 1W: -- 1.9998 Ω Average: -- 1.9979 Ω Tap number:5 1U – 1V: -- 1.9532 Ω 1V – 1W: -- 1.9473 Ω 1U – 1W: -- 1.9535 Ω Average: -- 1.9513 Ω			---

PREPARED BY

CHECKED BY

TC 2636843



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org





TC538918000000614F

REPORT NO.: RP-1819-026833

Sheet : 5 OF 15

DATE : 10.10.2018

Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained Value	Remarks
	Tap number:6			
	1U - 1V:	--	1.9084 Ω	
	1V - 1W:	--	1.9014 Ω	
	1U - 1W:	--	1.9056 Ω	
	Average:	--	1.9051 Ω	
	Tap number:7			
	1U - 1V:	--	1.8627 Ω	
	1V - 1W:	--	1.8556 Ω	
	1U - 1W:	--	1.8658 Ω	
	Average:	--	1.8614 Ω	
	LV Winding			
	2u - 2v:	--	2.5006 m Ω	
	2v - 2w:	--	2.4424 m Ω	
	2u - 2w:	--	2.4678 m Ω	
	Average:	--	2.4703 m Ω	
<div> <div>  PREPARED BY </div> <div>  CHECKED BY </div> </div>				

TC 2636842





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC538918000000614F

REPORT NO.: RP-1819-026833

Sheet : 6 OF 15

DATE : 10.10.2018

Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained Value	Remarks
2.	Measurement of voltage ratio and check of phase displacement : (As per cl.no.21.2.b of IS 1180 (Part 1) : 2014) Measurement of voltage ratio Tap number:1 1U-1V and 2u-2n: 46.200 ($\pm 0.5\%$) 1V-1W and 2v-2n: 46.200 ($\pm 0.5\%$) 1W-1U and 2w-2n: 46.200 ($\pm 0.5\%$) Tap number:2 1U-1V and 2u-2n: 45.100 ($\pm 0.5\%$) 1V-1W and 2v-2n: 45.100 ($\pm 0.5\%$) 1W-1U and 2w-2n: 45.100 ($\pm 0.5\%$) Tap number:3 1U-1V and 2u-2n: 44.000 ($\pm 0.5\%$) 1V-1W and 2v-2n: 44.000 ($\pm 0.5\%$) 1W-1U and 2w-2n: 44.000 ($\pm 0.5\%$) Tap number:4 1U-1V and 2u-2n: 42.900 ($\pm 0.5\%$) 1V-1W and 2v-2n: 42.900 ($\pm 0.5\%$) 1W-1U and 2w-2n: 42.900 ($\pm 0.5\%$) Tap number:5 1U-1V and 2u-2n: 41.800 ($\pm 0.5\%$) 1V-1W and 2v-2n: 41.800 ($\pm 0.5\%$) 1W-1U and 2w-2n: 41.800 ($\pm 0.5\%$) Tap number:6 1U-1V and 2u-2n: 40.700 ($\pm 0.5\%$) 1V-1W and 2v-2n: 40.700 ($\pm 0.5\%$) 1W-1U and 2w-2n: 40.700 ($\pm 0.5\%$) Tap number:7 1U-1V and 2u-2n: 39.600 ($\pm 0.5\%$) 1V-1W and 2v-2n: 39.600 ($\pm 0.5\%$) 1W-1U and 2w-2n: 39.600 ($\pm 0.5\%$) Vector Group :	Dyn11	Dyn11	Conforms
PREPARED BY		CHECKED BY		

TC 2636841



[illegible]

TC 2636840



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**TC538918000000614F****REPORT NO.:** RP-1819-026833**Sheet :** 8 of 15**DATE** : 10.10.2018

Sr. No	Particulars of test and Cl. No.	Requirement as per specification	Obtained Value	Remarks
4.	Measurement of no-load loss and current : (As per cl.no.21.2.d of IS 1180 (Part 1) : 2014) Tested with average 433.02 volts (on LV side) Frequency : 49.990 Hz RMS voltage (Volts) No-load current (Amps) Measured no-load loss (Watts) Corrected no-load loss (Watts)	---	432.84 0.8587 428.80 428.97	---
5.	Total losses at 50 % load (Watts) : (As per cl.no.7.8 of IS 1180 (Part 1): 2014)	Max. 955	915.75	Conforms
6.	Total losses at 100 % load (Watts) : (As per cl.no.7.8 of IS 1180 (Part 1): 2014)	Max. 2750	2381.33	Conforms
7.	No load current at 112.5 percent voltage : (As per cl.no.21.4.c of IS 1180 (Part 1) : 2014) Test voltage of 112.5 percent of rated voltage at rated frequency was applied to the L.V. winding terminals and H.V. winding terminals were kept open circuited. No load current was recorded. Test voltage (Volts) No load current (Amps) No load current (%)	Max. 5.0	487.14 1.1770 0.28	Conforms

PREPARED BY**CHECKED BY**

TC 2636839





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC538918000000614F

REPORT NO.: RP-1819-026833

Sheet : 9 of 15

DATE : 10.10.2018

Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained Value	Remarks
8.	Measurement of short-circuit impedance and load loss at 50 percent and 100 percent load : (At tap number : 1) (As per cl.no.21.2.c of IS 1180 (Part 1) : 2014) At 50% load : Tested with 7.868 Amps (on HV side) Frequency : 49.995 Hz Average oil temperature : 31.8 °C <div style="text-align: right;"> Test current (Amps) Impedance voltage (Volts) Measured load loss (Watts) Impedance voltage (%) (Computed to 50% load) At 31.8 °C At 75 °C Load loss (Watts) (Computed to 50% load) At 31.8 °C At 75 °C </div> At 100% load : Tested with 15.7316 Amps (on HV side) Frequency : 50.004 Hz Average oil temperature : 31.8 °C <div style="text-align: right;"> Test current (Amps) Impedance voltage (Volts) Measured load loss (Watts) Impedance voltage (%) (Computed to 100% load) At 31.8 °C At 75 °C Load loss (Watts) (Computed to 100% load) At 31.8 °C At 75 °C </div>			---
			7.868	
			237.60	
			422.1	
			2.06	
		---	2.07	
			421.64	
		---	474.41	
			15.7316	
			475.88	
			1694.40	
			4.13	
		---	4.13	---
			1698.37	
		---	1904.46	---

PREPARED BY

CHECKED BY

TC 2645107



(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

EBDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



TC538918000000614F

REPORT NO.: RP-1819-026833

Sheet : 10 of 15

DATE : 10.10.2018

[illegible]

PREPARED BY

CHECKED BY

TC 2636837





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**TC538918000000614F****REPORT NO.:** RP-1819-026833**Sheet :** 11 OF 15**DATE :** 10.10.2018

Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained Value	Remarks
10.	Measurement of insulation resistance : (As per cl.no.21.2.e of IS 1180 (Part 1) : 2014) Average oil temperature : 32.0°C IR value measured between HV winding --- Earth at 2500 V DC LV winding --- Earth at 500 V DC HV winding --- LV winding at 2500 V DC	-- -- --	2.61 GΩ 1.439 GΩ 2.67 GΩ	---
11.	Induced overvoltage withstand test : (As per cl.no.21.2.f of IS 1180 (Part 1) : 2014) The test voltage of 866 Volts, 3 - phase was applied to the LV winding of the transformer. The supply frequency was maintained at 150 Hz. The test voltage was applied for 40 seconds.	Transformer shall withstand 866 volts at 150 Hz frequency for 40 seconds.	Withstood	Conforms
12.	Separate-source voltage withstand Test : (As per cl.no.21.2.g of IS 1180 (Part 1) : 2014) ➤ on HV winding: The test voltage of 28 kV ac, rms was applied between the HV winding and earth. The tank and LV winding were shorted together and earthed. The test voltage was applied for 60 seconds. ➤ on LV winding: The test voltage of 3 kV ac, rms was applied between the LV winding and earth. The tank and HV winding were shorted together and earthed. The test voltage was applied for 60 seconds.	Transformer shall withstand power frequency voltage of 28 kV for 60 seconds. Transformer shall withstand power frequency voltage of 3 kV for 60 seconds.	Withstood Withstood	Conforms

PREPARED BY

CHECKED BY

TC 263683





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**TC538918000000614F****REPORT NO.:** RP-1819-026833**Sheet :12 of 15****DATE** : 10.10.2018

Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained value	Remarks
13.	Temperature-rise test : (As per Cl.no.21.3.b of IS 1180 (Part 1) :2014) (At Tap No. 7) Before starting test, the dimensions of tank with radiators were measured & recorded. Size of tank : L-1120 mm,W-470 mm, H1-1080 mm, H2-1060 mm Size of fins: L-800 mm,W-230 mm No. of radiators-04 No. of fins per radiator-03 Total losses fed for temperature-rise test were 2516.55 Watts. (Measured no- load loss : 428.97 Watts & load loss at 75°C at tap no. 7: 2087.58 Watts) Measured losses were fed to the transformer (i.e. Supply was connected to HV winding and LV winding kept short-circuited) till steady state temperature-rise was attained. Top oil temperature was recorded hourly. After steady state condition, the losses were brought down in reference to the rated current one hour prior to shut down. At the shutdown, the hot windings resistance were measured and temperature-rise calculated. A) Top oil temperature-Rise : B) Winding Temperature Rise (Resistance method) 1) HV Winding : 2) LV Winding : C) Ambient temperature at shutdown : D)Time of Shutdown(HRS) :			Conforms
		Max. 40°C	28.6°C	
		Max. 45°C	35.8°C	
		Max. 45°C	30.7°C	
			29.0°C	
			01:30	

PREPARED BY

CHECKED BY

TC 2636935





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**TC538918000000614F****REPORT NO.:** RP-1819-026833**Sheet :** 13 of 15**DATE** : 10.10.2018

Sr. No.	Particulars of test and Cl. No.			Requirement as per specification	Obtained Value	Remarks		
14.	Magnetic balance test : (As per CBIP manual; Publication no.317 - 2013)					Conforms		
	Voltage Applied Between	Applied Voltage (Volts)	Measured Voltage Between					
	2u & 2n	100.10	2v & 2n				50 to 90 V	77.87
			2w & 2n					22.81
	2v & 2n	100.25	2u & 2n				30 to 70 V	50.88
			2w & 2n				30 to 70 V	49.29
	2w & 2n	100.00	2u & 2n					23.57
			2v & 2n				50 to 90 V	76.90
15.	Oil leakage test : (As per cl.no.21.2.j of IS 1180 (Part 1): 2014) The assembled transformer with all fittings including bushings in position was tested at a pressure at the top equivalent to the head that was available at the base of the tank for 8 hours.			There should be no leakage at any point.	No leakage observed.	Conforms		
16.	Pressure test (routine test) : (As per cl.no.21.2.h of IS 1180 (Part 1) : 2014) The transformer tank with bolted cover was tested at an air pressure of 35 kPa above atmosphere pressure maintained inside the tank for 10 min.			There should be no leakage at any point.	No leakage observed.	Conforms		
<div><div>PREPARED BY</div><div>CHECKED BY</div></div>								

TC 2645056



(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



TC538918000000614F

REPORT NO.: RP-1819-026833

Sheet : 14 of 15

DATE : 10.10.2018

Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained Value	Remarks																																																		
17.	<p>Pressure test (type test) : (As per cl.no.21.3.d of IS 1180 (Part 1): 2014)</p> <p>➤ The transformer tank was subjected to air pressure of 80 kPa for 30 minutes. The permanent deflection of flat plates were recorded, after pressure has been released.</p> <table border="0"> <tr> <td>Deflection Measured at</td><td>Length of plate (mm)</td><td></td><td></td><td></td></tr> <tr> <td>HV side</td><td>1120</td><td>Max. 6.5 mm</td><td>0.7 mm</td><td></td></tr> <tr> <td>LV side</td><td>1120</td><td>Max. 6.5 mm</td><td>0.4 mm</td><td></td></tr> <tr> <td>Side A</td><td>470</td><td>Max. 5.0 mm</td><td>0.1 mm</td><td></td></tr> <tr> <td>Side B</td><td>470</td><td>Max. 5.0 mm</td><td>0.0 mm</td><td></td></tr> </table> <p>➤ The transformer tank was subjected to vacuum of 500 mm of Mercury for 30 minutes. The permanent deflection of flat plates were recorded, after vacuum has been released.</p> <table border="0"> <tr> <td>Deflection Measured at</td><td>Length of plate (mm)</td><td></td><td></td><td></td></tr> <tr> <td>HV side</td><td>1120</td><td>Max. 6.5 mm</td><td>0.4 mm</td><td></td></tr> <tr> <td>LV side</td><td>1120</td><td>Max. 6.5 mm</td><td>0.1 mm</td><td></td></tr> <tr> <td>Side A</td><td>470</td><td>Max. 5.0 mm</td><td>0.0 mm</td><td></td></tr> <tr> <td>Side B</td><td>470</td><td>Max. 5.0 mm</td><td>0.0 mm</td><td></td></tr> </table> <div style="border: 1px solid black; padding: 10px; margin-top: 10px; text-align: center;"> <p>HV SIDE</p> <p>SIDE A SIDE B</p> <p>LV SIDE</p> </div>	Deflection Measured at	Length of plate (mm)				HV side	1120	Max. 6.5 mm	0.7 mm		LV side	1120	Max. 6.5 mm	0.4 mm		Side A	470	Max. 5.0 mm	0.1 mm		Side B	470	Max. 5.0 mm	0.0 mm		Deflection Measured at	Length of plate (mm)				HV side	1120	Max. 6.5 mm	0.4 mm		LV side	1120	Max. 6.5 mm	0.1 mm		Side A	470	Max. 5.0 mm	0.0 mm		Side B	470	Max. 5.0 mm	0.0 mm				
Deflection Measured at	Length of plate (mm)																																																					
HV side	1120	Max. 6.5 mm	0.7 mm																																																			
LV side	1120	Max. 6.5 mm	0.4 mm																																																			
Side A	470	Max. 5.0 mm	0.1 mm																																																			
Side B	470	Max. 5.0 mm	0.0 mm																																																			
Deflection Measured at	Length of plate (mm)																																																					
HV side	1120	Max. 6.5 mm	0.4 mm																																																			
LV side	1120	Max. 6.5 mm	0.1 mm																																																			
Side A	470	Max. 5.0 mm	0.0 mm																																																			
Side B	470	Max. 5.0 mm	0.0 mm																																																			
		There should be no air leakage at any point.	No air leakage observed.	Conforms																																																		

PREPARED BY

CHECKED BY

TC 2636833



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC538918000000614F

REPORT NO.: RP-1819-026833

Sheet : 15 of 15

DATE : 10.10.2018

PHOTOGRAPHS OF TEST SAMPLE

DISTRIBUTION TRANSFORMER
RAJASTHAN POWERGEN
TRANSFORMER PVT. LTD.
Nandip-Surimal Road, Karpur, Sandhwa-383 041,
Dist. Rajasthan INDIA


PHASE TRANSFORMER
STANDARD IS: 1100 (2014)
KVA 1000
VOLTS AT NO LOAD HV 11KV LV 440V
AMPERES HV 5.25 LV 1365
FREQUENCY 50 HZ
VECTOR GROUP BY
IMPEDANCE VOLT % 4.5
TAPPING 2+2
FOR HYDRATION
IN STEP FROM TO
CUSTOMER ORDER NO.

ENERGY EFFICIENCY LEVEL
MAX. TOTAL LOSSES AT 50% RATED LOAD W
MAX. TOTAL LOSSES AT 100% RATED LOAD W
TYPE OF COOLING
TEMP. RISE OIL DEG. C
TEMP. RISE WDG DEG. C
MASS OF OIL KGS
TOTAL MASS KGS
VOL. OF OIL L
MONTH & YEAR OF MFG
SERIAL NO.

MADE IN INDIA

OFF CIRCUIT TAP CHANGER		NO LOAD VOLTAGE	
SWITCH POSITION	CONNECTION	HV	LV
1	1-2	11KV	440V
2	2-3	11KV	440V
3	3-4	11KV	440V
4	4-5	11KV	440V
5	5-6	11KV	440V
6	6-7	11KV	440V
7	7-8	11KV	440V
8	8-9	11KV	440V
9	9-10	11KV	440V

Diagram showing tap changer connections and a triangle diagram with 10, 20, 30, 40, 50, 60, 70, 80, 90, 100.







PREPARED BY

CHECKED BY

TC 2636833




 DISTRIBUTION TRANSFORMER 			
RAJASTHAN POWERGEN TRANSFORMER PVT. LTD. RAJASTHAN.(INDIA)			
<div style="display: flex; justify-content: space-between;"> <div> 3 PHASE TRANSFORMER STANDARD IS:1180 (2014) KVA 315 VOLTS AT HV 11000 NO LOAD LV 433 BIL HV 75kvp/28kvrms LV -/3kvrms AMPERES HV 16.53 LV 420 FREQUENCY 50 Hz VECTOR GROUP REF. Dyn-11 IMPEDANCE VOLT % 4.5% TAPPING - FOR HV VARIATION IN 2.5 STEP FROM +5% TO - 10 % CUSTOMER - ORDER NO. - </div> <div> ENERGY EFFICIENCY LEVEL 3 MAX. TOTAL LOSSES AT 50% RATED LOAD W 955 MAX. TOTAL LOSSES AT 100% RATED LOAD W 2750 TYPE OF COOLING ONAN TEMP RISE OIL DEG C 40 TEMP RISE WDG DEG C 45 MASS OF OIL KGS 410 TOTAL MASS KGS 2230 VOL. OF OIL L 500 MONTH & YEAR OF MFG. SEP-2018 SERIAL NO. RPTPL-001 </div> </div>			
 MADE IN INDIA 			
95		105	

SIZE: 105x105 mm HOLE CENTER: 95x95 mm



NOTE:
 * YEAR OF MANUFACTURE &
 MONTH OF MANUFACTURE
 WILL BE PUNCHED AT THE TIME OF DESPATCH

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
 KAROLA BHIMAL ROAD, KAROLA, SANCHORE-343041

REV. NO.	DATE SIGN	BRIEF DESCRIPTION	DRN BY	RATING & TERMINAL MARKING PLATE FOR 315 KVA, 11/0.433 KV DISTRIBUTION TRANSFORMER- 3 PHASE, EFFICIENCY LEVEL-3	REV. NO.
			CHD BY		
			APPD BY		
01 of 02			 DRG. NO. RPTPL-RP-315KVA-01/02-2018		

No. of sheets: 01
 Date: 10-10-18
 315 KVA 330V
 100%
 This drawing is prepared by ERDA is
 subject to relevant dimensional checks only
 All dimensions are marked with 1st

OFF CIRCUIT TAP CHANGER		NO LOAD VOLTAGE	
SWITCH POSITION	CONNECTION	HV	LV
1	6-7	11550	433
2	7-5	11275	433
3	5-8	11000	433
4	8-4	10725	433
5	4-9	10450	433
6	9-3	10175	433
7	3-10	9900	433



SIZE: 105x105 mm HOLE CENTER: 95x95 mm

NOTE:

* YEAR OF MANUFACTURE &
MONTH OF MANUFACTURE
WILL BE PUNCHED AT THE TIME OF DESPATCH

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.

KAROLA BHIMAL ROAD, KAROLA, SANCHORE-343041

DRN BY

RATING & TERMINAL MARKING PLATE FOR

CHD BY

315 KVA, 11/0.433 KV DISTRIBUTION TRANSFORMER

APPD BY

3 PHASE, EFFICIENCY LEVEL-3

REV.
NO.

DATE
SIGN

BRIEF
DESCRIPTION



DRG. NO.

RPTPL-RP-315KVA-02/02-2018

REV. NO.

ELECTRICAL CLEARANCE IN AIR IN mm MIN			
CLEARANCE BETWEEN	HV	H1	H2
PHASE TO PHASE	255	75	
PHASE TO EARTH	140	40	

DIMENSIONS IN mm			
TANK(INSIDE)	L1	B1	H1
OVERALL	L	B	H
	1700	1250	1950


NOTE:

1. TOLERANCE ON WEIGHTS & DIMENSIONS +/- 10%
- * Not Provided During Testing

SR.NO.	DESCRIPTION	QTY.
23	BIMETALLIC CONNECTORS FOR HV & LV	7
22	COVER LIFTING EYES	2
21	OFF CIRCUIT TAP SWITCH	1
20	TANK REINFORCING ANGLE	2
19	AIR RELEASE PLUG	1
18	FILTER VALVE WITH PLUG (32 mm)	1
* 17	UNI-DIRECTIONAL FLAT ROLLERS	4
16	EXPLOSION VENT	1
* 15	METALLIC COVER FOR DRAIN VALVE	1
14	PULLING LUGS-8t	4
13	COOLING RADIATORS-800 c/c X 230 W X 3 FINS	4
12	LV BUSHINGS	4
11	HV BUSHING WITH ARCHING HORNS	3
10	OIL LEVEL GAUGE WITH MARKINGS	1
9	UNDER BASE CHANNELS	2
* 8	SILICAGEL BREATHER - 1kg	1
7	THERMOMETER POCKET	1
6	CONSERVATOR WITH DRAIN PLUG	1
5	DRAIN VALVE WITH PLUG	1
4	OIL FILLING HOLE WITH CAP	1
3	LIFTING LUGS	4
2	EARTHING TERMINALS WITH LUGS	2
1	RATING & TERMINAL MARKING PLATE	1

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
KAROLA BHIMAL ROAD, KAROLA, SANCHORE-343041

OUTLINE DRAWING	
315 KVA, 11/0.433 KV CU WOUND DISTIN. T/FS.	
RPTPL-OL-315KVA-02-2018	



SR.NO.	WEIGHT CHART	FIGURES
1	CORE COIL ASSEMBLY	1450 KG
2	TANK WITH FITTINGS	370 KG
3	MASS OF OIL	410 KG
4	TOTAL MASS	2230 KG
5	OIL VOLUME	500 LTR

TENDER NO.: CUSTOMER:	
DRN BY	E. E. L-3
APPROD BY	
DATE	26.09.2018
SCALE	

10-10-18
315 KVA
LAP

