



Certificate No. : TC-5389

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



## TEST REPORT

SHEET No. 1 of 12

<b>NAME &amp; ADDRESS OF CUSTOMER</b> Rajasthan Powergen Transformer Pvt. Ltd. Khasra No. 911-914, Karola-Bhinmal Road, Sanchoe - 343041 RJ	<b>REPORT NO.:</b> RP-1718-051919 <b>DATE</b> : 19 Jan 2018	
	<b>CUSTOMER REF NO.</b> NP/ERDA/TT/40/2017-18	<b>DATE</b> 29 Nov 2017
	<b>DATE OF SAMPLE RECEIPT</b> 05 Dec 2017	<b>DATE OF TESTING</b> 28 Dec 2017 to 10 Jan 2018
	<b>SAMPLE DESCRIPTION</b> <b>DISTRIBUTION TRANSFORMER (NON-SEALED TYPE)</b> Make: RAJASTHAN POWERGEN TRANSFORMER PVT. LTD. Rating: 500 kVA 11000 / 433 Volts 26.24 / 666.71 Amp. Vector Group: Dyn11 Energy efficiency level: 2 Further details as per sheet No. 2.	
	<b>SAMPLE IDENTIFICATION</b> ERDA sample code number: ERDA-00229816 Manufacturer serial number: RPTPL/500KVA/2017-18/001 Year of manufacture: 2017 Enclosed drawing numbers: 1) RPTPL/500KVA/003 2) RPTPL/500KVA/002 3) RPTPL/17-18/500 KVA/004 REV:00 SHEET NO.: 01	
<b>TEST DETAILS</b> As per sheet 3.	<b>TEST SPECIFICATION</b> As per sheet 3.	
<b>TEST RESULTS:</b> As per sheets from 4 to 10		
<b>ENCLOSURE:</b> Photographs of test sample - As per sheets from 11 to 12		
<b>REMARKS:</b> 1) The transformer <b>conforms</b> to the guaranteed requirement as per above mentioned test specification for above mentioned test nos. 1, 2, 5, 6, 7, 8, 9. 2) Criteria limit has not been specified for test nos. 3, 4, 10.		
<b>PREPARED BY</b> 	<b>CHECKED BY</b> 	<b>APPROVED BY</b> (Kapil J. Sharma)
<b>NOTE:</b> 1. This report relates only to the particular sample received for testing in good condition at ERDA, Vadodara. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from Director, ERDA. 4. Only the tests asked for by the customer have been carried out. 5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arisen.		
<b>Caution:</b> ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to consumers for verification of the authenticity of test reports issued by ERDA.		

TC 2434151





Certificate No. : TC-5389

## ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



SHEET No. 2 of 12

REPORT NO.: RP-1718-051919

Date: 19 Jan 2018

### TECHNICAL SPECIFICATIONS OF TEST OBJECT ASSIGNED BY CUSTOMER

1	Name of manufacturer	RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
2	Serial No.	RPTPL/500KVA/2017-18/001
3	kVA rating	500
4	Rated voltage H.V. (Volts)	11000
5	Rated voltage L.V. (Volts)	433
6	Rated current H.V. (Amp.)	26.24
7	Rated current L.V. (Amp.)	666.71
8	Number of phases	3
9	Energy efficiency level	2
10	Vector group	Dyn11
11	Winding material	Copper
12	Type of cooling	ONAN
13	Frequency (Hz.)	50
14	Guaranteed percentage impedance(%)	4.5
15	Total losses at 50% load (Watts)	1510
16	Total losses at 100% load (Watts)	4300
17	Guaranteed temperature rise of oil/winding	40°C /45°C
18	Year of manufacture	2017
19	Standard No.	IS: 1180 PART 1-2014 WITH AMENDMENT NO. 1 & 2, as per customer's requirement, CBIP manual, IS 2026

PREPARED BY

CHECKED BY



TC 2434280





Certificate No. : TC-5389

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



SHEET No. 3 of 12

REPORT NO.: RP-1718-051919

Date: 19 Jan 2018

Sr. No.	TEST DETAILS	TEST SPECIFICATION
1	No load current at 112.5 percent voltage:	As per cl.no.21.4.c of IS: 1180 PART 1-2014
2	Magnetic balance test	As per CBIP manual; Publication no.317 - 2013
3	Measurement of zero-sequence impedance (s) on three-phase transformers	As per customer`s requirement testing procedure followed as per cl.no.10.7. of IS: 2026 PART 1-2011
4	Measurement of unbalance current	As per customer`s requirement
5	Temperature-rise test	As per customer`s requirement testing procedure followed as per cl.no.21.3.b of IS: 1180 PART 1-2014
6	Oil leakage test	As per cl.no.21.2.j of IS: 1180 PART 1-2014
7	Pressure test (routine test)	As per cl.no.21.2.h of IS: 1180 PART 1-2014
8	Pressure test (type test)	As per cl.no.21.3.d of IS: 1180 PART 1-2014
9	Permissible flux density and over fluxing	As per cl.no. 7.9 of IS: 1180 PART 1-2014
10	Measurement of the Harmonics of the No-load current	As per customer`s requirement testing procedure followed as per cl.no.10.6. of IS: 2026 (PART 1)-2011
<div> <div> </div> <div> </div> </div> <div> <div>PREPARED BY</div> <div>CHECKED BY</div> </div>		



TC 2434279



Certificate No. : TC-5389

**ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



SHEET No. 4 of 122

REPORT NO.: RP-1718-051919

Date: 19 Jan 2018

Sr. No.	Particular of Tests & Cl.No.			Requirement as per Specification	Obtained Value	Remarks
1	<b>No load current at 112.5 percent voltage:</b> (As per cl.no.21.4.c of IS: 1180 PART 1-2014)  Test voltage of 112.5 percent of rated voltage at rated frequency was applied to the L.V. winding terminals and H.V. winding terminals were kept open circuited. No load current was recorded. <div>Test voltage (Volts) No load current (Amps) No Load Current (%)</div>			Max. 5.0	487.125 1.7809 0.267	Conforms
2	<b>Magnetic balance test</b> (As per CBIP manual; Publication no.317 - 2013)					Conforms
	<b>Voltage Applied Between</b>	<b>Applied Voltage (Volts)</b>	<b>Measured Voltage Between</b>			
	2u & 2n	99.99	2v & 2n			
			2w & 2n			
	2v & 2n	100.09	2u & 2n			
			2w & 2n			
	2w & 2n	100.08	2u & 2n			
			2v & 2n			
3	<b>Measurement of zero-sequence impedance(s) on three-phase transformers</b> (As per customer`s requirement testing procedure followed as per cl.no.10.7. of IS: 2026 PART 1-2011) The 2u, 2v and 2w terminals of LV winding shorted together. A test current (i.e. 1/3rd of rated current) was circulated between shorted terminals and 2n and measured a voltage across them. The obtained values are tabulated as below: <div>Test current (Amps)</div>				222.24	---

2434275

PREPARED BY

CHECKED BY







Certificate No. : TC-5389

**ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



SHEET No. 5 of 12

REPORT NO.: RP-1718-051919

Date: 19 Jan 2018

Sr. No.	Particular of Tests & Cl.No.	Requirement as per Specification	Obtained Value	Remarks
	<b>Measured Voltage (Volts)</b> $Z_{ps} = 3V/I (\Omega/\text{Phase})$ $(3V * kVA)$ $Z_{ps} = \text{-----} (\%)$ $(I * 10 (kV)^2)$	--	1.310 0.018 4.716	
4	<b>Measurement of unbalance current</b> (As per customer's requirement) All the three terminals of the secondary (LV) winding shorted together, except neutral terminal. Current measuring terminal of ammeter was connected between short circuited secondary (LV) windings and neutral terminal for measurement of unbalance current. 3-phase voltage was applied to the primary (HV) winding for circulating rated current in both the windings and measured unbalance current. a) Rated secondary (LV) winding current (Amps): b) Measured unbalance current (Amps): c) Measured unbalance current (%):	--	666.71 0.1 0.015	---
5	<b>Temperature-rise test</b> (As per customer's requirement testing procedure followed as per cl.no.21.3.b of IS: 1180 PART 1-2014) Before starting test, the dimensions of tank with radiators were measured & recorded.  Size of tank: L1-1245 mm, W1-550 mm, H1-1050 mm, H2-1065 mm Size of fins: L-700 mm, W-300 mm, No. of radiators-4, No. of fins per radiator-9  <b>Losses fed for temperature-rise test were 4300 Watts</b>			Conforms

PREPARED BY

CHECKED BY



TC 2434281



Certificate No. : TC-5389

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



SHEET No. 01

REPORT NO.: RP-1718-051919			Date: 19 Jan 2018	
Sr. No.	Particular of Tests & Cl.No.	Requirement as per Specification	Obtained Value	Remarks
	(As specified by the customer)  Specified losses were fed to the transformer (i.e. supply was connected to HV winding and LV winding kept short circuited) till steady state temperature rise was attained. Top oil temperature was recorded hourly. After steady state condition, the losses were brought down in reference to the rated current one hour prior to shut down.  At the shut down, the hot winding resistances were measured and temperature rise calculated.  A) Top oil temperature-rise B) Winding temperature-rise (Resistance method) 1) HV winding 2) LV winding C) Ambient temperature at shutdown D) Time of shutdown (Hrs)	          Max. 40°C      Max. 45°C Max. 45°C	          30.9°C      44.7°C 42.2°C 23.8°C 01:30	
6	<b>Oil leakage test</b> (As per cl.no.21.2.j of IS: 1180 PART 1-2014)  The assembled transformer with all fittings including bushings in position was tested at a pressure at the top equivalent to the head that was available at the base of the tank for 8 hours.	          There should be no leakage at any point	          No leakage observed	<b>Conforms</b>
7	<b>Pressure test (routine test)</b> (As per cl.no.21.2.h of IS: 1180 PART 1-2014)  The transformer tank was tested at an air pressure of 35 kPa above atmosphere pressure maintained inside the tank for 10 min.	          There should be no leakage at any point	          No leakage observed	<b>Conforms</b>

2434163

TJ

PREPARED BY

CHECKED BY

Age Products

TC2434168

TS

PREPARED BY

CHECKED BY







Certificate No. : TC-5389

**ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



SHEET No. 7 of 12

REPORT NO.: RP-1718-051919		Date: 19 Jan 2018																																														
Sr. No.	Particular of Tests & Cl.No.	Requirement as per Specification	Obtained Value	Remarks																																												
8	<p><b>Pressure test (type test)</b> (As per cl.no.21.3.d of IS: 1180 PART 1-2014)</p> <p>The transformer tank was subjected to air pressure of 80 kPa for 30 minutes. The permanent deflection of flat plates was recorded, after pressure had been released.</p> <table><thead><tr><th>Deflection measured at</th><th>Length of plate (mm)</th></tr></thead><tbody><tr><td>HV side</td><td>1245</td></tr><tr><td>LV side</td><td>1245</td></tr><tr><td>Side A</td><td>550</td></tr><tr><td>Side B</td><td>550</td></tr></tbody></table> <p>The transformer tank was subjected to vacuum of 500 mm of Mercury for 30 minutes. The permanent deflections of flat plates was recorded, after vacuum had been released.</p> <table><thead><tr><th>Deflection measured at</th><th>Length of plate (mm)</th></tr></thead><tbody><tr><td>HV side</td><td>1245</td></tr><tr><td>LV side</td><td>1245</td></tr><tr><td>Side A</td><td>550</td></tr><tr><td>Side B</td><td>550</td></tr></tbody></table> <div><div>HV Side</div><div>Side A<div>Side B</div></div><div>LV Side</div></div>	Deflection measured at	Length of plate (mm)	HV side	1245	LV side	1245	Side A	550	Side B	550	Deflection measured at	Length of plate (mm)	HV side	1245	LV side	1245	Side A	550	Side B	550	<table><tbody><tr><td>Max. 6.5 mm</td><td>0.3 mm</td></tr><tr><td>Max. 6.5 mm</td><td>0.3 mm</td></tr><tr><td>Max. 5.0 mm</td><td>0.2 mm</td></tr><tr><td>Max. 5.0 mm</td><td>0.1 mm</td></tr></tbody></table> <table><tbody><tr><td>Max. 6.5 mm</td><td>0.2 mm</td></tr><tr><td>Max. 6.5 mm</td><td>0.2 mm</td></tr><tr><td>Max. 5.0 mm</td><td>0.1 mm</td></tr><tr><td>Max. 5.0 mm</td><td>0.1 mm</td></tr></tbody></table> <p>There should be no leakage at any point</p>	Max. 6.5 mm	0.3 mm	Max. 6.5 mm	0.3 mm	Max. 5.0 mm	0.2 mm	Max. 5.0 mm	0.1 mm	Max. 6.5 mm	0.2 mm	Max. 6.5 mm	0.2 mm	Max. 5.0 mm	0.1 mm	Max. 5.0 mm	0.1 mm	<table><tbody><tr><td>0.3 mm</td><td>0.3 mm</td></tr><tr><td>0.3 mm</td><td>0.2 mm</td></tr><tr><td>0.2 mm</td><td>0.1 mm</td></tr><tr><td>0.1 mm</td><td>0.1 mm</td></tr></tbody></table> <p>No leakage observed</p>	0.3 mm	0.3 mm	0.3 mm	0.2 mm	0.2 mm	0.1 mm	0.1 mm	0.1 mm	Conforms
Deflection measured at	Length of plate (mm)																																															
HV side	1245																																															
LV side	1245																																															
Side A	550																																															
Side B	550																																															
Deflection measured at	Length of plate (mm)																																															
HV side	1245																																															
LV side	1245																																															
Side A	550																																															
Side B	550																																															
Max. 6.5 mm	0.3 mm																																															
Max. 6.5 mm	0.3 mm																																															
Max. 5.0 mm	0.2 mm																																															
Max. 5.0 mm	0.1 mm																																															
Max. 6.5 mm	0.2 mm																																															
Max. 6.5 mm	0.2 mm																																															
Max. 5.0 mm	0.1 mm																																															
Max. 5.0 mm	0.1 mm																																															
0.3 mm	0.3 mm																																															
0.3 mm	0.2 mm																																															
0.2 mm	0.1 mm																																															
0.1 mm	0.1 mm																																															
9	<p><b>Permissible flux density and over fluxing</b> (As per cl.no. 7.9 of IS: 1180 PART 1-2014)</p>			Conforms																																												

2434167

PREPARED BY

CHECKED BY





# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



SHEET No. 8 of 12

REPORT NO.: RP-1718-051919

Date: 19 Jan 2018

Sr. No.	Particular of Tests & Cl.No.			Requirement as per Specification	Obtained Value	Remarks
	<b>(a) Overfluxing test:</b> Test voltage at rated frequency was applied to the L.V. winding terminals and H.V. winding terminals were kept open circuited and exciting current was recorded at 100% and 112.5% of rated voltage. Rated full load current of L.V. winding = 666.71 Amps					
	% of rated voltage	Test voltage (Volts)	No load current (Amps)			
	100%	434.16	1.2275			
	112.5%	487.125	1.7809			
	<b>(b) Permissible flux density:</b> Transformer was opened for the measurement of total area of the core. The core was dismantled and various dimensions of width and thickness were measured to calculate the total area of the core. Number of turns of L.V. winding were counted. Total measured area of the core: <b>33397.47</b> mm <sup>2</sup> Stacking factor: <b>0.97</b> (As specified by customer) Total no. of turns of L.V winding: <b>25</b> per phase Rated voltage of L.V winding: <b>250</b> V per phase Rated frequency: <b>50</b> Hz Flux density is calculated with +12.5 percent combined voltage and frequency variation from rated voltage and frequency. <div>112.5 % of voltage/phase</div> <div>Flux density= -----</div> <div>(4.44 x Freq.(Hz) x Turns x Area of Core)</div>					
			1.9 Tesla	1.56 Tesla		

TC 2434166

TS

PREPARED BY

CHECKED BY







Certificate No. : TC-5389

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33



Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



SHEET No. 9 of 12

REPORT NO.: RP-1718-051919			Date: 19-Jan-2018	
Sr. No.	Particulars of test and clause no.	Requirement as per specification.	Obtained value	Remarks
10	<b>Measurement of the Harmonics of the No-load current</b> (As per customer's request testing procedure followed as per cl. no. 10.6 of IS 2026 (Part 1):2011)	The harmonics of the no-load current in the three phases shall be measured and magnitude of the harmonics shall be expressed as a percentage of the fundamental component.	Refer table 1 for individual current harmonics components & individual voltage harmonics components measured at LV side at rated voltage i.e. 433 V  Current THD: R-ph: 24.05% Y-ph: 24.42% B-ph: 22.76% Voltage THD: R-ph: 1.62% Y-ph: 1.64% B-ph: 1.54%	---
<div> <div>  </div> <div>  </div> </div> <div> <div>Prepared by:</div> <div>Checked by:</div> </div>				



TC 2434730



Certificate No. : TC-5389

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33



Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



SHEET No. 10 of 12

REPORT NO.: RP-1718-051919						Date: 19-Jan-2018			
TABLE-1 : Harmonics in voltage and current (as a percentage of fundamental)									
Harmonic order	Current I <sub>R</sub> in %	Current I <sub>R</sub> in Amps	Voltage V <sub>RY</sub> in %	Current I <sub>Y</sub> in %	Current I <sub>Y</sub> in Amps	Voltage V <sub>YB</sub> in %	Current I <sub>B</sub> in %	Current I <sub>B</sub> in Amps	Voltage V <sub>BR</sub> in %
1	100.00	1.75	100.00	100.00	1.05	100.00	100.00	1.73	100.00
2	1.86	0.03	0.02	1.61	0.02	0.02	1.61	0.03	0.02
3	3.12	0.05	0.20	6.48	0.07	0.14	8.30	0.14	0.11
4	0.55	0.01	0.02	2.15	0.02	0.03	0.25	0.00	0.01
5	22.35	0.39	1.19	20.95	0.22	1.08	16.62	0.29	1.24
6	0.52	0.01	0.01	0.91	0.01	0.03	0.54	0.01	0.03
7	1.22	0.02	0.45	4.80	0.05	0.51	3.47	0.06	0.48
8	0.29	0.01	0.01	0.30	0.00	0.01	0.18	0.00	0.01
9	2.72	0.05	0.06	3.81	0.04	0.31	2.73	0.05	0.17
10	0.47	0.01	0.01	0.92	0.01	0.01	0.56	0.01	0.01
11	5.15	0.09	0.95	1.73	0.02	0.97	1.15	0.02	0.57
12	0.26	0.00	0.01	0.44	0.00	0.02	0.24	0.00	0.02
13	2.71	0.05	0.17	7.76	0.08	0.43	8.73	0.15	0.46
14	0.28	0.00	0.01	0.44	0.00	0.01	0.28	0.00	0.01
15	1.36	0.02	0.13	1.01	0.01	0.14	7.17	0.12	0.08
16	0.11	0.00	0.01	0.19	0.00	0.01	0.10	0.00	0.02
17	1.07	0.02	0.14	1.83	0.02	0.06	1.10	0.02	0.09
18	0.10	0.00	0.00	0.18	0.00	0.01	0.12	0.00	0.01
19	2.88	0.05	0.05	0.16	0.00	0.01	2.99	0.05	0.03
20	0.31	0.01	0.00	0.51	0.01	0.00	0.31	0.01	0.01
21	2.74	0.05	0.02	0.74	0.01	0.03	2.76	0.05	0.04
22	0.10	0.00	0.00	0.15	0.00	0.00	0.10	0.00	0.00
23	1.16	0.02	0.02	0.23	0.00	0.02	1.19	0.02	0.02
24	0.10	0.00	0.00	0.18	0.00	0.00	0.10	0.00	0.00
25	1.25	0.02	0.01	0.13	0.00	0.03	1.26	0.02	0.02
THD %	24.05		1.62	24.42		1.64	22.76		1.54
Parameter measured	1.80 A		430.53 V	1.08 A		433.37 V	1.77 A		436.03 V
Prepared by  Checked by 									

TC 2434711







Certificate No. : TC-5389

## ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org





SHEET No. 11 of 12

REPORT NO.: RP-1718-051919

Date: 19 Jan 2018

### PHOTOGRAPHS OF TEST SAMPLE



PREPARED BY

CHECKED BY



TC 243416



Certificate No. : TC-5389

## ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>




SHEET No. 12 of 12

REPORT NO.: RP-1718-051919

Date: 19 Jan 2018

### PHOTOGRAPHS OF TEST SAMPLE



PREPARED BY

CHECKED BY



TC 2434164




105  
95

## DISTRIBUTION TRANSFORMER

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD IS:1180(Part 1)  
KAROLA-BHINMAL ROAD, KAROLA, SANCHORE  
RAJASTHAN (INDIA) CML-540330105

3 PHASE TRANSFORMER	ENERGY LEVEL	2
STANDARD	IS:1180(PART-1)/2014	
MAX. TOTAL LOSS W/	AT 50% LOAD	W/ 1510
KVA	500	
MAX. TOTAL LOSS W/	AT 100% LOAD	W/ 4300
VOLTS AT	HV 11000	TYPE OF COOLING ONAN
NO. LOAD	LV 433	TEMP. RISE { OIL 40° C
		WDG. 45° C
BIL	HV 1195/AC28	MASS OF OIL(KG) 400
	LV 11- /AC3	
AMPERES	HV 26.25	TOTAL MASS (KG) 2330
	LV 666.7	
FREQUENCY HZ	50	VOLUME OF OIL LTRS 480
VECTOR GROUP	Dyn11	MONTH/YEAR OF MFG 2017
IMPEDANCE VOLT %	4.5	
TAPPING	NA	S.N.O RPTPL/500KVA/ZMT-18/001
CUSTOMER	---	
ORDER NO.	---	

MADE IN INDIA



MADE IN INDIA



Test Report No.: RP-1718-051919  
Date: 19/Jan/2018  
Product: 500kVA, 2wmer  
Verified By: [Signature]  
Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with 'V'.

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD  
KAROLA-BHINMAL ROAD, KAROLA, SANCHORE  
RAJASTHAN - 343041

TITLE: - NAME PLATE DRAWING OF 500KVA, 11/0.433KV  
COPPER WOUND ENERGY EFFICIENCY LEVEL-2 TRANSFORMER

CUSTOMER ---

T.S.No. RPTPL/17-18/500KVA/001


SCALE N T S

DRG. No. RPTPL/500KVA/003


# NOTES:-

1. ALL DIMENSIONS ARE IN MM UNLESS OTHERWISE STATED.
2.  $\pm 10\%$  TOLERANCES ON WEIGHTS & DIMENSIONS

Test Report No.: **RP-1788-051919**  
 Date: **19/Jun/2018**  
 Product: **500 KVA / 20med**  
 Verified By: **[Signature]**  
 Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with +33.



TANK DIMENSIONS	
LENGTH	1245
BREADTH	550
HEIGHT	1050/1065
WEIGHT DETAILS	
Core & Windings	1460 Kgs.
Tank & Fitting	470 Kgs.
Weight of Oil	400 Kgs.
Total Weight	2330 Kgs.
Quantity of Oil	480 Ltrs.
MIN. ELECTRICAL CLEARANCE	
PHASE TO PHASE	HV 255
PHASE TO EARTH	LV 75
DATE	SIGN.
REMARKS	



ITEM	DESCRIPTION	QTY.
23.	STIFFNER-(50X50X6)MM ANGLE	2
22.	EXPLOSION VENT	1
21.	HV OUTDOOR BUSHINGS	3
20.	LIFTING LUGS FOR TANK COVER	2
19.	TRANSFORMER LIFTING LUGS	4
18.	AIR RELEASE PLUG	1
17.	INSPECTION HOLE	1
16.	4" DIAL TYPE THERMOMETER WITH MAX. DEMAND POINTER	1
15.	THERMOMETER POCKET	1
14.	UNDERBASE CHANNELS (125X65)MM	2
13.	EARTHING TERMINALS M-12X40L	2
12.	OIL DRAIN CUM SAMPLING VALVE	1
11.	COOLING PSR RADIATORS 700C/CX300W-9FINS	4
10.	IDENTITY PLATE	1
9.	NAME & RATING PLATE	1
8.	PULLING LUGS	4
7.	L.V. BUSHING	4
6.	OIL FILTER VALVE-20MM GUN METAL	1
5.	CONSERVATOR PIPE	1
4.	OIL CONSERVATOR WITH DRAIN PLUG	1
3.	OIL LEVEL GAUGE	1
2.	DEHYDRATING BREATHER	1
1.	OIL FILLING HOLE WITH CAP	1



RAJASTHAN POWERGEN TRANSFORMER PVT. LTD  
 KAROLA-BHINMAL ROAD, KAROLA, SANCHORE  
 RAJASTHAN - 343041

Title:- OUTLINE GENERAL ARRANGEMENT DRAWING OF 500KVA  
 11/0.433KV ENERGY EFFICIENCY LEVEL-2 TRANSFORMER

DRN.	CUSTOMER	---
CKD.	SPEC. No.	---
APPD.	SCALE	N T S
DATE	DRG. No.	RPTPL/500KVA/002



File Path : BFTC\RPL\17012017\500 KVA DENSITY.dwg



STEP REF.	WIDTH (mm)	STEP THICKNESS (mm)	GROSS SECTION AREA (mm <sup>2</sup> )
1	200	57.10	11420.00
2	190	27.50	5225.00
3	180	19.60	3528.00
4	170	15.60	2652.00
5	160	13.00	2080.00
6	150	11.20	1680.00
7	140	9.70	1358.00
8	130	8.50	1105.00
9	120	7.50	900.00
10	110	6.60	726.00
11	100	5.80	580.00
12	80	9.60	768.00
13	60	7.10	426.00
TOTAL GROSS SECTION AREA (in mm <sup>2</sup> )			32448.00
SAFETY FACTOR			0.97
NET CROSS SECTION AREA (in mm <sup>2</sup> )			31474.56

SAY NET AREA (A x 0.97) = 31474.56

E = 4.44 x f x Bmax x A x N x 0.97 x 10<sup>-6</sup>

Bmax =  $\frac{E \times 10^6}{4.44 \times f \times A \times N \times 0.97}$

=  $\frac{250 \times 10^6}{4.44 \times 50 \times 25 \times 31474.56}$   
= 1.431 TESLA



Test Report No.: RP-1718-051919  
Date: 19/Jan/2018  
Product: 500KVA, 2MVA  
Verified By: RA  
Verification of this drawing by E.R.D.A is  
subjected to relevant dimensions and assembly.  
All dimensions are in millimeters unless  
otherwise stated. If in doubt - Please Ask!

Rev		Date	Draw	Checked	Approved	Description
00	17.04.2017					ORIGINAL ISSUE.
RAJASTHAN POWERGEN TRANSFORMER P. LTD.						
Kardla - Bhimal Road, Kardla, Sandhore - 343041 Dist - Jaipur, Rajasthan (India)						
Title:		OUTLINE GENERAL ARRANGEMENT				
Rating:		500 KVA, 110/433 kV, 30, 50 Hz, TRF.				
Drawing No.:		RPTPL/17-18/500 KVA/004				
Rev.:		00				
Sheet No.:		01				
Total Sheets:		01				
Scale:		N.T.S				