



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382





E-mail : erda@erda.org

Web : http://www.erda.org

**TEST REPORT**

TC53891900009880F

SHEET NO. : 1 OF 15

NAME & ADDRESS OF CUSTOMER M/s. Rajasthan Powergen Transformer Pvt. Ltd. Khasra No. 911-914 Karola - Bhinmal Road, Karola, Sanchore, Rajasthan-343041	TEST REPORT NO. : RP-1819-050495 DATE : 27/03/2019	
	CUSTOMER REF. NO. : NIL DATED : 20/03/2019	
	DATE OF SAMPLE RECEIPT 20/03/2019	DATE OF TESTING 27/03/2019
	SAMPLE DESCRIPTION DISTRIBUTION TRANSFORMER NON-SEALED TYPE ENERGY EFFICIENCY LEVEL : 2 RATING : 63 kVA RATED VOLTS : 11000/433 V RATED CURRENT : 3.306/84 A NO. OF PHASE : 03 TYPE OF COOLING : ONAN FREQUENCY : 50 Hz % IMPEDANCE : 4.5% VECTOR GROUP : Dyn 11 B.I.L. : H. V. : 28 kVrms / 95 kVp L.V. : 3 kVrms /----	
TEST DETAIL : Lightning Impulse Test with Chopped on the Tail on all the three phases of HV Terminals at 95 kVp.		TEST SPECIFICATION : As per IS:1180 (Part-I)-2014, Cl.No. 21.3.a Amendment No.1 & 2 & 3 and Test voltage was specified by the customer. (Test Procedure was followed as per IS : 2026-(Part-III)-2009, Cl. No. 14)
ENCLOSURE : DRG. NO.: 1) RPTPL-63KVA-RP-01/02-2019 2) RPTPL-63KVA-RP-02/02-2019 3) RPTPL-GA-63KVA-02-2019		
TEST WITNESSED BY : ----		
REMARKS : From the observation of enclosed oscillographic records, it is concluded that the transformer conforms to the requirements of the above mentioned standard with respect to the test carried out.		
 PREPARED BY	 CHECKED BY	 A. S. Khopkar APPROVED BY
Note : 1. This report relates only to the particular sample received in good condition for testing at ERDA Vadodara. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from Director, ERDA. 4. Only the tests asked for by the customer have been carried out. 5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be constructed as where the cause has arised		
Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.		

TC 2743465



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC53891900009880F

TEST REPORT NO. : RP-1819-050495

SHEET NO. : 2 of 15

DATE : 27/03/2019

Waveform	Comment	Ut / kVp	T1 / μ s	T2 / μ s	Tc / μ s
1U PHASE					
1	LI RW	-55.792	1.391	54.005	
2	100% LI FW	-93.509	1.397	54.048	
3	LI CRW	-58.663	1.386		3.105
4	110% LI CFW	-104.162	1.364		2.423
5	110% LI CFW	-104.516	1.376		2.996
6	100% LI FW	-95.848	1.385	53.907	
7	100% LI FW	-94.843	1.383	53.935	
1V PHASE					
8	LI RW	-55.904	1.394	53.945	
9	100% LI FW	-94.996	1.402	54.105	
10	LI CRW	-61.606	1.380		2.641
11	110% LI CFW	-103.670	1.392		2.758
12	110% LI CFW	-105.026	1.403		2.970
13	100% LI FW	-94.560	1.401	54.138	
14	100% LI FW	-96.200	1.401	54.129	
1W PHASE					
15	LI RW	-56.172	1.384	54.034	
16	100% LI FW	-94.695	1.389	54.043	
17	LI CRW	-60.200	1.364		2.844
18	110% LI CFW	-105.401	1.371		2.495
19	110% LI CFW	-105.522	1.374		2.485
20	100% LI FW	-95.988	1.384	53.991	
21	100% LI FW	-95.331	1.384	54.056	

TC 2743743

Dinmishy
PREPARED BY



P. Patel
CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC53891900009880F

TEST REPORT NO. : RP-1819-050495

SHEET NO.: 3 of 15

DATE : 27/03/2019




Fig.: 1

$U_p = -55.79 \text{ kV}$

$T_1 = 1.39 \text{ } \mu\text{s}$

$T_2 = 54.00 \text{ } \mu\text{s}$

$T_c = \text{ } \mu\text{s}$

Comment: LI RW




Fig.: 2

$U_p = -93.51 \text{ kV}$

$T_1 = 1.40 \text{ } \mu\text{s}$

$T_2 = 54.05 \text{ } \mu\text{s}$

$T_c = \text{ } \mu\text{s}$

Comment: 100% LI FW

TC 2743744

Nimishg
PREPARED BY



Pratul
CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC53891900009880F

TEST REPORT NO. : RP-1819-050495

SHEET NO.: 4 of 15

DATE : 27/03/2019





Fig.: 3

$U_p = -58.66 \text{ kV}$

$T_1 = 1.39 \mu\text{s}$

$T_2 = \mu\text{s}$

$T_c = 3.11 \mu\text{s}$



Comment: LI CRW





Fig.: 4

$U_p = -104.16 \text{ kV}$

$T_1 = 1.36 \mu\text{s}$

$T_2 = \mu\text{s}$

$T_c = 2.42 \mu\text{s}$



Comment: 110% LI CFW

TC 2743745

Nimishg
PREPARED BY



P. Patel
CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC53891900009880F

TEST REPORT NO. : RP-1819-050495

SHEET NO.: 5 of 15

DATE : 27/03/2019





Fig.: 5

$U_p = -104.52 \text{ kV}$

$T_1 = 1.38 \text{ } \mu\text{s}$

$T_2 = \text{ } \mu\text{s}$

$T_c = 3.00 \text{ } \mu\text{s}$



Comment: 110% LI CFW





Fig.: 6

$U_p = -95.85 \text{ kV}$

$T_1 = 1.39 \text{ } \mu\text{s}$

$T_2 = 53.91 \text{ } \mu\text{s}$

$T_c = \text{ } \mu\text{s}$



Comment: 100% LI FW

TC 2743746

Nimishg
PREPARED BY



P. Patel
CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC53891900009880F

TEST REPORT NO. : RP-1819-050495

DATE : 27/03/2019

SHEET NO.: 6 of 15





Fig.: 7

$U_p = -94.84 \text{ kV}$

$T_1 = 1.38 \text{ µs}$

$T_2 = 53.93 \text{ µs}$

$T_c = \text{µs}$



Comment: 100% LI FW





Fig.: 8

$U_p = -55.90 \text{ kV}$

$T_1 = 1.39 \text{ µs}$

$T_2 = 53.94 \text{ µs}$

$T_c = \text{µs}$



Comment: LI RW

TC 2743747

Nimishg
PREPARED BY



P. Patel
CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC53891900009880F

TEST REPORT NO. : RP-1819-050495

DATE : 27/03/2019

SHEET NO.: 7 of 15




Fig.: 9
 $U_p = -95.00 \text{ kV}$
 $T_1 = 1.40 \text{ } \mu\text{s}$
 $T_2 = 54.10 \text{ } \mu\text{s}$
 $T_c = \text{ } \mu\text{s}$

Comment: 100% LI FW




Fig.: 10
 $U_p = -61.61 \text{ kV}$
 $T_1 = 1.38 \text{ } \mu\text{s}$
 $T_2 = \text{ } \mu\text{s}$
 $T_c = 2.64 \text{ } \mu\text{s}$

Comment: LI CRW

TC 2743748

Dinmishq
PREPARED BY



P. Patel
CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org





TC538919000009880F



TEST REPORT NO. : RP-1819-050495

SHEET NO.: 8 of 15

DATE : 27/03/2019



Comment: 110% LI CFW



Comment: 110% LI CFW

TC 2743749

Nirmishg
PREPARED BY



Praveen
CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org





TC538919000009880F



TEST REPORT NO. : RP-1819-050495

SHEET NO.: 9 of 15

DATE : 27/03/2019



Comment: 100% LI FW



Comment: 100% LI FW

TC 2743750

Nimishq
PREPARED BY



Pooja
CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC53891900009880F

TEST REPORT NO. : RP-1819-050495

SHEET NO. : 10 of 15

DATE : 27/03/2019





Fig.: 15

$U_p = -56.17 \text{ kV}$

$T_1 = 1.38 \text{ µs}$

$T_2 = 54.03 \text{ µs}$

$T_c = \text{µs}$



Comment: LI RW





Fig.: 16

$U_p = -94.70 \text{ kV}$

$T_1 = 1.39 \text{ µs}$

$T_2 = 54.04 \text{ µs}$

$T_c = \text{µs}$



Comment: 100% LI FW

TC 2743751

Dinmishy
PREPARED BY



P. Patel
CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC53891900009880F

TEST REPORT NO. : RP-1819-050495

SHEET NO.: 11 of 15

DATE : 27/03/2019




Fig.: 17

$U_p = -60.20 \text{ kV}$

$T_1 = 1.36 \mu\text{s}$

$T_2 = \mu\text{s}$

$T_c = 2.84 \mu\text{s}$

Comment: LI CRW




Fig.: 18

$U_p = -105.40 \text{ kV}$

$T_1 = 1.37 \mu\text{s}$

$T_2 = \mu\text{s}$

$T_c = 2.50 \mu\text{s}$

Comment: 110% LI CFW

Nimishg
PREPARED BY



P. Patel
CHECKED BY

TC 2743752



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC53891900009880F

TEST REPORT NO. : RP-1819-050495

SHEET NO.: 12 of 15

DATE : 27/03/2019




Fig.: 19
 $U_p = -105.52 \text{ kV}$
 $T_1 = 1.37 \mu\text{s}$
 $T_2 = \mu\text{s}$
 $T_c = 2.49 \mu\text{s}$

Comment: 110% LI CFW




Fig.: 20
 $U_p = -95.99 \text{ kV}$
 $T_1 = 1.38 \mu\text{s}$
 $T_2 = 53.99 \mu\text{s}$
 $T_c = \mu\text{s}$

Comment: 100% LI FW

TC 2743753

Dinmishq
PREPARED BY



P. Patel
CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TC53891900009880F

TEST REPORT NO. : RP-1819-050495

SHEET NO. : 13 of 15

DATE : 27/03/2019




Fig.: 21

$U_p = -95.33 \text{ kV}$

$T_1 = 1.38 \mu s$

$T_2 = 54.06 \mu s$

$T_c = \mu s$

Comment: 100% LI FW

TC 2743754

Aamishq
PREPARED BY



Puneet
CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



TC538919000009880F

TEST REPORT NO. : RP-1819-050495

SHEET NO.: 14 of 15

DATE : 27/03/2019

PHOTOGRAPH OF TEST SAMPLE



Atamishg.

PREPARED BY



P. Patel

CHECKED BY

TC 2743755



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




TC538919000009880F

TEST REPORT NO. : RP-1819-050495

SHEET NO.: 15 of 15

DATE : 27/03/2019

PHOTOGRAPH OF RATING AND TERMINAL MARKING PLATE




TC 2743756

Dinmishg
PREPARED BY



Puneet
CHECKED BY

No. **RP-1819-050495**
 Date: **27/03/2019**
 Product: **63kVA x 11000V**
 Verified By: **Devesh**
 Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with *

DISTRIBUTION TRANSFORMER	
RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.	
KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041 RAJASTHAN.(INDIA)	
IS: 1180 	PART-I CM/L-84.00030105
<input checked="" type="checkbox"/> 3 PHASE TRANSFORMER STANDARD <input type="checkbox"/> IS:1180 (2014) KVA <input type="checkbox"/> 63 VOLTS AT NO LOAD HV <input type="checkbox"/> 11000 LV <input type="checkbox"/> 433 BIL HV <input type="checkbox"/> 35kVp/28kVrms LV <input type="checkbox"/> 3kVrms AMPERES HV <input type="checkbox"/> 3.306 LV <input type="checkbox"/> 84 FREQUENCY <input type="checkbox"/> 50 Hz VECTOR GROUP REF. <input type="checkbox"/> Dyn-11 IMPEDANCE VOLT % <input type="checkbox"/> 4.5 TAPPING <input type="checkbox"/> /	ENERGY EFFICIENCY LEVEL <input type="checkbox"/> 2 MAX. TOTAL LOSSES AT 50% RATED LOAD W <input type="checkbox"/> 340 MAX. TOTAL LOSSES AT 100% RATED LOAD W <input type="checkbox"/> 1140 TYPE OF COOLING <input type="checkbox"/> ONAN TEMP RISE OIL DEG C <input type="checkbox"/> 35 TEMP RISE WDG DEG C <input type="checkbox"/> 40 MASS OF OIL KGS <input type="checkbox"/> 126 TOTAL MASS KGS <input type="checkbox"/> 505 VOL. OF OIL L <input type="checkbox"/> 150 MONTH & YEAR OF MFG. <input type="checkbox"/> MAR-2019 SERIAL NO. <input type="checkbox"/> RPTPL-001
FOR HV VARIATION IN <input type="checkbox"/> STEP FROM <input type="checkbox"/> TO <input type="checkbox"/> %	
CUSTOMER <input type="text"/> ORDER NO. <input type="text"/>	
MADE IN INDIA	
<div style="display: flex; justify-content: space-around;"> 95 105 </div>	

SIZE: 105x105 mm HOLE CENTER: 95x95 mm



NOTE:
 * SERIAL NO, YEAR OF MANUFACTURE & MONTH OF MANUFACTURE WILL BE PUNCHED AT THE TIME OF DISPATCH
 MATERIAL : Anodized Aluminum
 THICKNESS : 1.5mm


RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.

KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041
RAJASTHAN.

DRN BY		RATING & TERMINAL MARKING PLATE FOR 63 KVA, 11/0.433 KV DISTRIBUTION TRANSFORMER 3 PHASE, ENERGY EFFICIENCY LEVEL-2
CHD BY		
APPD BY		

DRG. NO. RPTPL-63KVA-RP-01/02-2019

REV. NO.	DATE SIGN	BRIEF DESCRIPTION
	16.03.2019	01 of 02



1


2

3

4

5

Test Report No. RP-1819-05.049.5.
 Date: 27.10.2019
 Product: 63 KVA 11/0.433 kV
 Verified by: *Wimesig*
 Verification of this drawing by ERDA is limited to test and dimensional checks only. Verified dimensions are marked with *.



SIZE: 105x105 mm HOLE CENTER: 95x95 mm

NOTE:
 * SERIAL NO.,
 YEAR OF MANUFACTURE &
 MONTH OF MANUFACTURE
 WILL BE PUNCHED AT THE TIME OF DISPATCH
 MATERIAL : Anodized Aluminum
 THICKNESS : 1.5 mm

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.


KAROLA-BHINMAL ROAD KAROLA SANCHORE-343041
 RAJASTHAN.

DRN BY		RATING & TERMINAL MARKING PLATE FOR 63 KVA, 11/0.433 KV DISTRIBUTION TRANSFORMER 3 PHASE , ENERGY EFFICIENCY LEVEL-2
CHD BY		
APPD BY		

REV. NO.	DATE SIGN	BRIEF DESCRIPTION		DRG. NO. RPTPL-63KVA-RP-02/02-2019
	16.03.2019	02 of 02		


1 2 3 4 5 6 7

SR. NO.	ACCESSORIES	QTY.	TECHNICAL DETAILS AS PER SPECS PER REFER
1	CONSERVATOR WITH OIL FILLING HOLE WITH CAP & DRAIN PLUG	1	M.S.
2	OIL LEVEL GAUGE WITH 3 POSITION	1	M.S.
3	SILICAGEL BREATHER (5000 Grams)	1	AL DIE CAST AL DIE CAST
4	H.V. TERMINAL 12m.m. DIA WITH NUT	3	BRASS
5	H.V. BUSHING 12KV, 250A	3	PORCELAIN
6	L.V. TERMINAL 12 m.m. DIA. WITH NUT	4	BRASS
7	COOLING RADIATOR	2	C.R.C.
8	RATING & TERMINAL MARKING PLATE	1	ANODIZED ALUMINIZED AL
9	STIFFENER ANGLE SIZE (40x40x5 mm)	4	M.S.
10	EARTHING TERMINAL WITH LUGS SIZE (16 Amp.)	2	M.S.
11	BASE CHANNELS 75x40x4-60mm. L.DING.	2	M.S.
12	L.V. BUSHING TURRET	4	TENDER DRG. TENDER DRG.
13	L.V. BUSHING 11KV/250A	4	PORCELAIN
14	THERMOMETER POCKET	1	M.S.
15	LIFTING LUGS FOR COVER	2	M.S.
16	LIFTING LUGS FOR TANK REINFORCED WITH FLAT	2	M.S.
17	AIR RELEASE PLUG	1	M.S.
18	PULLING LUG	4	M.S.
19	CONSERVATOR PIPE	2	M.S.
20	METALLIC TIN PLATE	1	S.S.



ELEVATION

SIDE VIEW



PLAN

COOLING DETAILS

1	TOTAL SURFACE AREA :- TANK: 1.7898 sq. m.
2	NUMBER OF RADIATORS
3	HEIGHT x WIDTH OF FIN
1	TOTAL NUMBER OF COOLING FIN

WEIGHTS IN KGS. (+/- 10% Tol.)		DIMENSIONS IN m.m.	
CORE	172	TRANSFORMER OVERALL (+/- 10% TOLERANCE)	
WINDINGS	78	L =	990
TANK & FITTINGS	110	W =	730
OIL	126	H =	1375
TOTAL WEIGHT	505	TRANSFORMER TANK (+/- 10% TOLERANCE)	
THICKNESS IN m.m.		L1 =	830
TANK SIDE PLATES (MIN.)	3.15	WT =	310
TOP & BOTTOM PLATES (MIN.)	5	H1/H2 =	780 / 790
TOLERANCE		BUSHING CLEARANCES WITH ANGLE	
O'VERALL DIMENSIONS	+/- 10 %	a3 (H.V.)	255 PHASE TO PHASE
DIMENSIONS OF CONSERVATOR		b3 (L.V.)	75 PHASE TO PHASE
a' INSIDE DIAMETER IN mm.	165	L5 (H.V.)	205 PHASE TO EARTH
b' LENGTH IN mm.	700	b5 (L.V.)	55 PHASE TO EARTH
c' CAPACITY IN LTRS.	15		

Test Report No. RP-1819-050493
 Date: 24/03/2019
 Product: 63kVA Dimeesh
 Verified By: Dimesh
 Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with *

- NOTE
- 1 SHAPE OF TANK: RECTANGULAR SHAPE
 - 2 ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE STATED.
 - 3 METALLIC TIN PLATE: OPPOSITE SIDE OF COMBINED NAME PLATE
 - 4 * NOT PROVIDED DURING TESTING

RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
 KAROLA-BHINMAL ROAD KAROLA, SANCHORE-343041

GENERAL ARRANGEMENT DRAWING
 63 KVA 11/0.433 KV DIST. TRANSFORMER
 ENERGY EFFICIENCY LEVEL-2



DRG.NO.: RPTPL-GA-63KVA-02-2019
 DATE: 16.03.2019

1 2 3 4 5 6 7