



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : http://www.erda.org

**TEST REPORT**

ULR-TC538919000026095F

SHEET 1 OF 21

NAME & ADDRESS OF CUSTOMER RAJASTHAN POWERGEN TRANSFORMER PVT. LTD. Khasra No. 911-914, Karola-Bhinmal Road, Karola Sanchore, Rajasthan-343041	TEST REPORT NO.: RP-1920-019523 DATE: 24/08/2019			
SAMPLE DESCRIPTION 160 kVA Distribution Transformer 11000/433 Volts, 8.40/213.34 Amp., Oil filled, Vector Group: Dyn-11, ENERGY EFFICIENCY LEVEL: 2 Further details as per sheet No. 3 OF 21.	CUSTOMER REF. No.: NIL	DATED: 12/07/2019		
	DATE OF SAMPLE RECEIPT: 12/07/2019	DATE OF TESTING: 17/07/2019 to 24/08/2019		
	SAMPLE IDENTIFICATION ERDA SAMPLE CODE NO.: ERDA-00324652 SERIAL NO.: RPTPL/01 YEAR OF MFG.: 2019			
<table border="0"> <tr> <td data-bbox="183 1243 885 1814"> TEST DETAILS Short-circuit withstand test [Cl. No. (17 & 21.3 c)] ENCLOSURES: Number of oscillograms : Eleven Number of photograph : One Number of test circuit diagram : One Number of drawings : Three TEST WITNESSED BY: Mr. Irfan Khatri REMARKS: The sample conforms to the requirements of standard for short-circuit withstand test as specified by customer. </td> <td data-bbox="893 1243 1517 1814"> TEST SPECIFICATIONS As per customer's requirement, Test procedure followed as per IS 1180 (Part 1): 2014 [Amendment No. 1, 2 & 3] </td> </tr> </table>			TEST DETAILS Short-circuit withstand test [Cl. No. (17 & 21.3 c)] ENCLOSURES: Number of oscillograms : Eleven Number of photograph : One Number of test circuit diagram : One Number of drawings : Three TEST WITNESSED BY: Mr. Irfan Khatri REMARKS: The sample conforms to the requirements of standard for short-circuit withstand test as specified by customer.	TEST SPECIFICATIONS As per customer's requirement, Test procedure followed as per IS 1180 (Part 1): 2014 [Amendment No. 1, 2 & 3]
TEST DETAILS Short-circuit withstand test [Cl. No. (17 & 21.3 c)] ENCLOSURES: Number of oscillograms : Eleven Number of photograph : One Number of test circuit diagram : One Number of drawings : Three TEST WITNESSED BY: Mr. Irfan Khatri REMARKS: The sample conforms to the requirements of standard for short-circuit withstand test as specified by customer.	TEST SPECIFICATIONS As per customer's requirement, Test procedure followed as per IS 1180 (Part 1): 2014 [Amendment No. 1, 2 & 3]			
PREPARED BY 	CHECKED BY 	APPROVED BY J. R. TAHILWANI		

- NOTE:**
1. This report relates only to the particular sample received for testing in good condition at ERDA.
 2. This report cannot be reproduced in part under any circumstances.
 3. Publication of this report requires prior permission in writing from Director, ERDA.
 4. Only test asked for by customer have been carried out.
 5. In case of any dispute, Vadodra will be the exclusive jurisdiction & shall be construed as where the cause has arisen.

Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.

TC 2839651





Web : <http://www.erda.org>



TTC 2839650



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



ULR-TC538919000026095F

TEST REPORT NO.: RP-1920-019523

SHEET 3 OF 21

DATE: 24/08/2019

TECHNICAL SPECIFICATIONS OF TEST OBJECT ASSIGNED BY CUSTOMER

- | | |
|-------------------------------------|--|
| 1. Name of manufacturer | : RAJASTHAN POWERGEN TRANSFORMER PVT. LTD. |
| 2. Equipment | : 160 kVA Distribution Transformer |
| 3. Standard No. | : As per customer's requirement,
Test procedure followed as per
[Cl. No. (17 & 21.3 c)] of
IS 1180 (Part 1): 2014
[Amendment No. 1, 2 & 3] |
| 4. Serial No. | : RPTPL/01 |
| 5. Energy efficiency level | : 2 |
| 6. Type | : Outdoor, Oil Cooled, Non Sealed,
Aluminium wound, CRGO core |
| 7. kVA rating | : 160 |
| 8. Rated voltage H.V. (Volts) | : 11000 |
| L.V. (Volts) | : 433 |
| 9. Rated current H.V. (Amp.) | : 8.40 |
| L.V. (Amp.) | : 213.34 |
| 10. Number of phases | : 3 |
| 11. Connection H.V./L.V. | : Delta/Star |
| 12. Frequency (Hz.) | : 50 |
| 13. Type of cooling | : ONAN |
| 14. Temperature rise of oil/winding | : 35°C/40°C |
| 15. Percentage Impedance | : 4.5% |
| 16. Type of winding | : Concentric |
| 17. Primary winding conductor | : SEM Aluminium wire, bare dia. 2.65mm |
| 18. Secondary winding conductor | : DPC Aluminium strip, bare size
(8.85mm x 5.2mm) x 6 Nos. in parallel |
| 19. Quantity of oil (Litre) | : 280 |
| 20. Weight of oil (kg.) | : 230 |
| 21. Total weight (kg.) | : 1035 |
| 22. Vector group | : Dyn-11 |
| 23. Year of manufacture | : 2019 |
| 24. Insulation level H.V. | : 28 kVrms |
| 25. Insulation level L.V. | : 03 kVrms |
| 26. Total losses at 75°C (Watts) | : 670 Max. (at 50 % load) |
| 27. Total losses at 75°C (Watts) | : 1950 Max. (at 100 % load) |

PREPARED BY

CHECKED BY

TC 2839649





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



ULR-TC538919000026095F

TEST REPORT NO.: RP-1920-019523

SHEET 4 OF 21

DATE: 24/08/2019**ROUTINE TEST RESULTS BEFORE SHORT CIRCUIT****a) MEASUREMENT OF WINDING RESISTANCE**

Measurement at average oil temperature: 37.5°C					
LV Winding resistance (mΩ)			HV Winding Resistance (Ω)		
u - v	v - w	w - u	U - V	V - W	W - U
6.9110	6.8905	6.9720	7.0515	7.0410	7.0395

b) MEASUREMENT OF VOLTAGE RATIO AND CHECK OF PHASE DISPLACEMENT

Vector group: Dyn-11 was verified.

Rated turns Ratio	Measured turns ratio between Terminals					
	U-V/u-n	Difference %	V-W/v-n	Difference %	W-U/w-n	Difference %
44.001	43.895	-0.241	43.989	-0.027	43.958	-0.098

c) MEASUREMENT OF SHORT-CIRCUIT IMPEDANCE AND LOAD LOSS (at 100 % load)

Average oil temp.: 38.4°C

Test current (Amp.) I _{avg} .	Impedance voltage (V) V _{avg} .	Frequency (Hz.)	Load loss measured (Watts)	Impedance Voltage (%Z) at 50 Hz.	Load loss computed at 75°C (Watts)	%Z at 75°C
8.400	504.954	49.959	1334.06	4.594	1491	4.613

d) MEASUREMENT OF LOAD LOSS (at 50 % load)

Average oil temp.: 38.4°C

Test current (Amp.) I _{avg} .	Impedance voltage (V) V _{avg} .	Frequency (Hz.)	Load loss measured (Watts)	Load loss computed at 75°C (Watts)
4.199	251.930	49.898	332.79	372

PREPARED BY**CHECKED BY**

TC 2839648



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



ULR-TC538919000026095F

TEST REPORT NO.: RP-1920-019523

SHEET 5 OF 21

DATE: 24/08/2019e) MEASUREMENT OF NO-LOAD LOSS AND CURRENT

Average oil temp.: 38.4°C

Applied Voltage (V) Vavg.	Current (Amp.) Iavg.	Frequency (Hz.)	Losses Measured (Watts)
433.048	0.744	50.013	268

- Total losses at 75°C: 640 Watts (at 50 % load)
- Total losses at 75°C: 1759 Watts (at 100% load)

f) MEASUREMENT OF INSULATION RESISTANCE

Average oil temp.: 37.5°C

Measured between	DC Test Voltage (V)	IR value (MΩ)
HV to LV winding	2500	> 2000
HV winding to LV + EARTH	2500	> 2000
LV winding to HV + EARTH	500	> 2000

g) INDUCED OVER-VOLTAGE WITHSTAND TEST

Sr. No.	Test	Applied voltage (V)	Applied Freq. (Hz.)	Duration (sec.)	Remarks
1.	Between LV windings with tank connected to earth.	866	100	60	Withstood

h) SEPARATE-SOURCE VOLTAGE WITHSTAND TEST

Sr. no.	Test	Applied voltage (kV)	Duration (sec.)	Remarks
1.	Between HV winding and LV winding connected to the tank and earth	28	60	Withstood
2.	Between LV winding and HV winding connected to the tank and earth	03	60	Withstood

TC 2839647

KVS

PREPARED BY

Opal

CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



ULR-TC538919000026095F

TEST REPORT NO.: RP-1920-019523

SHEET 6 OF 21

DATE: 24/08/2019**SHORT-CIRCUIT WITHSTAND TEST:**

The verification of Short-circuit withstand test was performed on transformer by connecting the secondary winding to three phase balanced source and primary winding short circuited using synchronization switch. The test conducted with short circuiting of the primary winding follow the application of the voltage to the secondary winding of the transformer as per schematic circuit diagram No. OLSC/DTC/03.

Condition of the equipment under test: As after routine tests.

Supply Frequency: 50 Hz.

Test No.	Oscillogram No.	Applied voltage (Vrms)	Short circuit current on LV (kA)			Duration (sec.)	Remarks
			Peak	RMS	Avg.		
1.	0486/01	-	- 7.142 -	3.356 3.338 3.407	3.367	0.1	Calibration shot
2.	0486/02	433	- 10.004 -	4.582 4.501 4.503	4.529	0.5	No Abnormality
3.	0486/03	433	- 10.094 -	4.417 4.356 4.492	4.422	0.5	No Abnormality
4.	0486/04	433	- 10.025 -	4.457 4.505 4.502	4.488	0.5	No Abnormality
5.	0486/05	433	- - 9.616	4.557 4.338 4.507	4.467	0.5	No Abnormality
6.	0486/06	433	- - 9.602	4.388 4.458 4.858	4.558	0.5	No Abnormality
7.	0486/07	433	- - 9.649	4.467 4.515 4.506	4.496	0.5	No Abnormality
8.	0486/08	433	9.696 - -	4.438 4.520 4.515	4.491	0.5	No Abnormality
9.	0486/09	433	9.704 - -	4.481 4.531 4.530	4.514	0.5	No Abnormality
10.	0486/10	433	9.972 - -	4.487 4.545 4.534	4.514	0.5	No Abnormality
11.	0486/11	433	- 9.892 -	4.492 4.508 4.536	4.512	2.0	Thermal Shot* No Abnormality

*As per customer's requirement

PREPARED BY

CHECKED BY

TC 2839646





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



ULR-TC538919000026095F


TEST REPORT NO.: RP-1920-019523

SHEET 7 OF 21

DATE: 24/08/2019**Measurement of the % reactance during the short circuit test**

LV winding was short circuited. Three phase AC supply was connected to HV winding to pass test current. Before the short circuit test and after each shot, the percentage reactance was measured.

Sr. No.	Measurement performed		Measured value of % reactance at 50 Hz.			%Change in % reactance		
			U	V	W	U	V	W
1.	Before test		4.52	4.53	4.50	-	-	-
2.	After the test no.	2.	4.52	4.53	4.50	0.00	0.00	0.00
3.	After the test no.	3.	4.52	4.53	4.50	0.00	0.00	0.00
4.	After the test no.	4.	4.52	4.53	4.50	0.00	0.00	0.00
5.	After the test no.	5.	4.52	4.53	4.50	0.00	0.00	0.00
6.	After the test no.	6.	4.52	4.53	4.50	0.00	0.00	0.00
7.	After the test no.	7.	4.52	4.54	4.51	0.00	0.22	0.22
8.	After the test no.	8.	4.52	4.54	4.51	0.00	0.22	0.22
9.	After the test no.	9.	4.51	4.54	4.51	-0.22	0.22	0.22
10.	After the test no.	10.	4.52	4.54	4.51	0.00	0.22	0.22
11.	After the test no.	11.	4.51	4.53	4.52	-0.22	0.00	0.44


PREPARED BY

CHECKED BY


TC 2839645



Certificate No.: TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



ULR-TC538919000026095F

TEST REPORT NO.: RP-1920-019523

SHEET 8 OF 21

DATE: 24/08/2019**ROUTINE TEST RESULTS AFTER SHORT CIRCUIT****a) MEASUREMENT OF WINDING RESISTANCE**

Measurement at average oil temperature: 33.5°C					
LV Winding resistance (mΩ)			HV Winding Resistance (Ω)		
u - v	v - w	w - u	U - V	V - W	W - U
6.7475	6.7710	6.8330	6.8910	6.8800	6.8805

b) MEASUREMENT OF VOLTAGE RATIO AND CHECK OF PHASE DISPLACEMENT

Vector group: Dyn-11 was verified.

Rated turns Ratio	Measured turns ratio between Terminals					
	U-V/u-n	Difference %	V-W/v-n	Difference %	W-U/w-n	Difference %
44.001	43.891	-0.250	43.990	-0.025	43.954	-0.107

c) MEASUREMENT OF SHORT-CIRCUIT IMPEDANCE AND LOAD LOSS (at 100 % load)

Average oil temp.: 33.7°C

Test current (Amp.) I _{avg} .	Impedance voltage (V) V _{avg} .	Frequency (Hz.)	Load loss measured (Watts)	Impedance Voltage (%Z) at 50 Hz.	Load loss computed at 75°C (Watts)	%Z at 75°C
8.396	503.542	49.903	1301.690	4.589	1478	4.610

d) MEASUREMENT OF LOAD LOSS (at 50 % load)

Average oil temp.: 33.7°C

Test current (Amp.) I _{avg} .	Impedance voltage (V) V _{avg} .	Frequency (Hz.)	Load loss measured (Watts)	Load loss computed at 75°C (Watts)
4.196	251.354	49.897	324.430	369

PREPARED BY**CHECKED BY**

TC 2839644



Certificate No.: TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



ULR-TC538919000026095F

TEST REPORT NO.: RP-1920-019523

SHEET 9 OF 21

DATE: 24/08/2019**e) MEASUREMENT OF NO-LOAD LOSS AND CURRENT**

Average oil temp.: 33.7°C

Applied Voltage (V) Vavg.	Current (Amp.) Iavg.	Frequency (Hz.)	Losses Measured (Watts)
433.041	0.741	50.007	269

- Total losses at 75°C: 638 Watts (at 50 % load)
- Total losses at 75°C: 1747 Watts (at 100% load)

f) MEASUREMENT OF INSULATION RESISTANCE

Average oil temp.: 33.5°C

Measured between	DC Test Voltage (V)	IR value (MΩ)
HV to LV winding	2500	> 2000
HV winding to LV + EARTH	2500	> 2000
LV winding to HV + EARTH	500	> 2000

g) INDUCED OVER-VOLTAGE WITHSTAND TEST

Sr. No.	Test	Applied voltage (V)	Applied Freq. (Hz.)	Duration (sec.)	Remarks
1.	Between LV windings with tank connected to earth	866	100	60	Withstood

h) SEPARATE-SOURCE VOLTAGE WITHSTAND TEST

Sr. No.	Test	Applied voltage (kV)	Duration (sec.)	Remarks
1.	Between HV winding and LV winding connected to the tank and earth	28	60	Withstood
2.	Between LV winding and HV winding connected to the tank and earth	03	60	Withstood

Observation after test: The transformer was untanked and inspected.

- Condition of conductor, core and clamping:
 - No visible damage, deformation or displacement.
- Condition of spacers : Intact
- Condition of oil : Clear

Results: 1) % Change in % reactance is within tolerance limits as per standard.

- The results of routine tests carried out before and after the short-circuit withstand test found within limits as per standard.

TC 2839643

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000026095F

TEST REPORT NO.: RP-1920-019523

SHEET 10 OF 21


DATE: 24/08/2019



OSCILLOGRAM NO. : 0486/01

PREPARED BY *KNS*

CHECKED BY *g.e.*



TC 2822150



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000026095F

TEST REPORT NO.: RP-1920-019523

SHEET 11 OF 21

DATE: 24/08/2019



OSCILLOGRAM NO. : 0486/02

PREPARED BY

CHECKED BY



TC 2822151



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
Fax : +91 (0265) 2638382
E-mail : erda@erda.org
Web : http://www.erda.org




ULR-TC538919000026095F

TEST REPORT NO.: RP-1920-019523

SHEET 12 OF 21

DATE: 24/08/2019



OSCILLOGRAM NO. : 0486/03

PREPARED BY

CHECKED BY



TC 2822152



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000026095F

TEST REPORT NO.: RP-1920-019523

SHEET 13 OF 21

DATE: 24/08/2019



OSCILLOGRAM NO. : 0486/04

PREPARED BY

CHECKED BY



TC 2822153



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000026095F

TEST REPORT NO.: RP-1920-019523

SHEET 14 OF 21

DATE: 24/08/2019



OSCILLOGRAM NO. : 0486/05

PREPARED BY

CHECKED BY



TC 2822154



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
Fax : +91 (0265) 2638382
E-mail : erda@erda.org
Web : http://www.erda.org




ULR-TC538919000026095F

TEST REPORT NO.: RP-1920-019523

SHEET 15 OF 21

DATE: 24/08/2019



OSCILLOGRAM NO. : 0486/06

PREPARED BY

CHECKED BY



TC 2822155



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
Fax : +91 (0265) 2638382
E-mail : erda@erda.org
Web : http://www.erda.org




ULR-TC538919000026095F

TEST REPORT NO.: RP-1920-019523

SHEET 16 OF 21

DATE: 24/08/2019



OSCILLOGRAM NO. : 0486/07

PREPARED BY

CHECKED BY



TC 2822156



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000026095F

TEST REPORT NO.: RP-1920-019523

SHEET 17 OF 21


DATE: 24/08/2019



OSCILLOGRAM NO. : 0486/08

PREPARED BY

CHECKED BY



TC 2822157




Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
Fax : +91 (0265) 2638382
E-mail : erda@erda.org
Web : http://www.erda.org



ULR-TC538919000026095F
TEST REPORT NO.: RP-1920-019523
DATE: 24/08/2019


SHEET 18 OF 21



OSCILLOGRAM NO. : 0486/09

PREPARED BY

CHECKED BY



TC 2822158



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000026095F

TEST REPORT NO.: RP-1920-019523

SHEET 19 OF 21

DATE: 24/08/2019



OSCILLOGRAM NO. : 0486/10

PREPARED BY

CHECKED BY



TC 2822159

TC 2822160

ULR-TC538919000026095F
TEST REPORT NO.: RP-1920-019523
DATE: 24/08/2019

SHEET 20 OF 21



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
Fax : +91 (0265) 2638382
E-mail : erda@erda.org
Web : http://www.erda.org



OSCILLOGRAM NO.:0486/11

PREPARED BY
WNT

CHECKED BY
J. J.



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




ULR-TC538919000026095F

TEST REPORT NO.: RP-1920-019523

DATE: 24/08/2019

SHEET 21 OF 21



KNS
PREPARED BY

QJL
CHECKED BY



TC 2839642

105


95

DISTRIBUTION TRANSFORMER

Rajasthan Powergen Transformer Pvt. Ltd
Khasra No. 911-914, Karola-Bhimmal Road, Karola,
Sanchole-343041, Dist. Jalore, Rajasthan

3 PHASE TRANSFORMER ENERGY LEVEL 2
STANDARD IESIB(PART-I)/2014 MAX. TOTAL LOSS W/ 670
KVA 160 MAX. TOTAL LOSS W/ 1950
VOLTS AT HV 11000 TYPE OF COOLING ONAN
NO LOAD LV 433 TEMP. RISE { OIL 35° C
BIL { HV 1105/AC28 WDG. 40° C
LV LI-/AC3 MASS OF OIL(KG) 230
AMPERES { HV 8.40
LV 213.34 TOTAL MASS (KG) 1035
FREQUENCY HZ 50 VOLUME OF OIL LTRS 280
VECTOR GROUP Dyn11 MONTH & YEAR OF MFG 2018
IMPEDANCE VOLT % 4.5
TAPPING NA SERIAL NO. RPTPL/01
CUSTOMER
ORDER NO.

MADE IN INDIA



MADE IN INDIA

Test Report No. 2410819
Date 24/08/19
Product 160 KVA DT
Verification of this drawing by 30.08.19
Applicable relevant dimensions are marked
Dimensions are marked



RAJASTHAN POWERGEN TRANSFORMER PVT. LTD
KHASRA No. 911-914, KAROLA-BHINMAL ROAD, KAROLA,
SANCHORE-343041, DIST. JALORE, RAJASTHAN


TITLE:— NAME PLATE DRAWING OF 160 KVA, 11/0.433KV
ALUMINIUM WOUND ENERGY EFFICIENCY LEVEL-2 TRANSFORMER

CUSTOMER ---

T.S.No. ---

SCALE N T S

DRG. No. NP/160/08



WEIGHT CHART	
1. CORE & WINDING	570 Kgs.
2. TANK & FITTING	235 Kgs.
3. WEIGHT OF OIL	230 Kgs.
4. TOTAL WEIGHT	1035Kgs.
5. VOLUME OF OIL	280 Ltrs.

MIN ELECTRICAL CLEARANCE IN AIR	
PH. TO PH.	PH. TO EARTH
HV 255	HV 140
LV 75	LV 40

TANK THICKNESS	
SIDE WALL	4.0mm
TOP&BOTTOM	5.0mm


S.No.	DESCRIPTIONS	QTY.
17.	THERMOMETER POCKET	1
16.	IDENTITY PLATE	1
15.	AIR RELEASE PLUG	1
14.	EARTHING TERMINALS	2
13.	UNDER BASE CHANNELS (100mm x 50 mm)	2
12.	EXPLOSION VENT	1
11.	DRAIN CUM SAMPLING VALVE 20mm	1
10.	NAME RATING & DIAGRAM PLATE	1
9.	STIFFNER (50 mm x 50 mm x 6 mm THICK)	2
8.	PRESS STEEL RADIATOR (600C/CX300W)-6FINS	2
7.	L.V. BUSHING	4
6.	TRANSFORMER LIFTING LUGS 8 mm THICK	4
5.	H.V. BUSHING WITH ARCKING HORN & BIMETALLIC CONNECTOR	3
4.	SILICAGEL BREATHER 500 Grm.	1
3.	OIL CONSERVATOR WITH DRAIN PLUG	1
2.	OIL LEVEL INDICATORS	1
1.	OIL FILLING HOLE WITH CAP	1

RAJASTHAN POWERGEN TRANSFORMER PVT LTD
KHASRA NO. 911-914, KAROLA-BHINMAL ROAD, KAROLA,
SANCHORE-943041, Dist. JALORE, RAJASTHAN


TITLE:- OUTLINE G.A. DRAWING OF 160KVA,11/0.433KV ALUMINIUM WOUND ENERGY EFFICIENCY LEVEL-2 TRANSFORMER	
DRN. 2222	CUSTOMER ---
	T.S.No. ---
	SCALE N T S
DATE 10-07-2019	DRG. No. RPTL-OGA-180-07

- NOTES:-
- ALL DIMENSIONS ARE IN mm.
 - TOLERANCES ON OVERALL DIMENSION, TANK & WEIGHT ARE $\pm 10\%$
 - (*) ACCESSORIES NOT PROVIDED DURING TESTING





SECTIONAL SIDE VIEW



SECTIONAL PLAN

NOTES: -

1. ALL DIMENSIONS: ARE IN MM .
2. LV CONDUCTOR SIZE : (8.85x5.2)mmX6 DPC ALUMINIUM STRIP
3. HV CONDUCTOR SIZE : 2.65 MM DIA.SEM ALUMINIUM WIRE

9.	M.S. FOOT CHANNEL (100X50)MM	2
8.	M.S. TIE ROD ϕ 12 mm.	8
7.	P.B. SPACER BETWEEN SECTION	8
6.	P.B. SEPERATOR (1.5 mm X2)	2
5.	L.V. COIL/LIMB 1 No.	3
4.	H.V. COIL/LIMB 6 Nos.	18
3.	M.S. CORE BOLTS ϕ 12 mm.	8
2.	M.S. CORE CHANNEL (125X65)	4
1.	SRBP TUBES	3
ITEM No.	N O M E N C L A T U R E	QTY.
RAJASTHAN POWERGEN TRANSFORMER PVT LTD		
KHASRA NO> 911-914, KAROLA-BHINMAL ROAD, KAROLA,		
SANCHORE-343041, JALORE, RAJASTHAN		
Title:— CORE COIL ASSEMBLY DRAWING OF 160KVA,11/0.433KV		
ALUMINIUM WOUND ENERGY EFFICIENCY LEVEL-2 DISTRIBUTION TRANSFORMER		
DRN.	---	CUSTOMER
		T. NO
APPD.	--	SCALE
		N T S
DATE	---	DRG. No.
		IGA/160/02

Title: -- CORE COIL ASSEMBLY DRAWING OF 160KVA,11/0.43KV ALUMINIUM WOUND ENERGY EFFICIENCY LEVEL-2 DISTRIBUTION TRANSFORMER