



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
Fax : +91 (0265) 2638382
E-mail : erda@erda.org
Web : http://www.erda.org



TEST REPORT

SHEET 1 OF 27

NAME & ADDRESS OF CUSTOMER M/s. RAJASTHAN POWERGEN TRANSFORMER PVT. LTD. Karola-Bhinmal Road, Karola, Sanchoe, Dist.- Jalore, Rajasthan-343041	REPORT NO.: RP-1718-050430 DATE: 10.01.2018	
	CUSTOMER REF. NO.: NP/ERDA/TT/41/ 2017-18	DATED: 29.11.2017
	DATE OF SAMPLE RECEIPT: 30.11.2017	DATE OF TESTING: 04.12.2017 to 26.12.2017
	SAMPLE IDENTIFICATION ERDA SAMPLE CODE NO.: ERDA-00228924 SERIAL NO.: RPTPL/16KVA/2017/18/001 YEAR OF MFG.: 2017 CUSTOMER : AVVNL	
SAMPLE DESCRIPTION 16 kVA Single Phase Distribution Transformer 6351/240 Volts, 2.52/66.67Amps., Oil filled, ENERGY EFFICIENCY LEVEL: 2 Further details as per sheet No. 3 of 27		
TEST DETAILS As per sheet 4 OF 27. ENCLOSURES: As per sheet 2 OF 27. REMARKS: On respective sheets from 5 OF 27 to 27 OF 27.		
TEST SPECIFICATIONS As per sheet 4 OF 27.		
PREPARED BY 	CHECKED BY 	APPROVED BY Kapil J. Sharma

- NOTE:**
1. This report relates only to the particular sample received for testing in good condition at ERDA.
 2. This report cannot be reproduced in part under any circumstances.
 3. Publication of this report requires prior permission in writing from Director, ERDA.
 4. Only test asked for by customer have been carried out.
 5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arisen.

Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.



TC 2429308



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



REPORT NO.: RP-1718-050430

SHEET 2 OF 27

DATE: 10.01.2018

Enclosures	
1. Oscillogram No.	1352/01 to 1352/05
2. Photograph No.	1718-014127/1261
3. Test circuit diagram No.	OLSC/DTC/05
4. Drawing No.	RPTPL/RP/02 Rev.:00 Sheet No. 00 RPTPL/OGA/02 Rev.:00 Sheet No. 01 RPTPL/IC/02 Rev.:00 Sheet No. 01 RPTPL/CD/02 Rev.:00 Sheet No. 00


PREPARED BY


CHECKED BY



TC 2417960



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1718-050430

SHEET 3 OF 27

DATE: 10.01.2018

TECHNICAL SPECIFICATIONS OF TEST OBJECT ASSIGNED BY CUSTOMER

- | | |
|---------------------------------------------|---------------------------------------------------------------------------------|
| 1. Name of manufacturer | : RAJASTHAN POWERGEN TRANSFORMER PVT. LTD. |
| 2. Equipment | : 16 kVA Single Phase Distribution Transformer |
| 3. Standard No. | : IS 1180 (Part 1): 2014 [Amendment No. 1& 2], IS 2026, as per customer request |
| 4. Serial No. | : RPTPL/16KVA/2017/18/001 |
| 5. Energy efficiency level | : 2 |
| 6. Type | : Outdoor, Oil cooled |
| 7. kVA rating | : 16 |
| 8. Rated voltage H.V.(volts) | : 6351 |
| L.V. (volts) | : 240 |
| 9. Rated current H.V. (Amp.) | : 2.52 |
| L.V.(Amp.) | : 66.67 |
| 10. Number of phases | : 1 |
| 11. Frequency (Hz.) | : 50 |
| 12. Type of cooling | : ONAN |
| 13. Temperature rise of oil/winding | : 35°C/40°C |
| 14. Percentage Impedance | : 4.0% |
| 15. Primary winding conductor | : Polyesterimide enamel class H
Aluminium wire, bare dia.2.50mm |
| 16. Secondary winding conductor | : DPC Aluminium strip, bare size
(14.0mm x 3.0mm) x 2 Nos. in parallel |
| 17. Quantity of oil (Litre) | : 54 |
| 18. Weight of oil (kg.) | : 47 |
| 19. Weight of core and winding assly. (kg.) | : 119 |
| 20. Total weight (kg.) | : 208 |
| 21. Polarity | : Subtractive |
| 22. Vector group | : 1-Phase |
| 23. Year of manufacture | : 2017 |
| 24. Insulation Level L.V. | : 03kVrms |
| 25. Total losses at 75°C (Watts) | : 82Max. (at 50 % load) |
| 26. Total losses at 75°C (Watts) | : 224Max. (at 100 % load) |

TC 2429307

PREPARED BY

CHECKED BY





ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



SHEET No. 4 of 27

REPORT NO.: RP-1718-050430		Date: 10 Jan 2018
Sr. No.	TEST DETAILS	TEST SPECIFICATION
1	Measurement of winding resistance	As per cl.no.21.2.a of IS: 1180 PART 1-2014
2	Measurement of voltage ratio and check of phase displacement	As per cl.no.21.2.b of IS: 1180 PART 1-2014
3	Measurement of short-circuit impedance and load loss at 50 percent and 100 percent load	As per cl.no.21.2.c of IS: 1180 PART 1-2014
4	Measurement of no-load loss and current	As per cl.no.21.2.d of IS: 1180 PART 1-2014
5	Total losses at 50% load	As per cl.no. 8.8 of IS: 1180 PART 1-2014
6	Total losses at 100% load	As per cl.no. 8.8 of IS: 1180 PART 1-2014
7	Measurement of no-load loss and current at 90%,110% and 112.5 % of rated voltage	As per customer`s requirement
8	No load current at 112.5 percent voltage:	As per cl.no.21.4.c of IS: 1180 PART 1-2014
9	Measurement of insulation resistance	As per cl.no.21.2.e of IS: 1180 PART 1-2014
10	Separate-source voltage withstand test	As per cl.no.21.2.g of IS: 1180 PART 1-2014
11	Induced over-voltage withstand test	As per cl.no.21.2.f of IS: 1180 PART 1-2014
12	Temperature-rise test	As per customer`s requirement testing procedure followed as per cl.no.21.3.b of IS: 1180 PART 1-2014
13	Oil leakage test	As per cl.no.21.2.j of IS: 1180 PART 1-2014
14	Pressure test (routine test)	As per cl.no.21.2.h of IS: 1180 PART 1-2014
15	Pressure test (type test)	As per cl.no.21.3.d of IS: 1180 PART 1-2014
16	Permissible flux density and over fluxing	As per cl.no. 8.9 of IS: 1180 PART 1-2014
17	Measurement of the Harmonics of the No load current	As per customer`s requirement, testing procedure followed as per cl. no. 10.6 of IS 2026 (Part 1):2011
18	Lightning Impulse test	As per cl.no.21.3.a of IS: 1180 PART 1-2014
19	Short circuit withstand test	As per cl.no.21.3.c of IS: 1180 PART 1-2014
20	Determination of sound levels	As per cl.no.21.4.a of IS: 1180 PART 1-2014
21	Paint adhesion tests	As per cl.no.21.4.d of IS: 1180 PART 1-2014
PREPARED BY		CHECKED BY

TC 2429306





ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



Certificate No. : TC-5389

SHEET No. 5 of 27

REPORT NO.: RP-1718-050430		Date: 10 Jan 2018		
Sr. No.	Particular of Tests & Cl.No.	Requirement as per Specification	Obtained Value	Remarks
1	Measurement of winding resistance (As per cl.no.21.2.a of IS: 1180 PART 1-2014) Top oil temperature: 24.9 °C HV winding 1.1 – 1.2(N): LV winding 2.1 – 2.2(n):	--	7.9755 Ω 12.446 mΩ	---
2	Measurement of voltage ratio and check of phase displacement (As per cl.no.21.2.b of IS: 1180 PART 1-2014) Measurement of voltage ratio 1.1-1.2(N) and 2.1-2.2(n): Polarity :	26.463(± 0.5%) Subtractive	26.470 Subtractive	Conforms
3	Measurement of short-circuit impedance and load loss at 50 percent and 100 percent load (As per cl.no.21.2.c of IS: 1180 PART 1-2014) At 50% load: Tested with 1.2601 Amps (on HV side) Frequency: 50.061 Hz Top oil temperature: 22.9°C Test current (Amps) Impedance voltage (Volts) Measured load loss (Watts) Impedance voltage (%) (Computed to 50% load) At 22.9°C At 75°C Load loss (Watts) (Computed to 50% load) At 22.9°C At 75°C	--	1.2601 126.090 29.18 1.985 1.987 29.175 34.195	---

TC 2429305

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



SHEET No. 6 of 27

REPORT NO.: RP-1718-050430		Date: 10 Jan 2018		
Sr. No.	Particular of Tests & Cl.No.	Requirement as per Specification	Obtained Value	Remarks
	At 100% load: Tested with 2.5212 Amps (on HV side) Frequency: 50.028 Hz Top oil temperature: 22.9°C Test current (Amps) Impedance voltage (Volts) Measured load loss (Watts) Impedance voltage (%) (Computed to 100% load) At 22.9°C At 75°C Load loss (Watts) (Computed to 100% load) At 22.9°C At 75°C	4 (IS Tol.) --	2.5212 252.380 117 3.972 3.995 116.889 136.938	Conforms ---
4	Measurement of no-load loss and current (As per cl.no.21.2.d of IS: 1180 PART 1-2014) Tested with mean value of voltage 240.580 volts (On LV side) Frequency : 50.051 Hz RMS Voltage (Volts) No-load current (Amps) Measured no-load loss (Watts) Corrected no-load loss (Watts)	-- --	240.320 0.19793 40.71 40.754	---
5	Total losses at 50% load (As per cl.no. 8.8 of IS: 1180 PART 1-2014)	Max. 82	74.949	Conforms
6	Total losses at 100% load (As per cl.no. 8.8 of IS: 1180 PART 1-2014)	Max. 224	177.692	Conforms

PREPARED BY

CHECKED BY



TC 2429304



(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



SHEET No. 7 of 27

REPORT NO.: RP-1718-050430

Date: 10 Jan 2018

Sr. No.	Particular of Tests & Cl.No.	Requirement as per Specification	Obtained Value	Remarks
7	<p>Measurement of no-load loss and current at 90%,110% and 112.5 % of rated voltage (As per customer`s requirement) At 90% of rated voltage Tested with average 216.4 volts (On LV side) Frequency : 49.964 Hz <div style="text-align: right;">RMS Voltage (Volts)</div> <div style="text-align: right;">No-load current (Amps)</div> <div style="text-align: right;">Measured no-load loss (Watts)</div> <div style="text-align: right;">Corrected no-load loss (Watts)</div> At 110% of rated voltage Tested with average 264.4 volts (On LV side) Frequency : 49.95 Hz <div style="text-align: right;">RMS Voltage (Volts)</div> <div style="text-align: right;">No-load current (Amps)</div> <div style="text-align: right;">Measured no-load loss (Watts)</div> <div style="text-align: right;">Corrected no-load loss (Watts)</div> At 112.5% of rated voltage Tested with average 270.41 volts (On LV side) Frequency : 49.963 Hz <div style="text-align: right;">RMS Voltage (Volts)</div> <div style="text-align: right;">No-load current (Amps)</div> <div style="text-align: right;">Measured no-load loss (Watts)</div> <div style="text-align: right;">Corrected no-load loss (Watts)</div> </p>	--	216.010 0.17169 32.61 32.669 264.020 0.24341 50.27 50.342 270.200 0.26195 53.04 53.081	---
8	<p>No load current at 112.5 percent voltage: (As per cl.no.21.4.c of IS: 1180 PART 1-2014)</p> <p>Test voltage of 112.5 percent of rated voltage at rated frequency was applied to the L.V. winding terminals and H.V. winding terminals were kept open circuited. No load current was recorded.</p>			Conforms

PREPARED BY

CHECKED BY



TC 2417925



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



SHEET No. 8 of 27

REPORT NO.: RP-1718-050430		Date: 10 Jan 2018		
Sr. No.	Particular of Tests & Cl.No.	Requirement as per Specification	Obtained Value	Remarks
	Test voltage (Volts) No load current (Amps) No Load Current (%)	Max. 6.0	270.020 0.25956 0.389	
9	Measurement of insulation resistance (As per cl.no.21.2.e of IS: 1180 PART 1-2014) Top oil temperature: 25.8 °C IR value measured between HV winding to Earth at 1000 V DC LV winding to Earth at 1000 V DC HV winding to LV winding at 1000 V DC	-- -- --	151.8 GΩ 96.0 GΩ 181.2 GΩ	---
10	Separate-source voltage withstand test (As per cl.no.21.2.g of IS: 1180 PART 1-2014) on HV winding: The power frequency test voltage of 3 kV ac, rms was applied between the HV winding and earth. The tank and LV winding were shorted together and earthed. The test voltage was applied for 60 seconds. on LV winding: The power frequency test voltage of 3 kV ac, rms was applied between the LV winding and earth. The tank and HV winding were shorted together and earthed. The test voltage was applied for 60 seconds.	Transformer shall withstand power frequency voltage of 3kV for 60 seconds. Transformer shall withstand power frequency voltage of 3kV for 60 seconds.	Withstood Withstood	Conforms
11	Induced over-voltage withstand test (As per cl.no.21.2.f of IS: 1180 PART 1-2014) The test voltage of 756 Volts, 1- phase was applied to the LV winding of the transformer. The supply frequency was maintained at 150 Hz. The test voltage was applied for 40 seconds.	Transformer shall withstand 756 volts at 150 Hz frequency for 40 seconds.	Withstood	Conforms

TC 2429303

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



SHEET No. 9 of 27

REPORT NO.: RP-1718-050430		Date: 10 Jan 2018		
Sr. No.	Particular of Tests & Cl.No.	Requirement as per Specification	Obtained Value	Remarks
12	<p>Temperature-rise test (As per customer's requirement testing procedure followed as per cl.no.21.3.b of IS: 1180 PART 1-2014)</p> <p>Before starting test, the dimensions of tank were measured & recorded.</p> <p>Size of tank: DIA-440 mm, H-635 mm</p> <p>Losses fed for temperature-rise test were 224 Watts (As specified by the customer)</p> <p>Specified losses were fed to the transformer (i.e. supply was connected to HV winding and LV winding kept short circuited) till steady state temperature rise was attained. Top oil temperature was recorded hourly. After steady state condition, the losses were brought down in reference to the rated current one hour prior to shut down.</p> <p>At the shut down, the hot winding resistances were measured and temperature rise calculated.</p> <p>A) Top oil temperature-rise B) Winding temperature-rise (Resistance method) 1) HV winding 2) LV winding C) Ambient temperature at shutdown D) Time of shutdown (Hrs)</p>			Conforms
13	<p>Oil leakage test (As per cl.no.21.2.j of IS: 1180 PART 1-2014)</p>			Conforms

TC 2429302

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



SHEET No. 10 of 37

REPORT NO.: RP-1718-050430				Date: 10 Jan 2018		
Sr. No.	Particular of Tests & Cl.No.			Requirement as per Specification	Obtained Value	Remarks
	The assembled transformer with all fittings including bushings in position was tested at a pressure at the top equivalent to the head that was available at the base of the tank for 6 hours.			There should be no leakage at any point	No leakage observed	
14	Pressure test (routine test) (As per cl.no.21.2.h of IS: 1180 PART 1-2014) The transformer tank was tested at an air pressure of 35 kPa above atmosphere pressure maintained inside the tank for 10 min.			There should be no leakage at any point	No leakage observed	Conforms
15	Pressure test (type test) (As per cl.no.21.3.d of IS: 1180 PART 1-2014) The transformer tank was subjected to air pressure of 100 kPa above atmospheric pressure for 30 minutes.			There should be no leakage at any point and there is no deformation of tank.	No leakage observed and no deformation of tank observed.	Conforms
16	Permissible flux density and over fluxing (As per cl.no. 8.9 of IS: 1180 PART 1-2014) (a) Overfluxing test: Test voltage at rated frequency was applied to the L.V. winding terminals and H.V. winding terminals were kept open circuited and exciting current was recorded at 100% and 112.5% of rated voltage. Rated full load current of L.V. winding = 66.67 Amps					Conforms
	% of rated voltage	Test voltage (Volts)	No load current (Amps)			
	100%	240.32	0.19793	Max. 3.0%	0.297%	

PREPARED BY

CHECKED BY



TC 2417928



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33



Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



SHEET No. 11 of 27

REPORT NO.: RP-1718-050430				Date: 10 Jan 2018		
Sr. No.	Particular of Tests & Cl.No.			Requirement as per Specification	Obtained Value	Remarks
	112.5%	270.02	0.25956	Max. 6.0%	0.389%	
	(b) Permissible flux density: Transformer was opened for the measurement of total area of the core. The core was dismantled and various dimensions of width and thickness were measured to calculate the total area of the core. Number of turns of L.V. winding were counted. Total measured area of the core: 13454.80 mm² Stacking factor: 0.96 (As specified by customer) Total no. of turns of L.V winding: 60 per phase Rated voltage of L.V winding: 240 V per phase Rated frequency: 50 Hz Flux density is calculated with +12.5 percent combined voltage and frequency variation from rated voltage and frequency. 112.5 % of voltage/phase Flux density= ----- (4.44 x Freq.(Hz) x Turns x Area of Core)					
				1.9 Tesla	1.57 Tesla	
PREPARED BY  CHECKED BY 						



TC 2417929



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



SHEET No. 12 of 27

REPORT NO.: RP-1718-050430

Date: 10.01.2018

Sr. No.	Particulars of test and clause no.	Requirement as per specification.	Obtained value	Remarks
17	Measurement of the Harmonics of the No-load current (As per customer's request testing procedure followed as per cl. no. 10.6 of IS 2026 (Part 1):2011)	The harmonics of the no-load current in the three phases shall be measured and magnitude of the harmonics shall be expressed as a percentage of the fundamental component.	Refer table 1 for individual current harmonics components & individual voltage harmonics components measured at LV side at rated voltage i.e. 240 V Current THD: 29.84% Voltage THD: 1.51%	---
Prepared by:		Checked by:		



TC 2417963

REPORT NO.: RP-1718-050430

Date: 10.01.2018

TABLE-1 : Harmonics in voltage and current (as a percentage of fundamental)

Harmonic order	Current I_R in %	Current I_R in Amps	Voltage V_{RY} in %
1	100.00	0.19	100.00
2	14.89	0.03	0.04
3	21.61	0.04	0.27
4	9.26	0.02	0.06
5	8.68	0.02	1.42
6	4.46	0.01	0.05
7	3.69	0.01	0.30
8	1.88	0.00	0.02
9	1.44	0.00	0.10
10	0.82	0.00	0.02
11	0.23	0.00	0.21
12	0.39	0.00	0.01
13	0.31	0.00	0.10
14	0.19	0.00	0.01
15	0.36	0.00	0.12
16	0.09	0.00	0.00
17	0.53	0.00	0.12
18	0.11	0.00	0.01
19	0.48	0.00	0.10
20	0.07	0.00	0.00
21	0.15	0.00	0.03
22	0.10	0.00	0.01
23	0.05	0.00	0.02
24	0.08	0.00	0.01
25	0.12	0.00	0.02
THD %	29.84		1.51
Parameter measured	0.20 A		240.32 V

Prepared by 

Checked by 

TC 2429301





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO.: RP-1718-050430
DATE : 10/01/2018

SHEET NO.: 14 of 27

18.Lightning Impulse Test (As per Cl. No.21.3.a of IS 1180 (part 1) : 2014 Amendment 1 & 2 & Test voltage was specified by the customer & Test procedure was followed as per IS : 2026- (part- III),2009, Cl. No. 14

Waveform	Comment	Ut / kVp	T1 / μ s	T2 / μ s	Tc / μ s
1.1-POLE					
1	60% LI RW	-44.734	1.292	53.765	
2	100% LI FW	-75.119	1.287	54.060	
3	60% LI CRW	-50.357	1.303		2.561
4	110% LI CFW	-83.811	1.308		2.723
5	110% LI CFW	-83.766	1.308		3.247
6	100% LI FW	-74.265	1.298	53.969	
7	100% LI FW	-74.759	1.290	54.096	

REMARKS: From the observation of enclosed oscillographic records , it is concluded that the transformer **conforms** to the requirements of the above mentioned standard with respect to the test carried out.



PREPARED BY

CHECKED BY

TC 2417882



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO.: RP-1718-050430

SHEET NO.: 15 of 27

DATE : 10/01/2018





Fig.: 1
 $U_p = -44.73 \text{ kV}$
 $T_1 = 1.29 \mu\text{s}$
 $T_2 = 53.76 \mu\text{s}$
 $T_c = \mu\text{s}$



Comment: 60% LI RW





Fig.: 2
 $U_p = -75.12 \text{ kV}$
 $T_1 = 1.29 \mu\text{s}$
 $T_2 = 54.06 \mu\text{s}$
 $T_c = \mu\text{s}$



Comment: 100% LI FW

TC 2417883

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



TEST REPORT NO.: RP-1718-050430

SHEET NO.: 16 of 27

DATE : 10/01/2018





Fig.: 3

$U_p = -50.36 \text{ kV}$

$T_1 = 1.30 \mu\text{s}$

$T_2 = \mu\text{s}$

$T_c = 2.56 \mu\text{s}$



Comment: 60% LI CRW





Fig.: 4

$U_p = -83.81 \text{ kV}$

$T_1 = 1.31 \mu\text{s}$

$T_2 = \mu\text{s}$

$T_c = 2.72 \mu\text{s}$



Comment: 110% LI CFW

TC 2417884

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO.: RP-1718-050430

SHEET NO.: 17 of 27

DATE : 10/01/2018





Fig.: 5
 $U_p = -83.77$ kV
 $T_1 = 1.31$ μ s
 $T_2 = \mu$ s
 $T_c = 3.25$ μ s



Comment: 110% LI CFW





Fig.: 6
 $U_p = -74.27$ kV
 $T_1 = 1.30$ μ s
 $T_2 = 53.97$ μ s
 $T_c = \mu$ s



Comment: 100% LI FW

TC 2417885

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



TEST REPORT NO.: RP-1718-050430

SHEET NO.: 18 of 27

DATE : 10/01/2018




Fig.: 7
 $U_p = -74.76$ kV
 $T_1 = 1.29$ μs
 $T_2 = 54.10$ μs
 $T_c = \mu s$

Comment: 100% LI FW



TC 2417886

PREPARED BY

CHECKED BY



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1718-050430

SHEET 19 OF 27

DATE: 10.01.2018

19. Short-circuit withstand test

(As per Cl. No. 17 & 21.3 c of IS 1180 (Part 1): 2014)

ROUTINE TEST RESULTS BEFORE SHORT CIRCUIT

a) MEASUREMENT OF WINDING RESISTANCE

Measurement at oil temperature: 20.0°C	
LV Winding resistance (mΩ)	HV Winding resistance (Ω)
2.1-2.2n	1.1-1.2N
12.413	7.8525

b) MEASUREMENT OF VOLTAGE RATIO AND CHECK OF POLARITY

Polarity: Subtractive was verified

Measured turns ratio between Terminals	Rated turns Ratio	Difference (%)
1.1-1.2N/2.1-2.2n		
26.491	26.463	0.106

c) MEASUREMENT OF SHORT-CIRCUIT IMPEDANCE AND LOAD LOSS(at 100 % load)

Oil temperature: 19.9°C

Test current (Amp.)	Impedance voltage (V)	Frequency (Hz.)	Load loss measured (Watts)	Impedance Voltage (%Z) at 50 Hz.	Load loss computed at 75°C (Watts)	%Z at 75°C
2.517	252.118	50.047	117.060	3.970	139	3.997

d) MEASUREMENT OF LOAD LOSS(at 50 % load)

Oil temperature: 19.9°C

Test current (Amp.)	Impedance voltage (V)	Frequency (Hz.)	Load loss measured (Watts)	Load loss computed at 75°C (Watts)
1.253	125.401	50.054	28.993	35

TC 2428301

PREPARED BY

CHECKED BY



REPORT NO.: RP-1718-050430
DATE: 10.01.2018

SHEET 20 OF 27

e) MEASUREMENT OF NO-LOAD LOSS AND CURRENT

Oil temperature: 19.9°C

Applied Voltage (V)	Current (Amp.)	Frequency (Hz.)	Losses Measured (Watts)
240.020	0.201	50.083	41

- Total losses at 75°C: 76 Watts (at 50 % load)
- Total losses at 75°C: 180 Watts (at 100% load)

f) MEASUREMENT OF INSULATION RESISTANCE

Oil temperature: 20.0°C, Measured at Voltage: 1000 V DC

	IR value (MΩ)
HV to LV winding	> 2000
HV winding to LV + EARTH	> 2000
LV winding to HV + EARTH	> 2000

g) INDUCED OVER-VOLTAGE WITHSTAND TEST

Sr. No.	Test	Applied voltage (V)	Applied Freq. (Hz.)	Duration (sec.)	Remarks
1.	Between LV windings with HV terminal open & neutral terminal earthed.	756	150	40	Withstood

h) SEPARATE-SOURCE VOLTAGE WITHSTAND TEST

Sr. no.	Test	Applied voltage (kV)	Duration (sec.)	Remarks
1.	Between HV winding and LV winding connected to the tank and earth	03	60	Withstood
2.	Between LV winding and HV winding connected to the tank and earth	03	60	Withstood

TC 2428302

PREPARED BY

CHECKED BY





ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1718-050430

SHEET 21 OF 27

DATE: 10.01.2018

SHORT-CIRCUIT WITHSTAND TEST:

The verification of short-circuit withstand test was performed on the transformer by connecting the secondary winding to single phase of the source and primary winding short circuited using synchronization switch. The test conducted with short circuiting of primary winding; follow the application of the voltage to the secondary winding of transformer as per schematic circuit diagram No. OLSC/DTC/05.

Condition of the equipment under test: As after routine tests.

Supply Frequency: 50 Hz.

Test No.	Oscillo-gram No.	Applied voltage (Vrms)	Short circuit current on LV (A)		Duration (sec.)	Remarks
			Peak	RMS		
1.	1352/01	-	2956	1316	0.1	Calibration Shot
2.	1352/02	240	3702	1791	0.5	No Abnormality
3.	1352/03	240	3734	1835	0.5	No Abnormality
4.	1352/04	240	3525	1790	0.5	No Abnormality
5.	1352/05	240	3668	1715	2.0	Thermal shot No Abnormality

PREPARED BY

CHECKED BY

TC 2428303





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



REPORT NO.: RP-1718-050430

SHEET 22 OF 27

DATE: 10.01.2018

Measurement of the % reactance during the short circuit test

LV winding was short circuited. AC supply was connected to HV winding to pass test current. Before the short circuit test and after each shot, the percentage reactance was measured.

Sr. No.	Measurement performed		Measured value of % reactance at 50 Hz.	%Change in % reactance
1.	Before test		3.90	-
2.	After the test no.	2.	3.91	0.26
3.	After the test no.	3.	3.91	0.26
4.	After the test no.	4.	3.91	0.26
5.	After the test no.	5.	3.91	0.26

PREPARED BY

CHECKED BY

TC 2428304





REPORT NO.: RP-1718-050430
DATE: 10.01.2018

SHEET 23 OF 27

ROUTINE TEST RESULTS AFTER SHORT CIRCUIT

a) MEASUREMENT OF WINDING RESISTANCE

Measurement at oil temperature: 25.2°C	
LV Winding resistance (mΩ)	HV Winding resistance (Ω)
2.1u-2.2n	1.1U-1.2N
12.693	8.0125

b) MEASUREMENT OF VOLTAGE RATIO AND CHECK OF POLARITY

Polarity: Subtractive was verified

Measured turns ratio between Terminals	Rated turns Ratio	Difference (%)
1.1U-1.2N/2.1u-2.2n		
26.478	26.463	0.057

c) MEASUREMENT OF SHORT-CIRCUIT IMPEDANCE AND LOAD LOSS(at 100 % load)

Oil temperature: 26.2°C

Test current (Amp.)	Impedance voltage (V)	Frequency (Hz.)	Load loss measured (Watts)	Impedance Voltage (%Z) at 50 Hz.	Load loss computed at 75°C (Watts)	%Z at 75°C
2.512	251.512	49.769	125.410	3.991	144	4.014

d) MEASUREMENT OF LOAD LOSS(at 50 % load)

Oil temperature: 26.2°C

Test current (Amp.)	Impedance voltage (V)	Frequency (Hz.)	Load loss measured (Watts)	Load loss computed at 75°C (Watts)
1.248	124.858	49.774	30.909	36

PREPARED BY

CHECKED BY

TC 2428305



REPORT NO.: RP-1718-050430

SHEET 24 OF 27

DATE: 10.01.2018

e) MEASUREMENT OF NO-LOAD LOSS AND CURRENT

Oil temperature: 26.2°C

Applied Voltage (V)	Current (Amp.)	Frequency (Hz.)	Losses Measured (Watts)
240.010	0.201	50.004	41

- Total losses at 75°C: 77 Watts (at 50 % load)
- Total losses at 75°C: 185 Watts (at 100% load)

f) MEASUREMENT OF INSULATION RESISTANCE

Oil temperature: 25.2°C, Measured at Voltage: 1000 V DC

	IR value (MΩ)
HV to LV winding	> 2000
HV winding to LV + EARTH	> 2000
LV winding to HV + EARTH	> 2000

g) INDUCED OVER-VOLTAGE WITHSTAND TEST

Sr. No.	Test	Applied voltage (V)	Applied Freq. (Hz.)	Duration (sec.)	Remarks
1.	Between LV windings with HV terminal open & neutral terminal earthed.	756	150	40	Withstood

h) SEPARATE-SOURCE VOLTAGE WITHSTAND TEST

Sr. no.	Test	Applied voltage (kV)	Duration (sec.)	Remarks
1.	Between HV winding and LV winding connected to the tank and earth	03	60	Withstood
2.	Between LV winding and HV winding connected to the tank and earth	03	60	Withstood

Observation after test: The transformer was untanked and inspected.

- Condition of conductor, core and clamping:
 - No visible damage, deformation or displacement.
- Condition of oil : Clear

Results: 1) % Change in % reactance is within tolerance limits as per standard.

2) The results of routine tests carried out before and after the short-circuit withstand test found within limits as per standard.ksp

PREPARED BY

CHECKED BY

TC 2428306





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**TEST REPORT NO: RP-1718-050430****DATE: 10/01/2018****SHEET 25 OF 27****Particulars of Tests & Cl. No.:**

20. Determinations of sound levels [Cl. No. 21.4.a of IS 1180 (Part 1): 2014 with 2 amendments & Cl. No. 13 of IS 2026 (Part 10): 2009]

Condition of transformer

Transformer was energized at no load condition & excited at the rated voltage of sinusoidal waveform & rated frequency.

Details of equipment used:**Name:** Sound level meter **Make:** Lutron
Meter Type: Type 1 **Serial No.:** I.62852
Calibration Report No. & Date: NCQC-M/141117/01, Dt. 27/11/2017**TEST RESULTS:****A-Weighted sound pressure levels of the background noise**

Sr. No.	Measurement Locations (Refer Sketch Below)	At the start of test dB(A)	At the end of test dB(A)
1	A	44.8	44.6
2	B	45.1	44.8
3	C	44.3	44.3
4	D	44.6	44.5
5	E	44.7	44.6
6	F	44.4	44.7
7	G	43.9	44.4
8	H	44.2	44.3
9	I	44.1	44.2
10	J	44.3	44.5
Arithmetic Average $\overline{L_{bgA}}$		44.5	44.5

A-Weighted sound pressure levels at energized condition L_{pAi}

Sr. No.	Measurement Locations (Refer Sketch Below) dB(A)	L_{pAi} dB(A)
1	A	46.4
2	B	46.1
3	C	46.9
4	D	46.8
5	E	47.1
6	F	47.3
7	G	47.6
8	H	47.9
9	I	47.5
10	J	47.8
Arithmetic Average $\overline{L_{pA0}}$		47.2

PREPARED BY

CHECKED BY



TC 2406661



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO: RP-1718-050430

DATE: 10/01/2018

SHEET 26 OF 27

TEST PARAMETERS:

Measurement distance : 1 m,

Microphone Spacing: 1 m

Measurement made : Half of the height of the transformer tank

Method followed: Sound pressure measurement as per Cl. No. 11, 11.3 & Table 2 of IS 2026 (Part 10): 2009.

Length of prescribed contour: 10.4 m

Transformer Tank Height: 0.635 m


A-Weighted sound pressure level (L_{pA0}):	47.2 dB(A)
------------------------------------------------	------------

Corrected average A-weighted sound pressure level (L_{pA}):	41.3 dB(A)
-----------------------------------------------------------------	------------

Calculated A- weighted sound power level (L_{WA}) :	50.4 dB(A)
---------------------------------------------------------	------------

Requirement: Guaranteed value of sound pressure level is considered as 48 dB(A) as mentioned in customer's letter.

REMARKS: Transformer conforms to the requirement of guaranteed value of Sound pressure level.



Sketch showing the locations of sound measurement

PREPARED BY

CHECKED BY



TC 2406662

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.



EPABX: +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33,

Fax : +91 (0265) 2638382,

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT No.: RP-1718-050430		DATE: 10-01-2018		SHEET 27 OF 27	
Sr. No.	Particular of Tests and Cl. No.	Requirements as per specification	Obtained value	Remarks	
21.	Paint Adhesion Test at 29°C & 25 % RH Test Method A – X-cut tape test (Test procedure followed as per ASTM D 3359-2017, Cl. No. 8) Cl. No. 21.4.d of IS 1180 (Part 1): 2014 - Adhesion strength of pressure sensitive tape 6.7 N/cm.	--	Observation 1- 5A – No peeling or removal was observed at the location. Observation 2- 5A – No peeling or removal was observed at the location. Observation 3- 5A – No peeling or removal was observed at the location.	--	
PREPARED BY 		CHECKED BY 			



2224572



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : <http://www.erda.org>



REPORT NO.: RP-1718-050430

DATE: 10.01.2018



OSCILLOGRAM NO. : 1352/01



TC 2405007



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : <http://www.erda.org>



REPORT NO.: RP-1718-050430

DATE: 10.01.2018



TC 2405008

OSCILLOGRAM NO. : 1352/02





(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33


Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



DATE: 10.01.2018



OSCILLOGRAM NO. : 1352/03

TC 2405009





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : <http://www.erda.org>




REPORT NO.: RP-1718-050430

DATE: 10.01.2018



OSCILLOGRAM NO. : 1352/04



TC 2405010



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : <http://www.erda.org>



REPORT NO.: RP-1718-050430

DATE: 10.01.2018



TC 2405011

OSCILLOGRAM NO.: 1352/05



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1718-050430


DATE: 10.01.2018



DISTRIBUTION TRANSFORMER			
RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.			
JALORE, RAJASTHAN			
1 PHASE TRANSFORMER			
STANDARD	IS : 1180 (Part-1)/2014	ENERGY EFFICIENCY LEVEL	2
KVA	16	MAX TOTAL LOSS AT 50% RATED LOAD W	82
VOLTS AT NO LOAD(V)	HV 11000 / 3	MAX TOTAL LOSS AT 100% RATED LOAD W	224
	LV 240	TYPE OF COOLING	ONAN
BIL (kV Peak)	HV 75	TEMP RISE OIL °C	35
	LV NA	WDG °C	40
CURRENT (A)	HV 2.52	MASS OF OIL kg	47
	LV 66.67	TOTAL MASS kg	208
FREQUENCY Hz	50	VOLUME OF OIL Ltr	54
VECTOR GROUP	1-PHASE	MONTH & YEAR OF MFG	/2017
IMPEDANCE VOLT %	4	SERIAL NO. & P	TVL/16KVA/1447
DISPATCH DATE		EXPIRY DATE G.P	
CONDUCTOR MATERIAL	ALUMINIUM		
CUSTOMER	AVVNL		
P.O. No.			
MADE IN INDIA			

SUBTRACTIVE POLARITY			
Signal Light	ICB	1.1	2.1
		1.2(N)	2.2(N)
HV FUSE LINK		1.2(N)	2.2(N)

TC 2428298



ELECTRICAL RESEARCH AND
DEVELOPMENT ASSOCIATION

SCHEMATIC CIRCUIT DIAGRAM

DRN. BY	CHKD.	DATE	DRG. NO.
S.B.S.	A.V.C.	30-9-01	OLSC/DTC/05



REPORT NO.: PP-1778-050430
DATE: 10.01.2018

4 HOLES
of Ø3.6mm

DISTRIBUTION TRANSFORMER RAJASTHAN POWERGEN TRANSFORMER PVT. LTD. JALORE, RAJASTHAN

1 PHASE TRANSFORMER

STANDARD IS: 1180 (Part-1) 2014

KVA 16

VOLTS AT NO LOAD (V) HV 11000/43

LV 240

BIL (KV Peak) HV 75

LV NA

CURRENT (A) HV 2.52

LV 56.67

FREQUENCY HZ 50

VECTOR GROUP 1-PHASE

IMPEDANCE VOLT % 4

DISPATCH DATE

CONDUCTOR MATERIAL ALUMINIUM

CUSTOMER AVNUL

P.O. No.

ENERGY EFFICIENCY LEVEL 2

MAX. TOTAL LOSS AT 50% RATED LOAD W 82

MAX. TOTAL LOSS AT 100% RATED LOAD W 224

TYPE OF COOLING ONAN

TEMP. RISE OIL °C 35

WDG °C 40

MASS OF OIL kg 47

TOTAL MASS kg 208

VOLUME OF OIL Ltr 54


MONTH & YEAR OF MFG. 12/2017

SERIAL NO. RPTPL/16KVA/2017/100

EXPIRY DATE G.R.

MADE IN INDIA

SUBTRACTIVE POLARITY




Test Report No. RP-1718-050430
Date 10.01.2018
Product 16 KVA 1-Ø D.T
Verified by K. S. Patel
Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with *x

NOTES:-

1. ** MARKED ITEMS SHOULD BE FINISHED AT THE TIME OF DISPATCH.
2. ALL LETTERS, FIGURES ETC. TO BE ENGRAVED & POLISHED BLACK.
3. MATERIAL - STAINLESS STEEL 20 WITH TOLERANCE ± 0.1 MM. THICK.
4. ALL DIMENSIONS ARE IN MM.

00	23.08.17				ORIGINAL ISSUE.
Rev	Date	Draw	Checked	Approved	Description
Title: RATING & DIAGRAM PLATE					
Rating: 16 KVA, 11/3/0.240 KV, 1Ø, 50 HZ, TRF.			Work Order:		
Drawing No.: RPTPL/RP/02			Rev.: 00	Sheet No.: 00	Total Sheets: 00
RAJASTHAN POWERGEN TRANSFORMER P. LTD. Karola - Bhinnal Road, Karola, Sanchari - 343041 Dist - Jalore, Rajasthan (India)			All dimensions are in millimeters unless otherwise stated. If in doubt - Please Ask!		
			Scale: NTS		



AIR CLEARANCES (MM)

VOLTAGE	H.V.	L.V. (unshielded)
PHASE TO PHASE	NA	NA
PHASE TO EARTH	148	20

WEIGHTS / QTY.

TRANSFORMER OIL	Ltrs.	54
TOTAL TRANSFORMER	Kg.	208
TRANSFORMER OIL	Kg.	47
TANK & FITTINGS	Kg.	42
INTERNAL ASSEMBLY	Kg.	119

Test Report No. 10-1247-072430
 Date 10.01.2017 (MOUNTING)
 Product 16KVA 1-0 D.T
 Verified by K.S. Patel
 Verification of this drawing by ERDA is limited to relevant dimensional checks only.
 Verified dimensions are marked with asterisk (*)



OUTLINE GENERAL ARRANGEMENT

S. No.	Description	Qty.
1	Tank Earthing terminal	1
2	Pressure relief device	1
3	L.V. Bushing	2
4	Top cover fan	1
5	H.V. Neutral bushing	1
6	H.V. Bushing	1
7	Rating & terminal marking plate	1
8	L.V. Terminal marking	1 set
9	Earthing terminal (LV host)	1 set
10	LV cable box	1
11	Signal light	1
12	Internal Circuit Breaker handle	1
13	Oil Level Gauge	1
14	Lifting lugs for complete unit	2
15	Pole mounting bracket (as per spec)	2
16	Top cover with yellow cover	1
17	Oil Filling hole with yellow cover	1
18	Top cover fan	1
19	Oil Filling hole with yellow cover	1
20	Top cover with yellow cover	1
21	Terminal marking plate	1

RAJASTHAN POWERGEN TRANSFORMER P. LTD.

At direction of the Rajasthani Power Generation Corporation Ltd. (Rajasthani Power Generation Corporation Ltd.)

At direction of the Rajasthani Power Generation Corporation Ltd. (Rajasthani Power Generation Corporation Ltd.)

At direction of the Rajasthani Power Generation Corporation Ltd. (Rajasthani Power Generation Corporation Ltd.)

RAJASTHAN POWERGEN TRANSFORMER P. LTD.

At direction of the Rajasthani Power Generation Corporation Ltd. (Rajasthani Power Generation Corporation Ltd.)

At direction of the Rajasthani Power Generation Corporation Ltd. (Rajasthani Power Generation Corporation Ltd.)

At direction of the Rajasthani Power Generation Corporation Ltd. (Rajasthani Power Generation Corporation Ltd.)

RAJASTHAN POWERGEN TRANSFORMER P. LTD.

At direction of the Rajasthani Power Generation Corporation Ltd. (Rajasthani Power Generation Corporation Ltd.)

At direction of the Rajasthani Power Generation Corporation Ltd. (Rajasthani Power Generation Corporation Ltd.)

At direction of the Rajasthani Power Generation Corporation Ltd. (Rajasthani Power Generation Corporation Ltd.)

RAJASTHAN POWERGEN TRANSFORMER P. LTD.

At direction of the Rajasthani Power Generation Corporation Ltd. (Rajasthani Power Generation Corporation Ltd.)

At direction of the Rajasthani Power Generation Corporation Ltd. (Rajasthani Power Generation Corporation Ltd.)

At direction of the Rajasthani Power Generation Corporation Ltd. (Rajasthani Power Generation Corporation Ltd.)

*** Not Provided during testing**

1. All dimensions are in mm. Tolerance 25%
 2. This drawing shows only general disposition of fitting.
 3. Top & bottom plate - 2.0 mm. Thick. 6.
 4. Paint shade: Olive Green Color conforming to No. 220 of IS : 311061

1. All dimensions are in mm. Tolerance 25%
 2. This drawing shows only general disposition of fitting.
 3. Top & bottom plate - 2.0 mm. Thick. 6.
 4. Paint shade: Olive Green Color conforming to No. 220 of IS : 311061

1. All dimensions are in mm. Tolerance 25%
 2. This drawing shows only general disposition of fitting.
 3. Top & bottom plate - 2.0 mm. Thick. 6.
 4. Paint shade: Olive Green Color conforming to No. 220 of IS : 311061

This document is the exclusive property of RAJASTHAN POWERGEN TRANSFORMER P. LTD. and shall not be used, copied or reproduced in any form without its prior written consent.

L.V. SIDE VIEW

SIDE VIEW

H.V. SIDE VIEW

CORE SIZE	
Core Window Height	240 mm
Core build up	2 x 43.5 mm
Core Street Width	160 mm

CONDUCTOR SIZE		
	LV	HV
Bare	14.0 x 3.0	2.50 CHa
Covered	14.4 x 3.4	2.50 CHa
Aluminum	DPG	Polycarbonate 3.4 x 1.6 (3.4 x 1.6) CHa
Specialty	1W x 2Q	


SOIL DIMENSIONS			
	LV	RV	
ID	93 x 60	103 x 234	
OD	152 x 229	270 x 344	
AXIAL HT.		350	

Sl. No.	LIST OF FITTINGS	Qty.
12	INTERNAL CIRCUIT BREAKER*	1
11	HV LEAD	-
10	LV LEAD	-
9	CORE (CRGO)	2 nos
8	LV & HV COIL (ALUMINIUM)	1 set
7	BOTTOM CORE CLAMP	1
6	COIL SEPARATOR	1 set
5	CHANNEL SEPARATOR	1 set
4	END INSULATION	1 set
3	TOP CORE CLAMP	1
2	LOCKING CUM LIFTING LUG	2
1	HV FUSE LINK*	1


Notes:-
1- All dimensions are in mm. Tolerance ± 0.05
2- This drawing shows only general disposition of fittings.

சிறப்பு தகவல்:

INTERNAL CONSTRUCTIONAL DETAIL DRAWING

		RAJASTHAN POWERGEN TRANSFORMER P. LTD. Head Office—Bharat Road, Jaipur, Rajasthan—302011 Reg.—Jaipur (Jaipur) (VOLL.)	Drawing No.: RPT/PC/02 Part: 00 Sheet No.: 01 Total Sheets: 01	Scale: N.T.S.
-------------------------------------------------------------------------------------	--	---------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------	----------------------

CRGO WOUND CORE



MATERIAL - CRGO

FLUX DENSITY CALCULATION

CORE DIMENSION :-

WIDTH - 160 mm.
STACK - 43.5 mm.

No. OF LOOPS - 2 Nos.
GROSS AREA - 13920 Sq. mm.
STACKING FACTOR - 0.96
NET CORE AREA (A) - 13363.2 Sq. mm.
FREQUENCY (f) - 50 Hz.
No. OF LV TURNS (N) - 60
SECONDARY VOLTAGE (V) - 0.240 kV

$$\text{FLUX DENSITY} = \frac{0.24 \times 10^3}{4.44 \times 50 \times 13363.2 \times 60} = 1.348 \text{ TESLA}$$

Test Report No.: RP-1718-090430
Date: 10/01/2018
Product: 16 kVA, 0.24 kV
Verified By: [Signature]
Verification of this drawing by ERCA is limited to relevant dimensional checks only. Verified dimensions are marked with this stamp.

	Dimensions (MM)
A	246
B	95
C	43.5
D	160
E	182
F	333
Qty. :	2 No's

Calculated Weight : 85 kg

Notes :-

1) All dimensions are in mm. Unless otherwise specified.

00	23.08.17				ORIGINAL ISSUE.
Rev	Date	Draw	Checked	Approved	Description
		Title : CORE DRAWING			Work Order :
Rating : 16 KVA, 11/√3/0.240 KV, 1Ø, 50 Hz, TRF.		Drawing No. : RPTPL/CD/02		Rev. : 00	Sheet No. : 00
RAJASTHAN POWERGEN TRANSFORMER P. LTD. Karola - Bhinmal Road, Karola, Sanchore - 343041 Dist - Jalore, Rajasthan (India)		All dimensions are in millimeters unless otherwise stated. If in doubt - Please Ask !		Scale : NTS	