



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT

SHEET 1 OF 24

NAME & ADDRESS OF CUSTOMER M/s. RAJASTHAN POWERGEN TRANSFORMER PVT.LTD. KHASRA NO.911-914, KAROLA-BHINMAL ROAD, KAROLA,SANCHORE,-343041 RAJASTHAN.	REPORT NO.: RP-1819-010895	
	DATE: 21.06.2018	
	CUSTOMER REF. NO. RPTPL/Type Test/ ERDA/003	DATED: 26.04.2018
	DATE OF SAMPLE RECEIPT: 26.04.2018	DATE OF TESTING: 02.05.2018 to 17.05.2018
SAMPLE DESCRIPTION 5 kVA, Single Phase Distribution transformer (Sealed Type) 11000/√3/240 Volts, 0.787/20.83 Amps., Oil filled, Energy efficiency level : 2 Further details as per sheet No. 3 of 24	SAMPLE IDENTIFICATION ERDA SAMPLE CODE NO.: ERDA-00254271 SERIAL NO.: RPTPL/5KVA/AL/18-19/001 YEAR OF MFG.: 2018	
	TEST DETAILS As per sheet 4 OF 24.	
TEST SPECIFICATIONS As per sheet 4 OF 24.		
ENCLOSURES: As per sheet 2 OF 24.		
REMARKS: On respective sheets from 5 OF 24 to 24 OF 24.		
 PREPARED BY	 CHECKED BY	 APPROVED BY Kapil J. Sharma

- NOTE:**
1. This report relates only to the particular sample received for testing in good condition at ERDA.
 2. This report cannot be reproduced in part under any circumstances.
 3. Publication of this report requires prior permission in writing from Director, ERDA.
 4. Only test asked for by customer have been carried out.
 5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arised.

Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.

TC 2557932





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



TEST REPORT NO : RP-1819-010895
DATE: 21.06.2018

Sheet 2 OF 24

Contents	
1. Oscillogram No.	0142/01 to 0142/05
2. Photograph No.	1819-001541/0165
3. Test circuit diagram No.	OLSC/DTC/05
4. Drawing No.	1) RPTPL/RP/05 Rev.:01 Sheet no.01 2) RPTPL/OGA/05 Rev.:01 Sheet no.01 3) RPTPL/IC/05 Rev.:01 Sheet no.01

M. J. Gupta
PREPARED BY

[Signature]
CHECKED BY



TC 2557931



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO : RP-1819-010895

Sheet 3 OF 24

DATE: 21.06.2018

TECHNICAL SPECIFICATIONS OF TEST OBJECT ASSIGNED BY CUSTOMER

1. Name of manufacturer : **RAJASTHAN POWERGEN TRANSFORMER PVT.LTD.**
2. Equipment : **5 kVA Single Phase Distribution Transformer**
3. Standard No. : **IS 1180 (Part 1): 2014**
[Amendment No. 1& 2], IS 2026 (Part 1): 2011
& IS 2026 (Part 10): 2009
4. Serial No. : **RPTPL/5KVA/AL/18-19/001**
5. Energy efficiency level : **2**
6. Type : **Outdoor, Oil cooled, Sealed Type**
7. kVA rating : **5**
8. Rated voltage H.V.(volts) : **11000/√3**
L.V. (volts) : **240**
9. Rated current H.V. (Amp.) : **0.787**
L.V.(Amp.) : **20.83**
10. Number of phases : **1**
11. Frequency (Hz.) : **50 Hz**
12. Type of cooling : **ONAN**
13. Temperature rise of oil/winding : **35°C/40°C**
14. Percentage Impedance : **2.5%**
15. Primary winding conductor : **Polysterimide enamel (Class-H) Aluminium wire, Bare dia. 1.27 mm**
16. Secondary winding conductor : **DPC Aluminium Strip, Bare size (10.9 mm x 3.0 mm)**
17. Quantity of oil (Litre) : **28**
18. Weight of oil (kg.) : **24**
19. Weight of core coil assembly (kg.) : **55**
20. Total weight (kg.) : **107**
21. Polarity : **Subtractive**
22. Vector group : **Ii0/Single Phase**
23. Year of manufacture : **2018**
24. Insulation Level L.V. : **03 kVrms**
25. Total losses at 75°C (Watts) : **35 Max. (at 50 % load)**
: **95 Max. (at 100 % load)**


PREPARED BY


CHECKED BY



TC 2557926



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.



EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010895		Sheet : 4 OF 24
DATE : 21.06.2018		
	TEST DETAILS	TEST SPECIFICATION
1.	Measurement of short-circuit impedance and load loss at 50 percent and 100 percent load	As per cl.no.21.2.c of IS 1180 (Part 1):2014
2.	Measurement of no-load loss and current	As per cl.no.21.2.d of IS 1180 (Part 1):2014
3.	Total losses at 50 % load	As per cl.no. 8.8 of IS 1180 (Part 1):2014
4.	Total losses at 100 % load	As per cl.no. 8.8 of IS 1180 (Part 1):2014
5.	No load current at 112.5 percent Voltage	As per cl.no.21.4.c of IS: 1180 (PART 1):2014
6.	Temperature-rise test	As per customer's requirement, testing procedure followed as per Cl.no.21.3.b of IS1180(Part 1):2014
7.	Oil leakage test	As per cl.no.21.2.j of IS 1180 (Part 1):2014
8.	Pressure test (routine test)	As per cl.no.21.2.h of IS 1180 (Part 1):2014
9.	Pressure test (type test)	As per cl.no.21.3.d of IS 1180 (Part 1):2014
10.	Determinations of sound levels	As per customer's requirement, testing procedure followed as per cl. no. 21.4.a of IS 1180 (Part 1) : 2014 & Cl. No.13 of IS 2026(Part 10): 2009
11.	Measurement of the Harmonics of the No-load current	As per customer's requirement testing procedure followed as per cl.no.10.6. of IS: 2026 (PART 1)-2011
12.	Lightning impulse test	As per cl.no.21.3.a of IS 1180 (Part 1):2014 And test voltage specified by the customer(Test procedure was followed as per cl.no.14 of IS 2026 (Part 3) : 2009
13.	Short-circuit withstand test	As per cl.no.17 & 21.3 c of IS 1180 (Part 1) :2014
14.	Paint Adhesion test	As per cl.no.21.4 d of IS 1180 (Part 1): 2014
 PREPARED BY		 CHECKED BY

TC 2557935





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010895		Sheet : 5 OF 24		
DATE : 21.06.2018				
Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained Value	Remarks
1.	<p>Measurement of short-circuit impedance and load loss at 50 percent and 100 percent load : (As per cl.no.21.2.c of IS 1180 (Part 1): 2014)</p> <p>At 50% load : Tested with 0.39388 Amps (on HV side) Frequency : 50.042 Hz Top oil temperature : 36.5°C</p> <p style="padding-left: 40px;">Test current (Amps) 0.39388 Impedance voltage (Volts) 78.040 Measured load loss (Watts) 12.499 Impedance voltage (%) (Computed to 50% load) At 36.5°C 1.229 At 75°C 1.236 Load loss (Watts) (Computed to 50% load) At 36.5°C 12.507 At 75°C 14.323</p> <p>At 100% load : Tested with 0.7867 Amps (on HV side) Frequency : 50.045 Hz Top oil temperature : 36.5°C</p> <p style="padding-left: 40px;">Test current (Amps) 0.7867 Impedance voltage (Volts) 155.95 Measured load loss (Watts) 49.87 Impedance voltage (%) (Computed to 100% load) At 36.5°C 2.466 At 75°C 2.526 Load loss (Watts) (Computed to 100% load) At 36.5°C 50.289 At 75°C 57.555</p>	<p>---</p> <p>---</p> <p>---</p> <p>2.5 (±10%)</p> <p>--</p>	<p>0.39388</p> <p>78.040</p> <p>12.499</p> <p>1.229</p> <p>1.236</p> <p>12.507</p> <p>14.323</p> <p>0.7867</p> <p>155.95</p> <p>49.87</p> <p>2.466</p> <p>2.526</p> <p>50.289</p> <p>57.555</p>	<p>----</p> <p>Conforms</p>

TC 2557934

PREPARED BY

CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010895		Sheet : 6 OF 24		
DATE : 21.06.2018				
Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained Value	Remarks
2.	Measurement of no-load loss and current : (As per cl.no.21.2.d of IS 1180 (Part 1): 2014) Tested with average 240.35 Volts (on LV side) Frequency : 50.056 Hz RMS voltage (Volts) No-load current (Amps) Measured no-load loss (Watts) Corrected no-load loss (Watts)		240.20 0.07795 17.19 17.201	--
3.	Total losses at 50 % load (Watts) : (As per cl.no.8.8 of IS 1180 (Part 1):2014)	Max. 35	31.524	Conforms
4.	Total losses at 100 % load (Watts) : (As per cl.no.8.8 of IS 1180 (Part 1):2014)	Max. 95	74.756	Conforms
5.	No load current at 112.5 percent Voltage : (As per cl.no.21.4.c of IS: 1180 PART 1-2014) Test voltage of 112.5 percent of rated voltage at rated frequency was applied to the L.V. winding terminals and H.V. winding terminals were kept open circuited. No load current was recorded. Test voltage (Volts) No load current (Amps) No Load Current (%)	Max. 6.0	270.18 0.09161 0.44	Conforms
PREPARED BY		CHECKED BY		

TC 2555948





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



Sheet : 7 OF 24

REPORT NO.: RP-1819-010895

DATE : 21.06.2018

Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained value	Remarks
6.	<p>Temperature-rise test : (As per customer's requirement, testing procedure followed as per Cl.no.21.3.b of IS1180(Part 1):2014)</p> <p>Before starting test, the dimensions of tank were measured & recorded.</p> <p>Size of tank : H-615 mm, Diameter-325 mm</p> <p>Specified losses fed for temperature-rise test were 95 Watts.</p> <p>Specified losses were fed to the transformer (i.e. Supply was connected to HV winding and LV winding kept short-circuited) till steady state temperature-rise was attained. Top oil temperature was recorded hourly. After steady state condition, the losses were brought down in reference to the rated current one hour prior to shut down.</p> <p>At the shutdown, the hot windings resistance were measured and temperature-rise calculated.</p> <p>A) Top oil temperature-Rise : Max. 35°C</p> <p>B) Winding Temperature Rise (Resistance method)</p> <p> 1) HV Winding : Max. 40°C</p> <p> 2) LV Winding : Max. 40°C</p> <p>C) Ambient temperature at shutdown : 29.4°C</p> <p>D) Time of Shutdown(Hrs) : 7:30</p>			Conforms

PREPARED BY

CHECKED BY

TC 2557933





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.



EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010895		Sheet : 8 OF 24		
DATE : 21.06.2018				
Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained Value	Remarks
7.	Oil leakage test : (As per cl.no.21.2.j of IS 1180 (Part1: 2014)) The assembled transformer with all fittings including bushings in position was tested at a pressure at the top equivalent to the head that was available at the base of the tank for 6 hours.	There should be no leakage at any point	No leakage observed.	Conforms
8.	Pressure test (routine test) : (As per cl.no.21.2.h of IS 1180 (Part 1: 2014)) The transformer was tested at an air pressure of 35 kPa above atmosphere pressure maintained inside the tank for 10 min.	There should be no leakage at any point.	No leakage observed.	Conforms
9.	Pressure test (Type test) : (As per cl.no.21.3.d of IS 1180 (Part 1: 2014)) The transformer was tested at an air pressure OF 100 kPa above atmosphere pressure maintained inside the tank for 30 min.	There should be no leakage at any point & no deformation of tank	No leakage & No deformation of tank observed.	Conforms
 PREPARED BY		 CHECKED BY		

TC 2555946





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**TEST REPORT NO: RP-1819-010895****DATE: 21.06.2018****SHEET : 9 OF 24****Particulars of Tests & Cl. No.:****10) Determinations of sound levels** [A- Weighted Sound Power Level Measurement]

[As per customer's request, testing procedure followed as per as per Cl. No. 21.4.a of IS 1180 (Part 1):2014 & Cl. No. 13 of IS 2026 (Part 10): 2009]

Condition of transformer

Transformer was energized at no load condition & excited at the rated voltage of sinusoidal waveform & rated frequency.

Details of equipment used:**Name:** Sound level meter **Make:** Lutron**Meter Type:** Type 1**Serial No.:** I.62852**Calibration Report No. & Date:** NCQC-M/141117/01, Dt. 27/11/2017**TEST RESULTS:****A-Weighted sound pressure levels of the background noise**

Sr. No.	Measurement Locations (Refer Sketch Below)	At the start of test dB(A)	At the end of test dB(A)
1	A	45.6	45.8
2	B	45.2	45.3
3	C	45.3	45.6
4	D	45.7	45.7
5	E	45.1	45.3
6	F	44.9	44.7
7	G	44.8	44.9
8	H	45.5	45.5
9	I	44.8	45.1
10	J	44.7	45.2
Arithmetic Average \bar{L}_{bgA}		45.2	45.3

A-Weighted sound pressure levels at energized condition L_{pAi}

Sr. No.	Measurement Locations (Refer Sketch Below) dB(A)	L_{pAi} dB(A)
1	A	46.8
2	B	47.2
3	C	48.4
4	D	47.0
5	E	48.4
6	F	46.4
7	G	46.9
8	H	47.4
9	I	47.3
10	J	47.3
Arithmetic Average \bar{L}_{pA0}		47.4


PREPARED BY

CHECKED BY

TC 2557937





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO: RP-1819-010895

DATE: 21.06.2018

SHEET: 10 OF 24

TEST PARAMETERS:

Measurement distance : 1 m,

Microphone Spacing: 1 m

Measurement made : Half of the height of the transformer tank

Method followed: Sound pressure measurement as per Cl. No. 11, 11.3 & Table 2 of IS 2026 (Part 10): 2009.

Length of prescribed contour: 9.92 m

Transformer Tank Height: 0.615 m


Person present during sound level measurement: 3

A-Weighted sound pressure level ($\overline{L_{pA0}}$):	47.4 dB(A)
---	------------

Corrected average A-weighted sound pressure level ($\overline{L_{pA}}$):	43.4 dB(A)
--	------------

Calculated A- weighted sound power level (L_{WA}) :	52.2 dB(A)
---	------------

REMARKS: 1) Guaranteed value of sound pressure level is considered as 48 db (A) as mentioned in customer's letter.
2)Transformer conforms to the requirement of guaranteed value of sound pressure level



Sketch showing the locations of sound measurement

PREPARED BY

CHECKED BY

TC 2557936





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33



Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



SHEET No. 11 OF 24

REPORT NO.: RP-1819-010895		Date: 21.06.2018		
Sr. No.	Particulars of test and clause no.	Requirement as per specification.	Obtained value	Remarks
11	Measurement of the Harmonics of the No-load current (As per customer's request testing procedure followed as per cl. no. 10.6 of IS 2026 (Part 1):2011)	The harmonics of the no-load current shall be measured and magnitude of the harmonics shall be expressed as a percentage of the fundamental component.	Refer table 1 for individual current harmonics components & individual voltage harmonics components measured at LV side at rated voltage i.e. 240 V Current THD: 27.4% Voltage THD: 0.83%	---
Prepared by: 		Checked by: 		



TC 2555945



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



SHEET No. 12 OF 24

REPORT NO.: RP-1819-010895

Date: 21.06.2018

TABLE-1 : Harmonics in voltage and current (as a percentage of fundamental)

Harmonic order	Current I _R in %	Current I _R in Amps	Voltage V _{RY} in %
1	100.00	0.0730	100.00
2	7.00	0.0051	0.02
3	24.53	0.0179	0.16
4	3.73	0.00272	0.02
5	8.50	0.00620	0.60
6	1.27	0.00093	0.00
7	0.77	0.00056	0.35
8	0.49	0.00036	0.02
9	0.58	0.00042	0.08
10	0.15	0.00011	0.02
11	1.45	0.00106	0.25
12	0.16	0.00012	0.02
13	1.90	0.00139	0.24
14	0.38	0.00028	0.04
15	0.52	0.00038	0.05
16	0.15	0.00011	0.02
17	1.70	0.00124	0.02
18	0.16	0.00012	0.01
19	0.77	0.00056	0.07
20	0.21	0.00015	0.02
21	0.53	0.00039	0.05
22	0.19	0.00014	0.00
23	0.85	0.00062	0.05
24	0.21	0.00015	0.02
25	0.58	0.00042	0.03
THD %	27.40		0.83
Parameter measured	0.08 A		240.50 V

Prepared by

Checked by

TC 2555944





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO.: RP-1819-010895

SHEET NO.: 13 of 24

DATE : 21/06/2018

12.Lightning Impulse Test (As per Cl. No.21.3.a of IS 1180 (part 1) : 2014 Amendment 1 & 2 & test procedure was followed as per IS : 2026-(part- III), 2009 cl. No. 14

Waveform	Comment	Ut / kVp	T1 / μ s	T2 / μ s	Tc / μ s
1.1 POLE					
1	LI RW	-47.762	1.357	45.764	
2	100% LI FW	-73.863	1.353	45.909	
3	LI CRW	-47.666	1.342		2.504
4	110% LI CFW	-83.086	1.350		3.101
5	110% LI CFW	-83.963	1.336		2.545
6	100% LI FW	-73.431	1.350	45.901	
7	100% LI FW	-75.631	1.351	45.911	

REMARKS: From the observation of enclosed oscillographic records , it is concluded that the transformer **conforms** to the requirements of the above mentioned standard with respect to the test carried out.

TC 2557901


PREPARED BY


CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO.: RP-1819-010895
DATE : 21/06/2018

SHEET NO.: 14 of 24





Fig.: 1
 $U_p = -47.76 \text{ kV}$
 $T_1 = 1.36 \text{ } \mu\text{s}$
 $T_2 = 45.76 \text{ } \mu\text{s}$
 $T_c = \text{ } \mu\text{s}$



Comment: LI RW





Fig.: 2
 $U_p = -73.86 \text{ kV}$
 $T_1 = 1.35 \text{ } \mu\text{s}$
 $T_2 = 45.91 \text{ } \mu\text{s}$
 $T_c = \text{ } \mu\text{s}$



Comment: 100% LI FW

TC 2557902

PREPARED BY

[Signature]

CHECKED BY

[Signature]





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org



Web : http://www.erda.org





TEST REPORT NO.: RP-1819-010895

SHEET NO.: 15 of 24

DATE : 21/06/2018



Comment: LI CRW



Comment: 110% LI CFW

TC 2557903

PREPARED BY

M. J. J.



CHECKED BY

A. J.



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO.: RP-1819-010895
DATE : 21/06/2018

SHEET NO.: 16 of 24





Fig.: 5

$U_p = -83.96 \text{ kV}$
 $T_1 = 1.34 \text{ } \mu\text{s}$
 $T_2 = \text{ } \mu\text{s}$
 $T_c = 2.55 \text{ } \mu\text{s}$



Comment: 110% LI CFW





Fig.: 6

$U_p = -73.43 \text{ kV}$
 $T_1 = 1.35 \text{ } \mu\text{s}$
 $T_2 = 45.90 \text{ } \mu\text{s}$
 $T_c = \text{ } \mu\text{s}$



Comment: 100% LI FW

TC 2557904

PREPARED BY

[Signature]

CHECKED BY

[Signature]





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO.: RP-1819-010895
DATE : 21/06/2018

SHEET NO.: 17 of 24




Fig.: 7
 $U_p = -75.63 \text{ kV}$
 $T_1 = 1.35 \mu\text{s}$
 $T_2 = 45.91 \mu\text{s}$
 $T_c = \mu\text{s}$

Comment: 100% LI FW

TC 2557905

PREPARED BY

[Signature]

CHECKED BY

[Signature]





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010895

SHEET 18 OF 24

DATE: 21.06.2018

13. Short-circuit withstand test

(As per Cl. No. 17 & 21.3 c of IS 1180 (Part 1): 2014)

ROUTINE TEST RESULTS BEFORE SHORT CIRCUIT

a) MEASUREMENT OF WINDING RESISTANCE

Measurement at oil temperature: 35.3°C	
LV Winding resistance (mΩ)	HV Winding resistance (Ω)
2.1-2.2(n)	1.1-1.2(N)
49.902	43.784

b) MEASUREMENT OF VOLTAGE RATIO AND CHECK OF POLARITY

Polarity: Subtractive was verified

Measured turns ratio between Terminals	Rated turns Ratio	Difference (%)
1.1-1.2(N)/2.1-2.2(n)		
26.404	26.463	-0.223

c) MEASUREMENT OF SHORT-CIRCUIT IMPEDANCE AND LOAD LOSS (at 100 % load)

Oil temperature: 35.9°C

Test current (Amp.)	Impedance voltage (V)	Frequency (Hz.)	Load loss measured (Watts)	Impedance Voltage (%Z) at 50 Hz.	Load loss computed at 75°C (Watts)	%Z at 75°C
0.786	154.999	49.751	49.475	2.456	57	2.518

d) MEASUREMENT OF LOAD LOSS (at 50 % load)

Oil temperature: 35.9°C

Test current (Amp.)	Impedance voltage (V)	Frequency (Hz.)	Load loss measured (Watts)	Load loss computed at 75°C (Watts)
0.392	77.225	49.757	12.281	14

TC 2554207


PREPARED BY


CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**REPORT NO.:** RP-1819-010895

SHEET 19 OF 24

DATE: 21.06.2018e) MEASUREMENT OF NO-LOAD LOSS AND CURRENT

Oil temperature: 35.9°C

Applied Voltage (V)	Current (Amp.)	Frequency (Hz.)	Losses Measured (Watts)
240.037	0.079	50.017	17

- Total losses at 75°C: 31 Watts (at 50 % load)
- Total losses at 75°C: 74 Watts (at 100% load)

f) MEASUREMENT OF INSULATION RESISTANCE

Oil temperature: 35.3°C

	Applied DC Voltage (V)	IR value (MΩ)
HV to LV winding	2500	> 2000
HV winding to LV + EARTH	2500	> 2000
LV winding to HV + EARTH	500	> 2000

g) INDUCED OVER-VOLTAGE WITHSTAND TEST

Sr. No.	Test	Applied voltage (V)	Applied Freq. (Hz.)	Duration (sec.)	Remarks
1.	Between LV windings with HV terminal open & neutral terminal earthed.	756	150	40	Withstood

h) SEPARATE-SOURCE VOLTAGE WITHSTAND TEST

Sr. no.	Test	Applied voltage (kV)	Duration (sec.)	Remarks
1.	Between HV winding and LV winding connected to the tank and earth	03	60	Withstood
2.	Between LV winding and HV winding connected to the tank and earth	03	60	Withstood


PREPARED BY


CHECKED BY



TC 2554208



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010895

SHEET 20 OF 24

DATE: 21.06.2018

SHORT-CIRCUIT WITHSTAND TEST:

The verification of short-circuit withstand test was performed on the transformer by connecting the secondary winding to single phase of the source and primary winding short circuited using synchronization switch. The test conducted with short circuiting of primary winding; follow the application of the voltage to the secondary winding of transformer as per schematic circuit diagram No. OLSC/DTC/05.

Condition of the equipment under test: As after routine tests.

Supply Frequency: 50 Hz.

Test No.	Oscillo-gram No.	Applied voltage (Vrms)	Short circuit current on LV (A)		Duration (sec.)	Remarks
			Peak	RMS		
1.	0142/01	-	1182	655	0.1	Calibration Shot
2.	0142/02	240	1470	848	0.5	No Abnormality
3.	0142/03	240	1438	851	0.5	No Abnormality
4.	0142/04	240	1410	815	0.5	No Abnormality
5.	0142/05	240	1421	827	2.0	Thermal shot No Abnormality


PREPARED BY


CHECKED BY

TC 2554209





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



REPORT NO.: RP-1819-010895

SHEET 21 OF 24

DATE: 21.06.2018

Measurement of the % reactance during the short circuit test

LV winding was short circuited. AC supply was connected to HV winding to pass test current. Before the short circuit test and after each shot, the percentage reactance was measured.

Sr. No.	Measurement performed		Measured value of % reactance at 50 Hz.	%Change in % reactance
1.	Before test		2.24	-
2.	After the test no.	2.	2.28	1.79
3.	After the test no.	3.	2.28	1.79
4.	After the test no.	4.	2.28	1.79
5.	After the test no.	5.	2.28	1.79


PREPARED BY


CHECKED BY

TC 2554210





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010895

SHEET 22 OF 24

DATE: 21.06.2018

ROUTINE TEST RESULTS AFTER SHORT CIRCUIT

a) MEASUREMENT OF WINDING RESISTANCE

Measurement at oil temperature: 37.3°C	
LV Winding resistance (mΩ)	HV Winding resistance (Ω)
2.1-2.2(n)	1.1-1.2(N)
50.705	44.264

b) MEASUREMENT OF VOLTAGE RATIO AND CHECK OF POLARITY

Polarity: Subtractive was verified

Measured turns ratio between Terminals	Rated turns Ratio	Difference (%)
1.1-1.2(N)/2.1-2.2(n)		
26.406	26.463	-0.215

c) MEASUREMENT OF SHORT-CIRCUIT IMPEDANCE AND LOAD LOSS (at 100 % load)

Oil temperature: 37.1°C

Test current (Amp.)	Impedance voltage (V)	Frequency (Hz.)	Load loss measured (Watts)	Impedance Voltage (%Z) at 50 Hz.	Load loss computed at 75°C (Watts)	%Z at 75°C
0.783	157.229	49.903	49.526	2.493	57	2.553

d) MEASUREMENT OF LOAD LOSS (at 50 % load)

Oil temperature: 37.1°C

Test current (Amp.)	Impedance voltage (V)	Frequency (Hz.)	Load loss measured (Watts)	Load loss computed at 75°C (Watts)
0.390	78.259	49.927	12.263	14


PREPARED BY


CHECKED BY



TC 2554211



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**REPORT NO.:** RP-1819-010895

SHEET 23 OF 24

DATE: 21.06.2018e) MEASUREMENT OF NO-LOAD LOSS AND CURRENT

Oil temperature: 37.1°C

Applied Voltage (V)	Current (Amp.)	Frequency (Hz.)	Losses Measured (Watts)
240.131	0.075	50.031	17

- Total losses at 75°C: 31 Watts (at 50 % load)
- Total losses at 75°C: 74 Watts (at 100% load)

f) MEASUREMENT OF INSULATION RESISTANCE

Oil temperature: 37.1°C

	Applied DC Voltage (V)	IR value (MΩ)
HV to LV winding	2500	> 2000
HV winding to LV + EARTH	2500	> 2000
LV winding to HV + EARTH	500	> 2000

g) INDUCED OVER-VOLTAGE WITHSTAND TEST

Sr. No.	Test	Applied voltage (V)	Applied Freq. (Hz.)	Duration (sec.)	Remarks
1.	Between LV windings with HV terminal open & neutral terminal earthed.	756	150	40	Withstood

h) SEPARATE-SOURCE VOLTAGE WITHSTAND TEST

Sr. no.	Test	Applied voltage (kV)	Duration (sec.)	Remarks
1.	Between HV winding and LV winding connected to the tank and earth	03	60	Withstood
2.	Between LV winding and HV winding connected to the tank and earth	03	60	Withstood

Observation after test: The transformer was untanked and inspected.

- 1) Condition of conductor, core and clamping:
 - No visible damage, deformation or displacement.
- 2) Condition of oil : Clear

Results: 1) % Change in % reactance is within tolerance limits as per standard.
 2) The results of routine tests carried out before and after the short-circuit withstand test found within limits as per standard.

TC 2554212

PREPARED BY

CHECKED BY



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.



EPABX: +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33,

Fax : +91 (0265) 2638382,

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT No.: RP-1819-010895		DATE: 21-06-2018		SHEET 24 OF 24	
Sr. No.	Particular of Tests and Cl. No.	Requirements as per specification	Obtained value	Remarks	
14.	Paint Adhesion Test at 37°C & 12 % RH Test Method A – X-cut tape test (Test procedure followed as per ASTM D 3359-2017, Cl. No. 8) Cl. No. 21.4.d of IS 1180 (Part 1): 2014 - Adhesion strength of pressure sensitive tape 6.7 N/cm.	--	Observation 1-5A – No peeling or removal was observed at the location. Observation 2-5A – No peeling or removal was observed at the location. Observation 3-5A – No peeling or removal was observed at the location.	--	
PREPARED BY 		CHECKED BY 			



2239897



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : http://www.erda.org




REPORT NO.: RP-1819-010895

DATE: 21.06.2018



TC 2530288

OSCILLOGRAM NO. : 0142/01





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : http://www.erda.org




REPORT NO.: RP-1819-010895

DATE: 21.06.2018



TC 2515155

OSCILLOGRAM NO. : 0142/02





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : <http://www.erda.org>




REPORT NO.: RP-1819-010895

DATE: 21.06.2018



TC 2515156

OSCILLOGRAM NO. : 0142/03





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010895

DATE: 21.06.2018



TC 2515158

OSCILLOGRAM NO. : 0142/04





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : http://www.erda.org




REPORT NO.: RP-1819-010895

DATE: 21.06.2018



[Handwritten Signature]



TC 2515159

OSCILLOGRAM NO.: 0142/05



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010895

DATE: 21.06.2018



DISTRIBUTION TRANSFORMER
RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.
JALORE, RAJASTHAN

PHASE TRANSFORMER

STANDARD	IS - 1180 (Part-1)/2014	ENERGY EFFICIENCY LEVEL	2
KVA	5	MAX. TOTAL LOSS AT 100% RATED LOAD W	35
VOLTS AT NO LOAD (V)	HV 11000 / 3	MAX. TOTAL LOSS AT 10% RATED LOAD W	95
	LV 240	TYPE OF COOLING	ONAN
BIL (KV Peak)	HV 75	TEMP. RISE	OIL °C 35
	LV NA		WDG °C 40
CURRENT (A)	HV 0.787	MASS OF OIL	kg 24
	LV 20.83	TOTAL MASS	kg 107
FREQUENCY	Hz 50	VOLUME OF OIL	Ltr 28
VECTOR GROUP	1-PHASE	MONTH & YEAR OF MFG	/201
IMPEDANCE VOLT %	2.5	SERIAL NO.	P/1501A/2
DISPATCH DATE		EXPIRY DATE G.P.	18/11/18
CONDUCTOR MATERIAL	ALUMINIUM	SY. NO. - RPTPL/S KVA/1M	
CUSTOMER	JVVNL		18-11-04
PO. No.			


MADE IN INDIA

SUBSERVATIVE POLARITY

1.1 2.1
1.2(N) 2.2(N)



TC 2546900



- CB - 66 kV CIRCUIT BREAKER
- TR - 66 kV/11kV TRANSFORMER
- ISO - ISOLATOR
- BCB - BACKUP CIRCUIT BREAKER
- MS - MASTER CIRCUIT BREAKER
- Z - SOURCE SIDE IMPEDANCE
- X - REACTANCE
- R - RESISTANCE
- SC/TR - SHORT CIRCUIT TRANSFORMER
- HTMS - H.T. MAKE SWITCH
- T.T. - TEST TRANSFORMER
- S - CURRENT MEASURING DEVICE



Handwritten signature

REPORT NO.: PL-1819-010895
 DATE: 21.06.2018

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION		DRG. NO.
SCHEMATIC CIRCUIT DIAGRAM		
DRM. BY	CKO.	DATE
S.B.S.	A.V.G.	30.9.05
		OLSC/DTC/05

4 HOLES
of Ø3.6mm


DISTRIBUTION TRANSFORMER
RAJASTHAN POWERGEN TRANSFORMER PVT LTD
JALORE, RAJASTHAN

1 PHASE TRANSFORMER

STANDARD	IS : 1180 (Part-1)/2014	ENERGY EFFICIENCY LEVEL	2
KVA	5	MAX. TOTAL LOSS AT 50% RATED LOAD W	35
VOLTS AT NO LOAD (V)	HV $11000/\sqrt{3}$	MAX. TOTAL LOSS AT 100% RATED LOAD W	95
	LV 240	TYPE OF COOLING	ONAN
BIL (kV Peak)	HV 75	TEMP. RISE	OIL °C 35
	LV NA		WDG °C 40
CURRENT (A)	HV 0.787	MASS OF OIL	kg 24
	LV 20.83	TOTAL MASS	kg 107
FREQUENCY	Hz 50	VOLUME OF OIL	Ltr 28
VECTOR GROUP	1-PHASE	MONTH & YEAR OF MFG.	/2018
IMPEDANCE VOLT %	2.5	SERIAL NO.	RPTPL/5 KVA/AL/18-19/001
DISPATCH DATE	-	EXPIRY DATE G.P.	-
CONDUCTOR MATERIAL	ALUMINIUM		
CUSTOMER	JVVNL		
P.O. No.			

MADE IN INDIA

SUBTRACTIVE POLARITY



Test Report No. RP-1819-010P91
 Date 21.06.2018
 Product 5 KVA 07
 Verified by PJ
 Verification of this drawing by ERDA is limited to relevant dimensional checks only.
 Verified dimensions are marked with ***




NOTES :-

- 1- *** MARKED ITEMS SHOULD BE PUNCHED AT THE TIME OF DISPATCH.
- 2- ALL LETTERS, FIGURES ETC. TO BE ENGRAVED & POLISHED BLACK.
- 3- MATERIAL - STAINLESS STEEL 0.9 WITH TOLERANCE ± 0.1 MM. THICK.
- 4- ALL DIMENSIONS ARE IN MM.

01	28.05.18				
00	01.02.18				ORIGINAL ISSUE.
Rev	Date	Draw	Checked	Approved	Description

	Title : RATING & DIAGRAM PLATE				Work Order : -----	
	Rating : 5 KVA, 11/√3/0.240 KV, 1Ø, 50 Hz, TRF.	Drawing No. : RPTPL/RP/05		Rev. : 01	Sheet No. : 01	Total Sheets: 01
RAJASTHAN POWERGEN TRANSFORMER P. LTD. Karola – Bhinmal Road, Karola, Sanchore – 343041 Dist – Jalore, Rajasthan (India)				All dimensions are in millimeters unless otherwise stated. If in doubt - Please Ask !		Scale : NTS



Test Report No: RD-1819-010825
 Date: 21.06.2018
 Product: 5 KVA DT
 Verified by: [Signature]
 Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with *.

Tank dia	325 mm
Tank height	615 mm

WEIGHTS / QTY.	
TRANSFORMER OIL	Ltrs. 28
TOTAL TRANSFORMER	Kg. 107
TRANSFORMER OIL	Kg. 24
TANK & FITTINGS	Kg. 28
CORE COIL ASSY	Kg. 55

- Notes :-
 1- All dimensions are in mm. Tolerance ±5%.
 2- This drawing shows only general disposition of fittings.
 3- Tank side plate - 2.0 mm. Thk.M.S.
 Top & bottom - 2.5 mm. Thk.M.S.
 4- Paint Shade : Olive Green Color conforming to No. 220 of IS : 5 / 1961
 * Not provided at the time of Type Testing

AIR CLEARANCES (MM)		
VOLTAGE	H.V. (enclosed)	L.V.
PHASE TO PHASE	NA	NA
PHASE TO EARTH	140	20

S. No.	Technical Plate	Qty.	S. No.	Description	Qty.
19	TECHNICAL PLATE	1	1	Signal light	1
18	TOP COVER ANTI THEFT BOLT	-	10	Internal Circuit Breaker handle	1
17	THERMOMETER POCKET WITH CAP	1	11	Tank Earthing terminal	2
16	OIL FILLING HOLE WITH WELDED COVER AND WITH EXTENDED PIPE as per IS 114"	1	12	Pole mounting bracket (as per spec)	2
15	-	-	13	Lifting lugs for complete unit	2
14	OIL LEVEL GAUGE	1	14	OIL LEVEL GAUGE	1
13	Lifting lugs for complete unit	2	15	-	-
12	Pole mounting bracket (as per spec)	2	16	Pressure relief device	1
11	Tank Earthing terminal	2	17	TOP COVER ANTI THEFT BOLT	-
10	Internal Circuit Breaker handle	1	18	TOP COVER ANTI THEFT BOLT	-
9	Pressure relief device	1	19	TECHNICAL PLATE	1
8	Pressure relief device	1	20	Internal Circuit Breaker handle	1
7	H.V. Neutral bushing	1	21	Signal light	1
6	H.V. Bushing	1			
5	Rating & terminal marking plate	1			
4	H.V. Terminal marking	1 set			
3	L.V. Terminal marking	1 set			
2	Earthing terminal (L.V. box)	2			
1	L.V. cable box	1			

OUTLINE GENERAL ARRANGEMENT

Rating: 5 KVA, 11kV/0.240 KV, 10, 50 Hz, TRF.

Drawing No.: RPTPL/OGA/05


Rev.: 01

Total Sheets: 01

Scale: N.T.S

RAJASTHAN POWERGEN TRANSFORMER P. LTD.
 Kanak - Bhimtal Road, Kanak, Sanchore - 343041 Dist - Jaipur, Rajasthan (India)

Rev	Date	Draw	Checked	Approved	Description
01	28.05.18				ORIGINAL ISSUE
00	01.02.18				



COIL DIMENSIONS	
LV	HV
ID 66 x 141	120 x 192
OD 112 x 184	180 x 252
AXIAL HT.	231

Core Window HL:	241 mm
Core build up:	2 x 30 mm
Core Sheet width:	195 mm

Conductor sizes	
LV	HV
Bare 10.9 x 3.0	1.27 Dia
Covered 11.3 x 3.4	1.35 Dia
Aluminum	Polyesterimide Enamelled
DPC	Formaldehyde

SL.No.	Description	Qty.
12	INTERNAL CIRCUIT BREAKER*	1
11	HV LEAD	-
10	LV LEAD	-
9	CRGO WOUND CORE	2
8	LV & HV COIL (Aluminium)	1 set
7	BOTTOM CORE CLAMP	1
6	COIL SEPARATOR	1 set
5	CHANNEL SEPARATOR	1 set
4	END INSULATION	1 set
3	TOP CORE CLAMP	1
2	LOCKING CUM LIFTING LUG	2
1	HV FUSE LINK*	1

LIST OF FITTINGS

Rev	Date	Draw	Checked	Approved	Description
01	28.05.18				ORIGINAL ISSUE.
00	01.02.18				



Test Report No. RP-1819-016895
 Date 21.06.2018
 Product S.K.V.A. 77
 Verified by [Signature]
 Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with *.

Notes :-
 1- All dimensions are in mm. Tolerance ±5%
 2- This drawing shows only general disposition of fittings.
 * Not provided at the time of Type Testing

Title: **INTERNAL CONSTRUCTIONAL DETAIL DRAWING**

Rating: 5 KVA, 11/√3/0.240 KV, 10, 50 Hz, TRF.

Drawing No.: RPTPL/IC/05

Rev.: 01

Sheet No.: 01

Total Sheets: 01

Scale: N.T.S.

Work Order: ---