



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT

SHEET 1 OF 25

NAME & ADDRESS OF CUSTOMER M/s. RAJASTHAN POWERGEN TRANSFORMER PVT.LTD. KHASRA NO.911-914, KAROLA-BHINMAL ROAD, KAROLA,SANCHORE,-343041 RAJASTHAN.	REPORT NO.: RP-1819-010640 DATE: 19.06.2018	
	CUSTOMER REF. NO. RPTPL/Type Test/ ERDA/001	DATED: 26.04.2018
	DATE OF SAMPLE RECEIPT: 26.04.2018	DATE OF TESTING: 02.05.2018 to 25.05.2018
	SAMPLE IDENTIFICATION	
SAMPLE DESCRIPTION 5 kVA, Single Phase Distribution transformer (Sealed Type) 11000/ $\sqrt{3}$ /240 Volts, 0.79/20.83 Amps., Oil filled, Energy efficiency level : 2 Further details as per sheet No. 3 of 25	ERDA SAMPLE CODE NO.: ERDA-00254262	
	SERIAL NO.: RPTPL/5KVA/CU/18-19/001	
	YEAR OF MFG.: 2018	
TEST DETAILS As per sheet 4 OF 25.		TEST SPECIFICATIONS As per sheet 4 OF 25.
ENCLOSURES: As per sheet 2 OF 25.		
REMARKS: On respective sheets from 5 OF 25 to 25 OF 25.		
 PREPARED BY	 CHECKED BY	 APPROVED BY Kapil J. Sharma

- NOTE:** 1. This report relates only to the particular sample received for testing in good condition at ERDA.
2. This report cannot be reproduced in part under any circumstances.
3. Publication of this report requires prior permission in writing from Director, ERDA.
4. Only test asked for by customer have been carried out.
5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arisen.

Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.

TC 2557925



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO : RP-1819-010640

Sheet 2 OF 25

DATE: 19.06.2018

Contents	
1. Oscillogram No.	0143/01 to 0143/05
2. Photograph No.	1819-001542/0194
3. Test circuit diagram No.	OLSC/DTC/05
4. Drawing No.	1) RPTPL/RP/04 Rev.:01 Sheet no.01 2) RPTPL/OGA/04 Rev.:01 Sheet no.01 3) RPTPL/IC/04 Rev.:01 Sheet no.01

MIRJADA

PREPARED BY

A

CHECKED BY



TC 2557014



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO : RP-1819-010640

Sheet 3 OF 25

DATE: 19.06.2018

TECHNICAL SPECIFICATIONS OF TEST OBJECT ASSIGNED BY CUSTOMER

- | | |
|--|---|
| 1. Name of manufacturer | : RAJASTHAN POWERGEN TRANSFORMER PVT.LTD. |
| 2. Equipment | : 5 kVA Single Phase Distribution Transformer |
| 3. Standard No. | : IS 1180 (Part 1): 2014
[Amendment No. 1& 2], IS 2026 (Part 1): 2011
& IS 2026 (Part 10): 2009 |
| 4. Serial No. | : RPTPL/5KVA/CU/18-19/001 |
| 5. Energy efficiency level | : 2 |
| 6. Type | : Outdoor, Oil cooled, Sealed Type |
| 7. kVA rating | : 5 |
| 8. Rated voltage H.V.(volts) | : 11000/ $\sqrt{3}$ |
| L.V. (volts) | : 240 |
| 9. Rated current H.V. (Amp.) | : 0.79 |
| L.V.(Amp.) | : 20.83 |
| 10. Number of phases | : 1 |
| 11. Frequency (Hz.) | : 50 Hz |
| 12. Type of cooling | : ONAN |
| 13. Temperature rise of oil/winding | : 35°C/40°C |
| 14. Percentage Impedance | : 2.5% (+ IS Tolerance) |
| 15. Primary winding conductor | : Polyesterimide enamel (Class-H) Copper wire,
Bare dia. 0.83 mm |
| 16. Secondary winding conductor | : Polyesterimide enamel (Class-H) Copper Strip,
Bare size (5.0 mm x 2.9 mm) |
| 17. Quantity of oil (Litre) | : 13 |
| 18. Weight of oil (kg.) | : 11 |
| 19. Weight of core coil assembly (kg.) | : 47 |
| 20. Total weight (kg.) | : 85 |
| 21. Polarity | : Subtractive |
| 22. Vector group | : 1-Phase |
| 23. Year of manufacture | : 2018 |
| 24. Insulation Level L.V. | : 03 kVrms |
| 25. Total losses at 75°C (Watts) | : 35 Max. (at 50 % load)
: 95 Max. (at 100 % load) |


PREPARED BY


CHECKED BY

TC 2557923



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.



EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010640		Sheet : 4 OF 25
DATE : 19.06.2018		
	TEST DETAILS	TEST SPECIFICATION
1.	Measurement of short-circuit impedance and load loss at 50 percent and 100 percent load	As per cl.no.21.2.c of IS 1180 (Part 1):2014
2.	Measurement of no-load loss and current	As per cl.no.21.2.d of IS 1180 (Part 1):2014
3.	Total losses at 50 % load	As per cl.no. 8.8 of IS 1180 (Part 1):2014
4.	Total losses at 100 % load	As per cl.no. 8.8 of IS 1180 (Part 1):2014
5.	No load current at 112.5 percent Voltage	As per cl.no.21.4.c of IS: 1180 (PART 1):2014
6.	Temperature-rise test	As per customer's requirement, testing procedure followed as per Cl.no.21.3.b of IS1180(Part 1):2014
7.	Oil leakage test	As per cl.no.21.2.j of IS 1180 (Part 1):2014
8.	Pressure test (routine test)	As per cl.no.21.2.h of IS 1180 (Part 1):2014
9.	Pressure test (type test)	As per cl.no.21.3.d of IS 1180 (Part 1):2014
10.	Determinations of sound levels	As per customer's requirement, testing procedure followed as per cl. no. 21.4.a of IS 1180 (Part 1) : 2014 & Cl. No.13 of IS 2026(Part 10): 2009
11.	Measurement of the Harmonics of the No-load current	As per customer's requirement testing procedure followed as per cl.no.10.6. of IS: 2026 (PART 1)-2011
12.	Lightning impulse test	As per cl.no.21.3.a of IS 1180 (Part 1):2014 And test voltage specified by the customer(Test procedure was followed as per cl.no.14 of IS 2026 (Part 3) : 2009
13.	Short-circuit withstand test	As per cl.no.17 & 21.3 c of IS 1180 (Part 1) :2014
14.	Paint adhesion test	As per cl.no.21.4 d of IS 1180 (Part 1): 2014
15.	Total dry film paint thickness	As per cl.no.15.5 & table 12 of IS 1180 (Part 1) :2014
PREPARED BY 		CHECKED BY 

TC 2557015





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010640		Sheet : 5 OF 25		
DATE : 19.06.2018				
Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained Value	Remarks
1.	<p>Measurement of short-circuit impedance and load loss at 50 percent and 100 percent load : (As per cl.no.21.2.c of IS 1180 (Part 1): 2014)</p> <p>At 50% load : Tested with 0.3909 Amps (on HV side) Frequency : 50.013 Hz Top oil temperature : 35.6°C</p> <p style="padding-left: 40px;">Test current (Amps) 0.3909 Impedance voltage (Volts) 74.640 Measured load loss (Watts) 14.91 Impedance voltage (%) (Computed to 50% load) At 35.6°C 1.185 At 75°C 1.197 Load loss (Watts) (Computed to 50% load) At 35.6°C 15.147 At 75°C 17.314</p> <p>At 100% load : Tested with 0.7894 Amps (on HV side) Frequency : 50.013 Hz Top oil temperature : 35.9°C</p> <p style="padding-left: 40px;">Test current (Amps) 0.7894 Impedance voltage (Volts) 150.72 Measured load loss (Watts) 60.76 Impedance voltage (%) (Computed to 100% load) At 35.9°C 2.375 At 75°C 2.467 Load loss (Watts) (Computed to 100% load) At 35.9°C 60.852 At 75°C 69.475</p>	<p>---</p> <p>---</p> <p>2.5 (±10%)</p> <p>---</p>		<p>---</p> <p>Conforms</p>

TC 2557803

PREPARED BY *[Signature]*

CHECKED BY *[Signature]*



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.



EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010640		Sheet : 6 OF 25		
DATE : 19.06.2018				
Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained Value	Remarks
2.	Measurement of no-load loss and current : (As per cl.no.21.2.d of IS 1180 (Part 1): 2014) Tested with average 239.97 Volts (on LV side) Frequency : 50.054 Hz RMS voltage (Volts) No-load current (Amps) Measured no-load loss (Watts) Corrected no-load loss (Watts)	--	240.11 0.08292 15.41 15.401	--
3.	Total losses at 50 % load (Watts) : (As per cl.no.8.8 of IS 1180 (Part 1):2014)	Max. 35	32.715	Conforms
4.	Total losses at 100 % load (Watts) : (As per cl.no.8.8 of IS 1180 (Part 1):2014)	Max. 95	84.876	Conforms
5.	No load current at 112.5 percent Voltage : (As per cl.no.21.4.c of IS: 1180 PART 1-2014) Test voltage of 112.5 percent of rated voltage at rated frequency was applied to the L.V. winding terminals and H.V. winding terminals were kept open circuited. No load current was recorded. Test voltage (Volts) No load current (Amps) No Load Current (%)	Max. 6.0	270.50 0.1107 0.531	Conforms
PREPARED BY 		CHECKED BY 		

TC 2557802



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010640		Sheet : 7 OF 25		
DATE : 19.06.2018				
Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained value	Remarks
6.	<p>Temperature-rise test : (As per customer's requirement, testing procedure followed as per Cl.no.21.3.b of IS1180(Part 1):2014)</p> <p>Before starting test, the dimensions of tank were measured & recorded.</p> <p>Size of tank : H-400 mm, Diameter-285 mm</p> <p>Specified losses fed for temperature-rise test were 95 Watts.</p> <p>Specified losses were fed to the transformer (i.e. Supply was connected to HV winding and LV winding kept short-circuited) till steady state temperature-rise was attained. Top oil temperature was recorded hourly. After steady state condition, the losses were brought down in reference to the rated current one hour prior to shut down.</p> <p>At the shutdown, the hot windings resistance were measured and temperature-rise calculated.</p>			Conforms
	A) Top oil temperature-Rise :	Max. 35°C	16.2°C	
	B) Winding Temperature Rise (Resistance method)			
	1) HV Winding :	Max. 40°C	25.3°C	
	2) LV Winding :	Max. 40°C	28.0°C	
	C) Ambient temperature at shutdown :		30.1°C	
	D) Time of Shutdown(Hrs) :		8:30	

TC 2557801

PREPARED BY 

CHECKED BY 



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.



EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010640		Sheet : 8 OF 25		
DATE :19.06.2018				
Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained Value	Remarks
7.	Oil leakage test : (As per cl.no.21.2.j of IS 1180 (Part1: 2014)) The assembled transformer with all fittings including bushings in position was tested at a pressure at the top equivalent to the head that was available at the base of the tank for 6 hours.	There should be no leakage at any point	No leakage observed.	Conforms
8.	Pressure test (routine test) : (As per cl.no.21.2.h of IS 1180 (Part 1: 2014)) The transformer was tested at an air pressure of 35 kPa above atmosphere pressure maintained inside the tank for 10 min.	There should be no leakage at any point.	No leakage observed.	Conforms
9.	Pressure test (Type test) : (As per cl.no.21.3.d of IS 1180 (Part 1: 2014)) The transformer was tested at an air pressure OF 100 kPa above atmosphere pressure maintained inside the tank for 30 min.	There should be no leakage at any point & no deformation of tank	No leakage & No deformation of tank observed.	Conforms
PREPARED BY 		CHECKED BY 		

TC 2557805



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO: RP-1819-010640

DATE: 19.06.2018

SHEET : 9 OF 25

Particulars of Tests & Cl. No.:

10) Determinations of sound levels [A- Weighted Sound Power Level Measurement]
[As per customer's request, testing procedure followed as per as per Cl. No. 21.4.a of IS 1180 (Part 1):2014 & Cl. No. 13 of IS 2026 (Part 10): 2009]

Condition of transformer Transformer was energized at no load condition & excited at the rated voltage of sinusoidal waveform & rated frequency.

Details of equipment used: **Name:** Sound level meter **Make:** Lutron
Meter Type: Type 1 **Serial No.:** I.62852
Calibration Report No. & Date: NCQC-M/141117/01, Dt. 27/11/2017

TEST RESULTS:

A-Weighted sound pressure levels of the background noise

Sr. No.	Measurement Locations (Refer Sketch Below)	At the start of test dB(A)	At the end of test dB(A)
1	A	45.9	45.2
2	B	45.7	45.4
3	C	45.6	45.6
4	D	45.7	45.3
5	E	45.1	45.4
6	F	45.4	45.6
7	G	45.7	45.9
8	H	45.6	45.7
9	I	45.5	45.4
10	J	45.1	45.1
Arithmetic Average \bar{L}_{bgA}		45.5	45.5

A-Weighted sound pressure levels at energized condition L_{pAi}

Sr. No.	Measurement Locations (Refer Sketch Below) dB(A)	L_{pAi} dB(A)
1	A	46.7
2	B	47.1
3	C	45.9
4	D	45.4
5	E	45.6
6	F	45.6
7	G	45.9
8	H	46.1
9	I	46.4
10	J	45.4
Arithmetic Average \bar{L}_{pA0}		46.1

PREPARED BY

CHECKED BY

TC 2557808



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



TEST REPORT NO: RP-1819-010640

DATE: 19.06.2018

SHEET: 10 OF 25

TEST PARAMETERS:

Measurement distance : 1 m,

Microphone Spacing: 1 m

Measurement made : Half of the height of the transformer tank

Method followed: Sound pressure measurement as per Cl. No. 11, 11.3 & Table 2 of IS 2026 (Part 10): 2009.

Length of prescribed contour: 9.76 m

Transformer Tank Height: 0.400 m


Person present during sound level measurement: 3

A-Weighted sound pressure level ($\overline{L_{pA0}}$):	46.1 dB(A)
---	------------

Corrected average A-weighted sound pressure level ($\overline{L_{pA}}$):	37.2 dB(A)
--	------------

Calculated A- weighted sound power level (L_{WA}) :	44.1 dB(A)
---	------------

REMARKS: 1) Guaranteed value of sound pressure level is considered as 48 db (A) as mentioned in customer's letter.
2) Transformer conforms to the requirement of guaranteed value of sound pressure level



Sketch showing the locations of sound measurement


PREPARED BY


CHECKED BY

TC 2557807



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33



Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



SHEET No. 11 OF 25

REPORT NO.: RP-1819-010640		Date: 19.06.2018		
Sr. No.	Particulars of test and clause no.	Requirement as per specification.	Obtained value	Remarks
11	Measurement of the Harmonics of the No-load current (As per customer's request testing procedure followed as per cl. no. 10.6 of IS 2026 (Part 1):2011)	The harmonics of the no-load current shall be measured and magnitude of the harmonics shall be expressed as a percentage of the fundamental component.	Refer table 1 for individual current harmonics components & individual voltage harmonics components measured at LV side at rated voltage i.e. 240 V Current THD: 30.03% Voltage THD: 0.85%	---
Prepared by: 		Checked by: 		

TC 2557922



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



SHEET No. 12 OF 25

REPORT NO.: RP-1819-010640

Date: 19.06.2018

TABLE-1 : Harmonics in voltage and current (as a percentage of fundamental)

Harmonic order	Current I _R in %	Current I _R in Amps	Voltage V _{RY} in %
1	100.00	0.0754	100.00
2	2.52	0.0019	0.02
3	28.91	0.0218	0.15
4	1.26	0.00095	0.01
5	6.80	0.00513	0.69
6	0.42	0.00032	0.02
7	2.92	0.00220	0.32
8	0.27	0.00020	0.01
9	0.66	0.00050	0.01
10	0.20	0.00015	0.01
11	0.23	0.00017	0.07
12	0.27	0.00020	0.01
13	1.35	0.00102	0.03
14	0.08	0.00006	0.01
15	0.25	0.00019	0.05
16	0.17	0.00013	0.01
17	0.69	0.00052	0.12
18	0.12	0.00009	0.00
19	0.16	0.00012	0.02
20	0.16	0.00012	0.01
21	0.12	0.00009	0.02
22	0.07	0.00005	0.00
23	0.09	0.00007	0.02
24	0.17	0.00013	0.02
25	0.36	0.00027	0.03
THD %	30.03		0.85
Parameter measured	0.08 A		240.11 V

Prepared by

Checked by

TC 2551624





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO.: RP-1819-010640
DATE : 19/06/2018

SHEET NO.: 13 of 25

12.Lightning Impulse Test (As per Cl. No.21.3.a of IS 1180 (part 1) : 2014 Amendment 1 & 2 & test procedure was followed as per IS : 2026-(part- III), 2009 cl. No. 14

Waveform	Comment	Ut / kVp	T1 / μ s	T2 / μ s	Tc / μ s
----------	---------	----------	--------------	--------------	--------------

1.1 POLE					
1	LI RW	-49.253	1.222	43.944	
2	100% LI FW	-75.194	1.224	44.165	
3	LI CRW	-48.603	1.239		2.927
4	110% LI CFW	-83.710	1.268		2.744
5	110% LI CFW	-81.950	1.262		3.001
6	100% LI FW	-75.929	1.225	44.138	
7	100% LI FW	-75.615	1.226	44.113	

REMARKS: From the observation of enclosed oscillographic records , it is concluded that the transformer **conforms** to the requirements of the above mentioned standard with respect to the test carried out.


PREPARED BY


CHECKED BY

TC 2557035





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO.: RP-1819-010640

SHEET NO.: 14 of 25

DATE : 19/06/2018





Fig.: 1
 $U_p = -49.25 \text{ kV}$
 $T_1 = 1.22 \text{ } \mu\text{s}$
 $T_2 = 43.94 \text{ } \mu\text{s}$
 $T_c = \text{ } \mu\text{s}$



Comment: LI RW





Fig.: 2
 $U_p = -75.19 \text{ kV}$
 $T_1 = 1.22 \text{ } \mu\text{s}$
 $T_2 = 44.17 \text{ } \mu\text{s}$
 $T_c = \text{ } \mu\text{s}$



Comment: 100% LI FW

PREPARED BY *AKASH*

CHECKED BY *AKASH*

TC 2557907



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO.: RP-1819-010640

SHEET NO.: 15 of 25

DATE : 19/06/2018





Fig.: 3
 $U_p = -48.60 \text{ kV}$
 $T_1 = 1.24 \text{ } \mu\text{s}$
 $T_2 = \text{ } \mu\text{s}$
 $T_c = 2.93 \text{ } \mu\text{s}$



Comment: LI CRW





Fig.: 4
 $U_p = -83.71 \text{ kV}$
 $T_1 = 1.27 \text{ } \mu\text{s}$
 $T_2 = \text{ } \mu\text{s}$
 $T_c = 2.74 \text{ } \mu\text{s}$



Comment: 110% LI CFW

TC 2557908

PREPARED BY

CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO.: RP-1819-010640

SHEET NO.: 16 of 25

DATE : 19/06/2018





Fig.: 5

$U_p = -81.95 \text{ kV}$

$T_1 = 1.26 \text{ } \mu\text{s}$

$T_2 = \mu\text{s}$

$T_c = 3.00 \text{ } \mu\text{s}$



Comment: 110% LI CFW





Fig.: 6

$U_p = -75.93 \text{ kV}$

$T_1 = 1.22 \text{ } \mu\text{s}$

$T_2 = 44.14 \text{ } \mu\text{s}$

$T_c = \mu\text{s}$



Comment: 100% LI FW

TC 2557909

PREPARED BY

[Signature]

CHECKED BY

[Signature]



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO.: RP-1819-010640
DATE : 19/06/2018

SHEET NO.: 17 of 25




Fig.: 7
 $U_p = -75.61 \text{ kV}$
 $T_1 = 1.23 \mu\text{s}$
 $T_2 = 44.11 \mu\text{s}$
 $T_c = \mu\text{s}$

Comment: 100% LI FW

M. J. Shah
PREPARED BY

[Signature]
CHECKED BY

TC 2557910



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010640

SHEET 18 OF 25

DATE: 19.06.2018

13. Short-circuit withstand test

(As per Cl. No. 17 & 21.3 c of IS 1180 (Part 1): 2014)

ROUTINE TEST RESULTS BEFORE SHORT CIRCUIT

a) MEASUREMENT OF WINDING RESISTANCE

Measurement at oil temperature: 35.5°C	
LV Winding resistance (mΩ)	HV Winding resistance (Ω)
2.1-2.2(n)	1.1-1.2(N)
61.530	51.890

b) MEASUREMENT OF VOLTAGE RATIO AND CHECK OF POLARITY

Polarity: Subtractive was verified

Measured turns ratio between Terminals	Rated turns Ratio	Difference (%)
1.1-1.2(N)/2.1-2.2(n)		
26.465	26.463	0.008

c) MEASUREMENT OF SHORT-CIRCUIT IMPEDANCE AND LOAD LOSS (at 100 % load)

Oil temperature: 36.0°C

Test current (Amp.)	Impedance voltage (V)	Frequency (Hz.)	Load loss measured (Watts)	Impedance Voltage (%Z) at 50 Hz.	Load loss computed at 75°C (Watts)	%Z at 75°C
0.790	149.724	49.768	60.042	2.368	68	2.458

d) MEASUREMENT OF LOAD LOSS (at 50 % load)

Oil temperature: 36.0°C

Test current (Amp.)	Impedance voltage (V)	Frequency (Hz.)	Load loss measured (Watts)	Load loss computed at 75°C (Watts)
0.394	74.638	49.795	14.915	17

TC 2554284


PREPARED BY


CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010640

SHEET 19 OF 25

DATE: 19.06.2018

e) MEASUREMENT OF NO-LOAD LOSS AND CURRENT

Oil temperature: 36.0°C

Applied Voltage (V)	Current (Amp.)	Frequency (Hz.)	Losses Measured (Watts)
240.082	0.083	50.012	15

- Total losses at 75°C: 32 Watts (at 50 % load)
- Total losses at 75°C: 83 Watts (at 100% load)

f) MEASUREMENT OF INSULATION RESISTANCE

Oil temperature: 35.5°C

	Applied DC Voltage (V)	IR value (MΩ)
HV to LV winding	2500	> 2000
HV winding to LV + EARTH	2500	> 2000
LV winding to HV + EARTH	500	> 2000

g) INDUCED OVER-VOLTAGE WITHSTAND TEST

Sr. No.	Test	Applied voltage (V)	Applied Freq. (Hz.)	Duration (sec.)	Remarks
1.	Between LV windings with HV terminal open & neutral terminal earthed.	756	150	40	Withstood

h) SEPARATE-SOURCE VOLTAGE WITHSTAND TEST

Sr. no.	Test	Applied voltage (kV)	Duration (sec.)	Remarks
1.	Between HV winding and LV winding connected to the tank and earth	03	60	Withstood
2.	Between LV winding and HV winding connected to the tank and earth	03	60	Withstood

TC 2554202


PREPARED BY


CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010640

SHEET 20 OF 25

DATE: 19.06.2018

SHORT-CIRCUIT WITHSTAND TEST:

The verification of short-circuit withstand test was performed on the transformer by connecting the secondary winding to single phase of the source and primary winding short circuited using synchronization switch. The test conducted with short circuiting of primary winding; follow the application of the voltage to the secondary winding of transformer as per schematic circuit diagram No. OLSC/DTC/05.

Condition of the equipment under test: As after routine tests.

Supply Frequency: 50 Hz.

Test No.	Oscillogram No.	Applied voltage (Vrms)	Short circuit current on LV (A)		Duration (sec.)	Remarks
			Peak	RMS		
1.	0143/01	-	1163	682	0.1	Calibration Shot
2.	0143/02	240	1438	855	0.5	No Abnormality
3.	0143/03	240	1430	850	0.5	No Abnormality
4.	0143/04	240	1413	856	0.5	No Abnormality
5.	0143/05	240	1386	841	2.0	Thermal shot No Abnormality


PREPARED BY


CHECKED BY

TC 2554203





ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



REPORT NO.: RP-1819-010640

SHEET 21 OF 25

DATE: 19.06.2018

Measurement of the % reactance during the short circuit test

LV winding was short circuited. AC supply was connected to HV winding to pass test current. Before the short circuit test and after each shot, the percentage reactance was measured.

Sr. No.	Measurement performed		Measured value of % reactance at 50 Hz.	%Change in % reactance
1.	Before test		2.04	-
2.	After the test no.	2.	2.07	1.47
3.	After the test no.	3.	2.07	1.47
4.	After the test no.	4.	2.08	1.96
5.	After the test no.	5.	2.08	1.96


PREPARED BY


CHECKED BY

TC 2554204





ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010640

SHEET 22 OF 25

DATE: 19.06.2018

ROUTINE TEST RESULTS AFTER SHORT CIRCUIT

a) MEASUREMENT OF WINDING RESISTANCE

Measurement at oil temperature: 34.5°C	
LV Winding resistance (mΩ)	HV Winding resistance (Ω)
2.1-2.2(n)	1.1-1.2(N)
63.405	51.845

b) MEASUREMENT OF VOLTAGE RATIO AND CHECK OF POLARITY

Polarity: Subtractive was verified

Measured turns ratio between Terminals	Rated turns Ratio	Difference (%)
1.1-1.2(N)/2.1-2.2(n)		
26.465	26.463	0.008

c) MEASUREMENT OF SHORT-CIRCUIT IMPEDANCE AND LOAD LOSS (at 100 % load)

Oil temperature: 34.7°C

Test current (Amp.)	Impedance voltage (V)	Frequency (Hz.)	Load loss measured (Watts)	Impedance Voltage (%Z) at 50 Hz.	Load loss computed at 75°C (Watts)	%Z at 75°C
0.789	152.531	49.917	60.616	2.409	70	2.503

d) MEASUREMENT OF LOAD LOSS (at 50 % load)

Oil temperature: 34.7°C

Test current (Amp.)	Impedance voltage (V)	Frequency (Hz.)	Load loss measured (Watts)	Load loss computed at 75°C (Watts)
0.394	76.223	49.904	15.163	17

TC 2554205


PREPARED BY


CHECKED BY





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010640

SHEET 23 OF 25

DATE: 19.06.2018

e) MEASUREMENT OF NO-LOAD LOSS AND CURRENT

Oil temperature: 34.7°C

Applied Voltage (V)	Current (Amp.)	Frequency (Hz.)	Losses Measured (Watts)
240.330	0.085	50.006	15

- Total losses at 75°C: 32 Watts (at 50 % load)
- Total losses at 75°C: 85 Watts (at 100% load)

f) MEASUREMENT OF INSULATION RESISTANCE

Oil temperature: 34.5°C

	Applied DC Voltage (V)	IR value (MΩ)
HV to LV winding	2500	> 2000
HV winding to LV + EARTH	2500	> 2000
LV winding to HV + EARTH	500	> 2000

g) INDUCED OVER-VOLTAGE WITHSTAND TEST

Sr. No.	Test	Applied voltage (V)	Applied Freq. (Hz.)	Duration (sec.)	Remarks
1.	Between LV windings with HV terminal open & neutral terminal earthed.	756	150	40	Withstood

h) SEPARATE-SOURCE VOLTAGE WITHSTAND TEST

Sr. no.	Test	Applied voltage (kV)	Duration (sec.)	Remarks
1.	Between HV winding and LV winding connected to the tank and earth	03	60	Withstood
2.	Between LV winding and HV winding connected to the tank and earth	03	60	Withstood

Observation after test: The transformer was untanked and inspected.

- 1) Condition of conductor, core and clamping:
 - No visible damage, deformation or displacement.
- 2) Condition of oil : Clear

Results: 1) % Change in % reactance is within tolerance limits as per standard.

- 2) The results of routine tests carried out before and after the short-circuit withstand test found within limits as per standard.

TC 2554206

PREPARED BY

CHECKED BY



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.



EPABX: +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33,

Fax : +91 (0265) 2638382,

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT No.: RP-1819-010640		DATE: 19-06-2018		SHEET 24 OF 25	
Sr. No.	Particular of Tests and Cl. No.	Requirements as per specification	Obtained value	Remarks	
14.	Paint Adhesion Test at 37°C & 11 % RH Test Method A – X-cut tape test (Test procedure followed as per ASTM D 3359-2017, Cl. No. 8) Cl. No. 21.4.d of IS 1180 (Part 1): 2014 - Adhesion strength of pressure sensitive tape 6.7 N/cm.	--	Observation 1-5A – No peeling or removal was observed at the location. Observation 2-4A – Trace peeling or Removal along incisions or at their intersection between the first coat and second coats. Observation 3-4A – Trace peeling or Removal along incisions or at their intersection between the first coat and second coats.	--	
PREPARED BY 				CHECKED BY 	

2244511

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX: +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33,

Fax : +91 (0265) 2638382,

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010640		Sheet : 25 of 25		
DATE : 19.06.2018				
Sr. No.	Particulars of test and Cl. No.	Requirement as per specification	Obtained Value	Remarks
15	Total Dry Film Paint Thickness ➤ Cl.no.15.5 & Table 12			
	Inside Tank	35.0 microns [Min.]	25.3 microns [#]	Does not Conform
	Outside Tank	80.0 microns [Min.]	83.8 microns [#]	Conforms
Note:1] Inside Paint Type of Tank: Hot Oil Resistant Paint 01 Coat; Outside Paint Type of Tank: Epoxy (Primer) 01 Coat with Polyurethane (Finish Coat) 02 Coats as mentioned in customer's letter. 2] '#' The result obtained is an average of twelve readings at different locations. 3] Testing was carried out at 40 ± 1°C.				
<u>S.P. Shah</u> PREPARED BY		<u>Nish</u> CHECKED BY		



2237206



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010640

DATE: 19.06.2018



TC 2515150

OSCILLOGRAM NO. : 0143/01





ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : <http://www.erda.org>




REPORT NO.: RP-1819-010640

DATE: 19.06.2018



TC 2515151

OSCILLOGRAM NO. : 0143/02





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010640

DATE: 19.06.2018



TC 2530287

OSCILLOGRAM NO. : 0143/03





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : <http://www.erda.org>




REPORT NO.: RP-1819-010640

DATE: 19.06.2018



TC 2515152

OSCILLOGRAM NO. : 0143/04





Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-010640

DATE: 19.06.2018



TC 2515153

OSCILLOGRAM NO.: 0143/05



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




REPORT NO.: RP-1819-010640

DATE: 19.06.2018



DISTRIBUTION TRANSFORMER			
RAJASTHAN POWERGEN TRANSFORMER PVT. LTD.			
JALORE, RAJASTHAN			
1 PHASE TRANSFORMER			
STANDARD IS	1180 (Part-1)/2014	ENERGY EFFICIENCY LEVEL	2
NVA	5	MAX TOTAL LOSS AT 50% RATED LOAD W	35
VOLTS AT NO LOAD (V)	HV 11000 / 3	MAX TOTAL LOSS AT 100% RATED LOAD W	95
	LV 240	TYPE OF COOLING	ONAN
BIL (kV Peak)	HV 75	TEMP RISE OIL °C	35
	LV NA	WDG °C	40
CURRENT (A)	HV 0.79	MASS OF OIL	kg 11
	LV 20.83	TOTAL MASS	kg 85
FREQUENCY	Hz 50	VOLUME OF OIL	Ltr 13
VECTOR GROUP	1-PHASE	MONTH & YEAR OF MFG	12018
IMPEDANCE VOLT %	2.5	SERIAL NO.	
DISPATCH DATE		EXPIRY DATE G.P.	
CONDUCTOR MATERIAL	COPPER	S.C. TEST IS 1180/2014	
CUSTOMER	JVVNL		
P.O. No.			
MADE IN INDIA			
SUBTRACTIVE POLARITY			

TC 2546899



- CB - 66 kV CIRCUIT BREAKER
- TR - 66 kV/11 kV TRANSFORMER
- ISO - ISOLATOR
- BCB - BACKUP CIRCUIT BREAKER
- MS - MASTER CIRCUIT BREAKER
- Z - SOURCE SIDE IMPEDANCE
- X - REACTANCE
- R - RESISTANCE
- SC/TR - SHORT CIRCUIT TRANSFORMER
- HTMS - H.T. MAKE SWITCH
- T.T. - TEST TRANSFORMER
- S - CURRENT MEASURING DEVICE

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION	
SCHEMATIC CIRCUIT DIAGRAM	
DRN. BY	DATE
S.B.S.	A.V.C. 30.9.01
DRG. NO. OLSC/DTC/05.	



REPORT NO.: RP-1819-010640
 DATE: 19.06.2018

4 HOLES
of Ø3.6mm

DISTRIBUTION TRANSFORMER


RAJASTHAN POWERGEN TRANSFORMER PVT LTD
JALORE, RAJASTHAN

1 PHASE TRANSFORMER

STANDARD	IS : 1180 (Part-1)/2014	ENERGY EFFICIENCY LEVEL	2
KVA	5	MAX. TOTAL LOSS AT 50% RATED LOAD W	35
VOLTS AT NO LOAD (V)	HV 11000 / $\sqrt{3}$	MAX. TOTAL LOSS AT 100% RATED LOAD W	95
	LV 240	TYPE OF COOLING	ONAN
BIL (kV Peak)	HV 75	TEMP. RISE	OIL °C 35
	LV NA		WDG °C 40
CURRENT (A)	HV 0.79	MASS OF OIL	kg 11
	LV 20.83	TOTAL MASS	kg 85
FREQUENCY	Hz 50	VOLUME OF OIL	Ltr 13
VECTOR GROUP	1-PHASE	MONTH & YEAR OF MFG.	/2018
IMPEDANCE VOLT %	2.5	SERIAL NO.	RPTPL/5 KVA/CU/18-19/001
DISPATCH DATE	-	EXPIRY DATE G.P.	-
CONDUCTOR MATERIAL	COPPER		
CUSTOMER	JVVNL		
P.O. No.			

MADE IN INDIA

SUBTRACTIVE POLARITY



NOTES :-


- 1- ** MARKED ITEMS SHOULD BE PUNCHED AT THE TIME OF DISPATCH.
- 2- ALL LETTERS, FIGURES ETC. TO BE ENGRAVED & POLISHED BLACK.
- 3- MATERIAL - STAINLESS STEEL 0.9 WITH TOLERANCE ± 0.1 MM. THICK.
- 4- ALL DIMENSIONS ARE IN MM.

01	28.05.18				
00	20.12.17				ORIGINAL ISSUE.
Rev	Date	Draw	Checked	Approved	Description

	Title : RATING & DIAGRAM PLATE			Work Order : -----	
	Rating : 5 KVA, 11/√3/0.240 KV, 1Ø, 50 Hz, TRF.	Drawing No. : RPTPL/RP/04		Rev. : 01	Sheet No. : 01
RAJASTHAN POWERGEN TRANSFORMER P. LTD. Karola - Bhinmal Road, Karola, Sanchore - 343041 Dist - Jalore, Rajasthan (India)			All dimensions are in millimeters unless otherwise stated. If in doubt - Please Ask !		Scale : NTS

Report No.: RP-1819-010610
19-6-18
5 KVA 20 meter





HV SIDE

LV SIDE

SIDE VIEW (MOUNTING)

Test Report No. RP-1819-010640
 Date 19.06.2018
 Product 5.5MVA
 Verified by S. S. R. P.
 Verification of this drawing by S. S. R. P.
 All important dimensional checks are marked with *
 All dimensions are marked with *

Tank diameter (mm)	285
Tank height (mm)	400

WEIGHTS / QTY.	
TOTAL TRANSFORMER OIL	Ltrs. 13
TRANSFORMER OIL	Kg. 85
TANK & FITTINGS	Kg. 11
CORE COIL ASSY	Kg. 47

Locking height (mm)	260
LV hole height (mm)	320
Oil level indicator (mm)	335
Breaker handle height (mm)	NA

AIR CLEARANCES (MM)		
VOLTAGE	H.V.	L.V. (enclosed)
PHASE TO PHASE	NA	NA
PHASE TO EARTH	140	20

S. No.	Technical Plate	Qty.
21	TECHNICAL PLATE	1
20	TOP COVER ANTI THEFT BOLT	1
19	-	-
18	OIL FILLING HOLE WITH WELDED COVER AND WITH EXTENDED PIPE as per IS 114"	1
17	THERMOMETER POCKET WITH CAP	1
16	OIL LEVEL GAUGE	1
15	Lifting lugs for complete unit	2
14	Pole mounting bracket (as per spec)	2
13	Signal light	1
12	MCCB*	1

S. No.	Description	Qty.
11	Tank Earthing terminal	2
10	Pressure relief device	1
9	L.V. Bushing	2
8	Top cover rim	-
7	H.V. Neutral bushing.	1
6	H.V. Bushing	1
5	Rating & terminal marking plate	1
4	H.V. Terminal marking	1 set
3	L.V. Terminal marking	1 set
2	Earthing terminal (L.V box)	2
1	LV MCCB box*	1

- Notes :-
- All dimensions are in mm. Tolerance $\pm 5\%$
 - This drawing shows only general disposition of fittings.
 - Tank side plate - 2.0 mm. Thk.M.S.
 - Top & bottom - 2.5 mm. Thk.M.S.
- 4- Paint Shade : Olive Green Color conforming to No. 220 of IS : 5 / 1961
- * Not provided at the time of Type Testing



OUTLINE GENERAL ARRANGEMENT

Title: ---

Rating: 5 KVA, 11/0.240 KV, 50 Hz, TRF.

Drawing No.: RPTPL/OGA/04

Rev.: 01

Sheet No.: 01


Total Sheets: 01

Scale: N.T.S

All dimensions are in millimeters unless otherwise stated. If in doubt - Please Ask!

RAJASTHAN POWERGEN TRANSFORMER P. LTD.
 Karol - Bihmal Road, Karol, Sanchore - 343041 Dist - Jaipur, Rajasthan (India)

Rev	Date	Draw	Checked	Approved	Description
01	28.05.2018				ORIGINAL ISSUE.
00	20.12.2017				



Test Report No. RP-UPV-010640
 Date 19.05.2018
 Product S 100A 107
 Verified by [Signature]
 Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with red.

CONDUCTOR SIZE	
LV	HV
Bare 2.9	0.83 Dia
Covered 5.1 x 3.0	0.91 Dia
Copper	Polyesterimide enameled (Class B)
Configuration	1W x 1D

CORE SIZE	
Core Window Height	147 mm
Core build up	2 x 34 mm
Core Sheet width	130 mm

COIL DIMENSIONS	
LV	HV
ID 74 x 136	107 x 169
OD 99 x 161	152 x 214
AXIAL HT.	137

SL.No.	Description	Qty.
11	HV LEAD	-
10	LV LEAD	-
9	CORE (CRGO CORE)	2 set
8	LV & HV COIL (COPPER)	1 set
7	BOTTOM CORE CLAMP	1
6	COIL SEPARATOR	1 set
5	CHANNEL SEPARATOR	1 set
4	END INSULATION	1 set
3	TOP CORE CLAMP	1
2	LOCKING CUM LIFTING LUG	2
1	HV FUSE LINK*	1

LIST OF FITTINGS

- Notes :-
 1- All dimensions are in mm. Tolerance ±5%
 2- This drawing shows only general disposition of fittings.
 * Not provided at the time of Type Testing



INTERNAL CONSTRUCTIONAL DETAIL DRAWING

Rating: 5 KVA, 11/√3/0.240 KV, 10, 50 Hz, TRF.

Drawing No.: RPTPL/IC/04

Rev.: 01

Sheet No.: 01

Total Sheets: 01

Scale: N.T.S.

Work Order: ---

RAJASTHAN POWERGEN TRANSFORMER P. LTD.
 Karol - Bhanmal Road, Karol, Sanchore - 343004 Dist - Jaipur, Rajasthan (India)